



Thermor

TECHNICAL DATAS

Intended for professionals.

Completed by the instructions manuals 2710 & 2711

AUREA 2



Air/Water Monobloc Heat Pump

Hydraulic unit :

☐ 024385

☐ 024388

☐ 024294




DHW Hydraulic unit :

☐ 024386

☐ 024389

☐ 024295



Compact indoor unit :

☐ 024384

Outdoor unit :

☐ 701403

☐ 701404

☐ 701405

☐ 701406


☐ 701410

☐ 701412

☐ 701407

☐ 701411

☐ 701413



Content

General description	3
Table of dimensions and weight	3
Volume de l'installation chauffage	4
Volume of the heating system	4
Drawing of the heat pump	5
Installing the outdoor unit	8
Installing the indoor unit	10
Diameter connections	12
ErP specifications	12
Performances	14
Performances tables in heating mode without electrical back-up	14
Performances tables in heating mode including progressively electrical backup	38
Performances tables in cooling mode	70
Sound power - Outdoor unit	82
Hydraulic circuit	86
Outdoor unit available hydronic pressures and flow rates.	86
Options	110

■ 230V 1N~

		<i>Indoor unit</i>		
<i>Outdoor unit</i>		Compact	1S	DHW
Model	Code	024384	024385	024386
AUREA 2-3	701403	527366	527403	527414
AUREA 2-4	701404	527367	527404	527415
AUREA 2-5	701405	527368	527405	527416
AUREA 2-7	701406	527369	527406	527417
AUREA 2-9	701410	527371	527408	527419
AUREA 2-12	701412	527372	527409	527420

■ 400V 3N~

		<i>Indoor unit</i>				
<i>Outdoor unit</i>		Compact	1S		DHW	
Model	Code	024384	024388	024294	024389	024295
AUREA 2-7TRI	701407	527373	527410	-	527421	-
AUREA 2-9TRI	701411	527375	-	527412	-	527423
AUREA 2-12TRI	701413	527376	-	527413	-	527424

General description

► Table of dimensions and weight

For more information, please refer to the instructions manuals.

Outdoor unit		OU AUREA 2								
Type		230V 1N~						400V 3N~		
Reference		3	4	5	7	9	12	7TRI	9TRI	12TRI
		701403	701404	701405	701406	701410	701412	701407	701411	701413
Dimensions (mm)	<i>h</i>	795				883		795	883	
	<i>l</i>	1319				1449		1319	1449	
	<i>p</i>	516				595		516	595	
Weight (kg)		94		105		131	136	122	147	155

Indoor unit		AUREA 2 COMPACT								
Type		230V 1N~						400V 3N~		
Reference		3	4	5	7	9	12	7TRI	9TRI	12TRI
		024384								
Dimensions (mm)	<i>h x l x p</i>	483 x 370 x 222								
Weight (kg)		10								

Indoor unit		AUREA 2 (1N~)						AUREA 2 (3N~)		
Type		230V 1N~						400V 3N~		
Reference		3	4	5	7	9	12	7TRI	9TRI	12TRI
		024385						024388 (AE 6kW)	024294 (AE 9kW)	
Dimensions (mm)	h x l x p	768 x 448x 483								
Weight (kg)		34 / 50								

Indoor unit		AUREA 2 DHW (1N~)						AUREA 2 DHW (3N~)		
Type		230V 1N~						400V 3N~		
Reference		3	4	5	7	9	12	7TRI	9TRI	12TRI
		024386						024389 (AE 6kW)	024295 (AE 9kW)	
Dimensions (mm)	h x l x p	1789 x 598 x 623								
Weight (kg)		130 / 340								

► Volume of the heating system

You must maintain the minimum installation water volume. If the required water volume is not available in the heating system a buffer tank must be installed on the return pipework of the heating circuit. For systems equipped with thermostatic valve(s), **water must be able to circulate continuously (at least one open loop per circuit).**

▼ AUREA 2 COMPACT

→ 40L for models 3/5.

→ 50L for models 7/12 (TRI).


▼ AUREA 2 & AUREA 2 DHW

<i>Model</i>	<i>Min. volume excluding Heat pump (in liters)</i>		
	<i>Fan-convector</i>	<i>Radiator</i>	<i>Heating-cooling floor</i>
3, 4, 5, 7, 7TRI	25L/circuit	1 heating loop opening	
9, 9TRI, 12, 12TRI	25L/circuit	2 heating loops opening or 20L	


► Drawing of the heat pump

▼ Dimensional drawing


■ UE AUREA 2




■ AUREA 2



■ AUREA 2 COMPACT



■ AUREA 2 DHW



► Installing the outdoor unit

▼ Installation precautions


The outdoor unit should always be installed outdoors. If a shelter is required, it should include wide openings on all 4 sides and comply with installation clearance requirements.

If the installation is in a region where temperatures can remain below 0 °C for an extended period, ensure that the presence of ice presents none of the dangers associated with freezing conditions. An evacuation pipe can also be connected to the outdoor unit

In regions with heavy snow, if the outdoor unit air inlet and outlet are blocked by snow, heating might be difficult and is likely to result in malfunction.

Do not tilt the Outdoor unit by more than 3 degrees.


■ Outdoor unit on the ground in open area



A : 250 mm
B : 200 mm

C : 300 mm
D : 600 mm

E : 600 mm



▼ Danger zone

In the event of a leak, R290 refrigerant can accumulate at ground level and pose a significant safety hazard. It is crucial to prevent the refrigerant from entering any building openings or the wastewater system.

It is imperative to prevent the accumulation of R290 refrigerant, as this poses a significant risk of creating a hazardous and explosive zone.

A danger area has been established around the product. This area must be free of any openings, vents, or access points.

The danger area must be absolutely free of any ignition sources.

No work shall be undertaken within the danger area unless all precautions related to the explosive and hazardous nature of R290 refrigerant are strictly adhered to.

▼ Neighborhood Zone

A 1m neighborhood zone has been defined around the danger zone.




Introducing an ignition source into the neighborhood zone is strongly discouraged.






Do not use material that could be a source of ignition near the appliance:

**Open flames, unprotected electrical systems,
Objects with a surface temperature above 370°C...**



■ Outdoor unit on the ground facing a wall



■ Outdoor unit on the ground in a corner




- A : 300 mm
- B : 500 mm
- C : 1 000 mm
- D : 1 500 mm
- E : 1 800 mm
- F : 2 000 mm
- G : 2 500 mm
- H : 3 000 mm
- V : 1 000 mm





► Installing the indoor unit



▼ AUREA 2 COMPACT




▼ AUREA 2



▼ AUREA 2 DHW



► Diameter connections



HP		3/7	9/12	
				radiator only
Ø	DN	DN25	DN32	DN25
L	m	<30	<30	<30
Ø	inche	1"	1"1/4	1"
Ø	mm	26x34	33x42	26x34
IT	mm	30	50	30

► ErP specifications

AUREA 2 COMPACT	3	4	5	7 / 7TRI	9 / 9TRI	12 / 12TRI
Energy class - heating (35° / 55°)	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++
Rated heat output (35° / 55°) (kW)	6 / 5	6 / 5	7 / 7	9 / 7	12 / 10	14 / 14
Seasonal space heating energy efficiency - heating (35° / 55°) (%)	200 / 143	200 / 143	185 / 148	193 / 148	186 / 140	192 / 142
Annual energy consumption - heating (35° / 55°) (kWh)	2524 / 2830	2524 / 2830	3257 / 3943	3797 / 3943	5241 / 6023	6022 / 8176
Sound power level (outdoor) (dBa)	54	54	55	55	56	59

AUREA 2	3	4	5	7 / 7TRI	9 / 9TRI	12 / 12TRI
Energy class - heating (35° / 55°)	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++
Rated heat output (35° / 55°) (kW)	6 / 5	6 / 5	7 / 7	9 / 7	12 / 11	14 / 14
Seasonal space heating energy efficiency - heating (35° / 55°) (%)	187 / 140	187 / 140	178 / 141	186 / 141	184 / 140	187 / 140
Annual energy consumption - heating (35° / 55°) (kWh)	2655 / 2769	2655 / 2769	3375 / 4008	3890 / 4008	5253 / 6114	6192 / 8130
Sound power level (indoor / outdoor) (dBa)	36 / 54	36 / 54	36 / 55	35 / 55	36 / 56	36 / 59

AUREA 2 DHW	3	4	5	7 / 7TRI	9 / 9TRI	12 / 12TRI
Energy class - heating (35° / 55°)	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++	A+++ / A++
Rated heat output (35° / 55°) (kW)	6 / 5	6 / 5	7 / 7	9 / 7	12 / 11	14 / 14
Seasonal space heating energy efficiency - heating (35° / 55°) (%)	187 / 140	187 / 140	178 / 141	186 / 141	184 / 140	187 / 140
Annual energy consumption - heating (35° / 55°) (kWh)	2655 / 2769	2655 / 2769	3375 / 4008	3890 / 4008	5253 / 6114	6192 / 8130
Sound power level (indoor / outdoor) (dBa)	36 / 54	36 / 54	36 / 55	36 / 55	36 / 56	36 / 59



A series of horizontal dotted lines spanning the width of the page, providing a guide for handwriting practice.

Performances

► Performances tables in heating mode without electrical back-up

▼ AUREA 2 COMPACT 3

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	0.65	5.60	8.60	0.80	5.60	7.02	0.91	5.48	6.06	1.05	5.46	5.19	1.22	5.46	4.49	1.38	5.46	3.96	1.55	5.46	3.54
	34°C	0.65	5.59	8.61	0.80	5.59	7.03	0.90	5.47	6.07	1.05	5.45	5.18	1.22	5.45	4.48	1.38	5.45	3.95	1.54	5.45	3.53
	33°C	0.65	5.58	8.63	0.79	5.58	7.05	0.90	5.46	6.08	1.05	5.44	5.18	1.21	5.44	4.48	1.38	5.44	3.95	1.54	5.44	3.53
	32°C	0.64	5.57	8.65	0.79	5.57	7.06	0.89	5.45	6.09	1.05	5.43	5.17	1.21	5.43	4.48	1.38	5.43	3.94	1.54	5.43	3.52
	31°C	0.64	5.56	8.67	0.79	5.56	7.08	0.89	5.44	6.11	1.05	5.42	5.17	1.21	5.42	4.47	1.38	5.42	3.94	1.54	5.42	3.52
	30°C	0.64	5.55	8.68	0.78	5.55	7.09	0.89	5.43	6.12	1.05	5.41	5.16	1.21	5.41	4.47	1.37	5.41	3.94	1.54	5.41	3.52
	29°C	0.64	5.54	8.70	0.78	5.54	7.10	0.88	5.42	6.13	1.05	5.40	5.16	1.21	5.40	4.46	1.37	5.40	3.93	1.54	5.40	3.51
	28°C	0.63	5.53	8.72	0.78	5.53	7.12	0.88	5.41	6.14	1.04	5.38	5.15	1.21	5.39	4.46	1.37	5.39	3.93	1.53	5.39	3.51
	27°C	0.63	5.52	8.73	0.77	5.52	7.13	0.88	5.40	6.15	1.04	5.37	5.15	1.21	5.37	4.45	1.37	5.38	3.92	1.53	5.38	3.51
	26°C	0.63	5.50	8.75	0.77	5.50	7.15	0.87	5.39	6.17	1.04	5.36	5.14	1.21	5.36	4.45	1.37	5.37	3.92	1.53	5.37	3.50
	25°C	0.63	5.49	8.77	0.77	5.49	7.16	0.87	5.38	6.18	1.04	5.35	5.14	1.20	5.35	4.44	1.37	5.35	3.92	1.53	5.36	3.50
	24°C	0.62	5.48	8.79	0.76	5.48	7.17	0.87	5.37	6.19	1.04	5.34	5.13	1.20	5.34	4.44	1.37	5.34	3.91	1.53	5.35	3.50
	23°C	0.62	5.47	8.80	0.76	5.47	7.19	0.86	5.35	6.20	1.04	5.33	5.13	1.20	5.33	4.44	1.36	5.33	3.91	1.53	5.33	3.49
	22°C	0.62	5.46	8.82	0.76	5.46	7.20	0.86	5.34	6.22	1.04	5.32	5.12	1.20	5.32	4.43	1.36	5.32	3.90	1.53	5.32	3.49
	21°C	0.62	5.45	8.84	0.76	5.45	7.22	0.86	5.33	6.23	1.04	5.31	5.12	1.20	5.31	4.43	1.36	5.31	3.90	1.52	5.31	3.49
	20°C	0.61	5.44	8.86	0.75	5.44	7.23	0.85	5.32	6.24	1.04	5.30	5.11	1.20	5.30	4.42	1.36	5.30	3.90	1.52	5.30	3.48
	19°C	0.61	5.43	8.88	0.75	5.43	7.25	0.85	5.31	6.25	1.04	5.29	5.11	1.20	5.29	4.42	1.36	5.29	3.89	1.52	5.29	3.48
	18°C	0.61	5.42	8.89	0.75	5.42	7.26	0.85	5.30	6.27	1.03	5.28	5.10	1.20	5.28	4.41	1.36	5.28	3.89	1.52	5.28	3.48
	17°C	0.61	5.41	8.91	0.74	5.41	7.28	0.84	5.29	6.28	1.03	5.27	5.10	1.20	5.27	4.41	1.36	5.27	3.88	1.52	5.27	3.47
	16°C	0.60	5.40	8.93	0.74	5.40	7.29	0.84	5.28	6.29	1.03	5.26	5.09	1.19	5.26	4.40	1.36	5.26	3.88	1.52	5.26	3.47
	15°C	0.60	5.38	8.95	0.74	5.38	7.30	0.84	5.27	6.30	1.03	5.25	5.09	1.19	5.25	4.40	1.35	5.25	3.88	1.52	5.25	3.47
	14°C	0.60	5.37	8.96	0.73	5.37	7.32	0.83	5.26	6.32	1.03	5.24	5.08	1.19	5.24	4.40	1.35	5.24	3.87	1.51	5.24	3.46
	13°C	0.60	5.36	8.98	0.73	5.36	7.33	0.83	5.25	6.33	1.03	5.23	5.08	1.19	5.23	4.39	1.35	5.23	3.87	1.51	5.23	3.46
	12°C	0.59	5.35	9.00	0.73	5.35	7.35	0.83	5.24	6.34	1.03	5.22	5.07	1.19	5.22	4.39	1.35	5.22	3.87	1.51	5.22	3.46
	11°C	0.65	5.30	8.20	0.76	5.30	6.96	0.85	5.22	6.17	1.03	5.19	5.05	1.19	5.19	4.37	1.35	5.19	3.85	1.51	5.20	3.44
	10°C	0.70	5.25	7.51	0.80	5.25	6.60	0.87	5.19	6.00	1.03	5.17	5.04	1.19	5.17	4.36	1.35	5.17	3.84	1.51	5.17	3.43
	9°C	0.75	5.20	6.92	0.83	5.20	6.28	0.88	5.17	5.84	1.03	5.15	5.02	1.19	5.15	4.34	1.35	5.15	3.83	1.51	5.15	3.42
	8°C	0.80	5.15	6.41	0.86	5.15	5.97	0.90	5.15	5.69	1.02	5.12	5.00	1.18	5.12	4.33	1.34	5.13	3.81	1.50	5.13	3.41
7°C	0.86	5.10	5.96	0.90	5.10	5.69	0.91	5.10	5.58	1.02	5.10	4.99	1.18	5.10	4.31	1.34	5.11	3.80	1.50	5.11	3.40	
6°C	0.92	5.00	5.46	0.96	4.98	5.17	1.01	4.96	4.91	1.12	4.94	4.43	1.25	4.92	3.93	1.39	4.90	3.52	1.53	4.88	3.19	
5°C	0.96	4.91	5.11	1.02	4.88	4.80	1.09	4.84	4.46	1.19	4.80	4.04	1.31	4.76	3.64	1.43	4.72	3.31	1.55	4.68	3.03	
4°C	0.99	4.84	4.87	1.05	4.79	4.55	1.14	4.74	4.16	1.24	4.68	3.78	1.35	4.63	3.44	1.45	4.58	3.15	1.56	4.52	2.90	
3°C	1.01	4.79	4.73	1.08	4.72	4.39	1.17	4.66	3.98	1.27	4.59	3.62	1.37	4.53	3.31	1.47	4.46	3.04	1.57	4.40	2.81	
2°C	1.02	4.72	4.63	1.08	4.64	4.28	1.18	4.56	3.86	1.28	4.48	3.50	1.38	4.40	3.20	1.47	4.32	2.93	1.57	4.24	2.70	
1°C	1.02	4.75	4.65	1.09	4.66	4.29	1.18	4.53	3.84	1.28	4.46	3.48	1.38	4.38	3.18	1.48	4.30	2.91	1.57	4.18	2.66	
0°C	1.03	4.77	4.66	1.09	4.68	4.28	1.18	4.51	3.81	1.28	4.43	3.45	1.38	4.36	3.15	1.49	4.28	2.88	1.58	4.12	2.62	
-1°C	1.03	4.80	4.65	1.10	4.69	4.26	1.19	4.48	3.78	1.29	4.41	3.42	1.39	4.33	3.11	1.50	4.26	2.83	1.58	4.06	2.57	
-2°C	1.04	4.83	4.64	1.12	4.71	4.21	1.19	4.46	3.75	1.30	4.38	3.38	1.40	4.31	3.07	1.52	4.23	2.78	1.59	4.00	2.52	
-3°C	1.05	4.85	4.61	1.14	4.73	4.16	1.19	4.43	3.72	1.31	4.36	3.34	1.42	4.29	3.02	1.55	4.21	2.71	1.60	3.94	2.46	
-4°C	1.07	4.88	4.57	1.16	4.75	4.09	1.20	4.41	3.68	1.32	4.34	3.29	1.44	4.27	2.96	1.59	4.19	2.64	1.61	3.88	2.41	
-5°C	1.09	4.91	4.52	1.19	4.77	4.01	1.20	4.38	3.64	1.33	4.31	3.24	1.46	4.24	2.90	1.63	4.17	2.56	1.63	3.82	2.35	
-6°C	1.10	4.94	4.47	1.22	4.78	3.92	1.21	4.36	3.60	1.35	4.29	3.18	1.49	4.22	2.84	1.68	4.15	2.47	1.65	3.76	2.28	
-7°C	1.13	4.96	4.40	1.26	4.80	3.82	1.22	4.33	3.56	1.37	4.27	3.12	1.52	4.20	2.76	1.74	4.13	2.38	1.67	3.70	2.22	
-8°C	1.12	4.88	4.37	1.25	4.70	3.77	1.26	4.30	3.41	1.41	4.25	3.02	1.55	4.19	2.70	1.74	4.13	2.38	1.74	3.83	2.21	
-9°C	1.11	4.79	4.34	1.23	4.59	3.72	1.31	4.28	3.27	1.44	4.23	2.93	1.58	4.18	2.65	1.74	4.13	2.38	1.80	3.97	2.20	
-10°C	1.09	4.71	4.30	1.22	4.48	3.66	1.35	4.25	3.14	1.48	4.21	2.84	1.61	4.18	2.59	1.74	4.14	2.37	1.87	4.10	2.19	
-11°C	1.11	4.52	4.06	1.24	4.32	3.49	1.36	4.12	3.03	1.48	4.08	2.76	1.60	4.03	2.52	1.72	3.98	2.31	1.84	3.87	2.11	
-12°C	1.13	4.33	3.82	1.25	4.16	3.33	1.37	3.99	2.92	1.48	3.94	2.67	1.58	3.89	2.45	1.69	3.81	2.25	1.80	3.65	2.02	
-13°C	1.15	4.14	3.59	1.26	4.00	3.17	1.37	3.87	2.81	1.47	3.81	2.58	1.57	3.75	2.38	1.67	3.65	2.19	1.77	3.42	1.94	
-14°C	1.17	3.95	3.37	1.28	3.84	3.01	1.38	3.74	2.71	1.47	3.67	2.50	1.56	3.60	2.31	1.64	3.49	2.12	1.73	3.19	1.84	
-15°C	1.19	3.76	3.16	1.29	3.69	2.86	1.39	3.61	2.60	1.49	3.54	2.38	1.59	3.46	2.18	1.67	3.33	1.99	1.70	2.97	1.75	
-16°C	1.16	3.64	3.12	1.26	3.57	2.82	1.36	3.50	2.56	1.45	3.42	2.37	1.53	3.35	2.20	1.61	3.23	2.01	1.69	2.92	1.73	
-17°C	1.14	3.51	3.08	1.24	3.45	2.78	1.34	3.38														

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,62	5,47	3,37	1,88	5,47	2,90	2,18	5,47	2,51	0,00	0,00	0,00	35°C
1,62	5,45	3,36	1,88	5,46	2,90	2,18	5,46	2,50	0,00	0,00	0,00	34°C
1,62	5,44	3,36	1,88	5,45	2,90	2,18	5,45	2,50	0,00	0,00	0,00	33°C
1,62	5,43	3,36	1,88	5,43	2,90	2,18	5,44	2,50	0,00	0,00	0,00	32°C
1,62	5,42	3,35	1,88	5,42	2,89	2,17	5,43	2,50	0,00	0,00	0,00	31°C
1,62	5,41	3,35	1,87	5,41	2,89	2,17	5,42	2,49	0,00	0,00	0,00	30°C
1,61	5,40	3,35	1,87	5,40	2,89	2,17	5,40	2,49	0,00	0,00	0,00	29°C
1,61	5,39	3,34	1,87	5,39	2,88	2,17	5,39	2,49	0,00	0,00	0,00	28°C
1,61	5,38	3,34	1,87	5,38	2,88	2,17	5,38	2,49	0,00	0,00	0,00	27°C
1,61	5,37	3,34	1,87	5,37	2,88	2,16	5,37	2,48	0,00	0,00	0,00	26°C
1,61	5,36	3,33	1,86	5,36	2,88	2,16	5,36	2,48	0,00	0,00	0,00	25°C
1,61	5,35	3,33	1,86	5,35	2,87	2,16	5,35	2,48	0,00	0,00	0,00	24°C
1,60	5,34	3,33	1,86	5,34	2,87	2,16	5,34	2,48	0,00	0,00	0,00	23°C
1,60	5,33	3,32	1,86	5,33	2,87	2,15	5,33	2,47	0,00	0,00	0,00	22°C
1,60	5,32	3,32	1,86	5,32	2,86	2,15	5,32	2,47	0,00	0,00	0,00	21°C
1,60	5,30	3,32	1,85	5,31	2,86	2,15	5,31	2,47	0,00	0,00	0,00	20°C
1,60	5,29	3,31	1,85	5,30	2,86	2,15	5,30	2,47	2,49	5,30	2,13	19°C
1,60	5,28	3,31	1,85	5,29	2,86	2,15	5,29	2,46	2,49	5,29	2,13	18°C
1,60	5,27	3,31	1,85	5,27	2,85	2,14	5,28	2,46	2,49	5,28	2,12	17°C
1,59	5,26	3,30	1,85	5,26	2,85	2,14	5,27	2,46	2,48	5,27	2,12	16°C
1,59	5,25	3,30	1,85	5,25	2,85	2,14	5,26	2,46	2,48	5,26	2,12	15°C
1,59	5,24	3,30	1,84	5,24	2,84	2,14	5,25	2,45	2,48	5,25	2,12	14°C
1,59	5,23	3,29	1,84	5,23	2,84	2,14	5,23	2,45	2,48	5,24	2,12	13°C
1,59	5,22	3,29	1,84	5,22	2,84	2,13	5,22	2,45	2,47	5,23	2,11	12°C
1,59	5,20	3,28	1,84	5,20	2,83	2,13	5,20	2,44	2,47	5,20	2,11	11°C
1,58	5,17	3,27	1,84	5,18	2,82	2,13	5,18	2,43	2,47	5,18	2,10	10°C
1,58	5,15	3,26	1,83	5,15	2,81	2,13	5,16	2,42	2,47	5,16	2,09	9°C
1,58	5,13	3,24	1,83	5,13	2,80	2,12	5,13	2,42	2,46	5,13	2,08	8°C
1,58	5,11	3,24	1,83	5,12	2,79	2,12	5,12	2,41	2,46	5,12	2,08	7°C
1,61	4,86	3,02	1,81	4,84	2,68	2,03	4,82	2,38	2,28	4,80	2,11	6°C
1,64	4,65	2,84	1,79	4,61	2,58	1,96	4,57	2,34	2,14	4,53	2,12	5°C
1,65	4,47	2,70	1,78	4,42	2,49	1,90	4,36	2,29	2,04	4,31	2,11	4°C
1,66	4,33	2,61	1,77	4,27	2,42	1,87	4,21	2,25	1,98	4,14	2,09	3°C
1,67	4,16	2,49	1,76	4,08	2,31	1,86	4,00	2,15	1,96	3,92	2,00	2°C
1,66	4,08	2,45	1,76	3,98	2,27	1,85	3,88	2,10	1,94	3,80	1,95	1°C
1,65	4,00	2,42	1,73	3,89	2,24	1,81	3,77	2,08	1,89	3,67	1,94	0°C
1,64	3,92	2,40	1,69	3,79	2,24	1,75	3,65	2,09	1,81	3,55	1,96	-1°C
1,61	3,85	2,38	1,64	3,69	2,25	1,66	3,54	2,13	1,69	3,43	2,03	-2°C
1,58	3,77	2,38	1,57	3,59	2,30	1,55	3,42	2,21	1,54	3,31	2,15	-3°C
1,55	3,69	2,39	1,48	3,50	2,37	1,41	3,31	2,34	1,36	3,18	2,35	-4°C
1,50	3,61	2,40	1,37	3,40	2,47	1,25	3,19	2,56	1,14	3,06	2,69	-5°C
1,45	3,53	2,43	1,25	3,30	2,63	1,06	3,08	2,90	0,88	2,94	3,32	-6°C
1,39	3,45	2,48	1,12	3,21	2,87	0,85	2,96	3,50	0,60	2,81	4,70	-7°C
1,56	3,49	2,24	1,38	3,15	2,28	1,20	2,81	2,33	1,08	2,71	2,51	-8°C
1,72	3,53	2,05	1,64	3,10	1,88	1,56	2,66	1,70	1,55	2,60	1,67	-9°C
1,89	3,57	1,89	1,91	3,04	1,60	1,92	2,51	1,31	2,03	2,49	1,22	-10°C
1,86	3,38	1,82	1,87	2,88	1,54	1,89	2,39	1,26	0,00	0,00	0,00	-11°C
1,82	3,18	1,75	1,84	2,72	1,48	1,86	2,26	1,21	0,00	0,00	0,00	-12°C
1,79	2,99	1,67	1,81	2,56	1,42	1,83	2,13	1,17	0,00	0,00	0,00	-13°C
1,75	2,80	1,59	1,78	2,40	1,35	1,80	2,01	1,11	0,00	0,00	0,00	-14°C
1,72	2,60	1,51	1,75	2,24	1,28	1,77	1,88	1,06	0,00	0,00	0,00	-15°C
1,71	2,56	1,49	1,73	2,19	1,26	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
1,70	2,51	1,47	1,72	2,14	1,24	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
1,69	2,46	1,46	1,71	2,09	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
1,68	2,41	1,44	1,69	2,04	1,20	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
1,67	2,36	1,42	1,68	1,98	1,18	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
1,65	2,31	1,39	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
1,64	2,26	1,37	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
1,63	2,21	1,35	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
1,62	2,16	1,33	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
1,61	2,11	1,31	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 COMPACT 4

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	0,79	6,57	8,28	0,98	6,57	6,71	1,11	6,43	5,79	1,30	6,39	4,93	1,49	6,39	4,28	1,69	6,39	3,78	1,89	6,39	3,39
34°C	0,79	6,56	8,30	0,98	6,56	6,72	1,11	6,41	5,80	1,30	6,38	4,92	1,49	6,38	4,27	1,69	6,37	3,78	1,88	6,37	3,38
33°C	0,79	6,55	8,31	0,97	6,55	6,73	1,10	6,40	5,81	1,29	6,37	4,92	1,49	6,36	4,27	1,69	6,36	3,77	1,88	6,36	3,38
32°C	0,78	6,54	8,33	0,97	6,54	6,75	1,10	6,39	5,82	1,29	6,35	4,91	1,49	6,35	4,26	1,69	6,35	3,77	1,88	6,35	3,38
31°C	0,78	6,52	8,35	0,96	6,52	6,76	1,09	6,38	5,83	1,29	6,34	4,91	1,49	6,34	4,26	1,68	6,34	3,76	1,88	6,34	3,37
30°C	0,78	6,51	8,36	0,96	6,51	6,78	1,09	6,36	5,85	1,29	6,33	4,90	1,49	6,33	4,26	1,68	6,32	3,76	1,88	6,32	3,37
29°C	0,78	6,50	8,38	0,96	6,50	6,79	1,08	6,35	5,86	1,29	6,32	4,90	1,48	6,31	4,25	1,68	6,31	3,76	1,88	6,31	3,37
28°C	0,77	6,48	8,40	0,95	6,48	6,80	1,08	6,34	5,87	1,29	6,30	4,89	1,48	6,30	4,25	1,68	6,30	3,75	1,87	6,30	3,36
27°C	0,77	6,47	8,41	0,95	6,47	6,82	1,08	6,33	5,88	1,29	6,29	4,89	1,48	6,29	4,24	1,68	6,29	3,75	1,87	6,28	3,36
26°C	0,77	6,46	8,43	0,95	6,46	6,83	1,07	6,31	5,89	1,29	6,28	4,88	1,48	6,27	4,24	1,67	6,27	3,75	1,87	6,27	3,35
25°C	0,76	6,44	8,45	0,94	6,44	6,84	1,07	6,30	5,90	1,28	6,27	4,88	1,48	6,26	4,23	1,67	6,26	3,74	1,87	6,26	3,35
24°C	0,76	6,43	8,46	0,94	6,43	6,86	1,06	6,29	5,92	1,28	6,25	4,87	1,48	6,25	4,23	1,67	6,25	3,74	1,87	6,25	3,35
23°C	0,76	6,42	8,48	0,93	6,42	6,87	1,06	6,27	5,93	1,28	6,24	4,87	1,48	6,24	4,23	1,67	6,24	3,73	1,86	6,23	3,34
22°C	0,75	6,41	8,50	0,93	6,41	6,88	1,05	6,26	5,94	1,28	6,23	4,86	1,47	6,22	4,22	1,67	6,22	3,73	1,86	6,22	3,34
21°C	0,75	6,39	8,51	0,93	6,39	6,90	1,05	6,25	5,95	1,28	6,22	4,86	1,47	6,21	4,22	1,67	6,21	3,73	1,86	6,21	3,34
20°C	0,75	6,38	8,53	0,92	6,38	6,91	1,05	6,24	5,96	1,28	6,20	4,85	1,47	6,20	4,21	1,66	6,20	3,72	1,86	6,20	3,33
19°C	0,74	6,37	8,55	0,92	6,37	6,93	1,04	6,22	5,98	1,28	6,19	4,85	1,47	6,19	4,21	1,66	6,19	3,72	1,86	6,18	3,33
18°C	0,74	6,36	8,56	0,92	6,36	6,94	1,04	6,21	5,99	1,28	6,18	4,84	1,47	6,18	4,20	1,66	6,17	3,72	1,85	6,17	3,33
17°C	0,74	6,34	8,58	0,91	6,34	6,95	1,03	6,20	6,00	1,27	6,17	4,84	1,47	6,16	4,20	1,66	6,16	3,71	1,85	6,16	3,32
16°C	0,74	6,33	8,60	0,91	6,33	6,97	1,03	6,19	6,01	1,27	6,15	4,83	1,47	6,15	4,20	1,66	6,15	3,71	1,85	6,15	3,32
15°C	0,73	6,32	8,62	0,90	6,32	6,98	1,03	6,18	6,02	1,27	6,14	4,83	1,46	6,14	4,19	1,66	6,14	3,70	1,85	6,14	3,32
14°C	0,73	6,30	8,63	0,90	6,30	6,99	1,02	6,16	6,04	1,27	6,13	4,82	1,46	6,13	4,19	1,65	6,12	3,70	1,85	6,12	3,31
13°C	0,73	6,29	8,65	0,90	6,29	7,01	1,02	6,15	6,05	1,27	6,12	4,82	1,46	6,11	4,18	1,65	6,11	3,70	1,85	6,11	3,31
12°C	0,72	6,28	8,67	0,89	6,28	7,02	1,01	6,14	6,06	1,27	6,11	4,82	1,46	6,10	4,18	1,65	6,10	3,69	1,84	6,10	3,31
11°C	0,78	6,22	7,99	0,93	6,22	6,70	1,04	6,11	5,89	1,27	6,08	4,80	1,46	6,07	4,16	1,65	6,07	3,68	1,84	6,07	3,30
10°C	0,83	6,16	7,41	0,96	6,16	6,39	1,06	6,08	5,73	1,27	6,05	4,78	1,46	6,04	4,15	1,65	6,04	3,67	1,84	6,04	3,28
9°C	0,89	6,10	6,89	1,00	6,10	6,11	1,08	6,05	5,58	1,26	6,02	4,76	1,46	6,02	4,13	1,65	6,01	3,65	1,84	6,01	3,27
8°C	0,94	6,04	6,43	1,03	6,04	5,85	1,11	6,03	5,44	1,26	5,99	4,75	1,45	5,99	4,12	1,65	5,99	3,64	1,84	5,99	3,26
7°C	0,99	5,98	6,03	1,07	5,98	5,60	1,12	5,97	5,33	1,26	5,97	4,73	1,45	5,97	4,11	1,64	5,98	3,64	1,83	5,98	3,26
6°C	1,09	5,96	5,46	1,17	5,93	5,07	1,25	5,90	4,73	1,38	5,87	4,25	1,55	5,85	3,78	1,71	5,82	3,40	1,88	5,80	3,08
5°C	1,17	5,94	5,08	1,25	5,89	4,71	1,35	5,84	4,33	1,48	5,79	3,92	1,62	5,74	3,54	1,77	5,69	3,22	1,92	5,65	2,95
4°C	1,22	5,93	4,84	1,31	5,86	4,48	1,42	5,79	4,08	1,54	5,72	3,70	1,68	5,65	3,37	1,81	5,59	3,09	1,94	5,52	2,84
3°C	1,26	5,92	4,71	1,34	5,83	4,34	1,46	5,75	3,93	1,58	5,67	3,58	1,71	5,59	3,27	1,83	5,51	3,00	1,96	5,42	2,77
2°C	1,27	5,90	4,65	1,36	5,80	4,28	1,48	5,70	3,86	1,60	5,60	3,50	1,72	5,50	3,20	1,84	5,40	2,93	1,96	5,30	2,70
1°C	1,27	5,93	4,66	1,36	5,80	4,27	1,48	5,67	3,83	1,60	5,57	3,48	1,72	5,47	3,18	1,84	5,30	2,88	1,96	5,21	2,65
0°C	1,28	5,96	4,65	1,37	5,80	4,25	1,48	5,64	3,80	1,60	5,54	3,46	1,72	5,45	3,17	1,84	5,20	2,83	1,97	5,12	2,60
-1°C	1,30	5,98	4,62	1,38	5,80	4,21	1,49	5,61	3,76	1,60	5,51	3,44	1,72	5,42	3,16	1,83	5,10	2,79	1,98	5,02	2,54
-2°C	1,32	6,01	4,56	1,40	5,80	4,15	1,51	5,58	3,70	1,61	5,48	3,41	1,71	5,39	3,15	1,82	5,00	2,75	1,99	4,93	2,47
-3°C	1,35	6,04	4,49	1,42	5,79	4,08	1,52	5,54	3,64	1,62	5,45	3,38	1,71	5,37	3,14	1,81	4,90	2,71	2,01	4,84	2,41
-4°C	1,38	6,07	4,40	1,45	5,79	4,00	1,54	5,51	3,58	1,62	5,43	3,34	1,71	5,34	3,13	1,80	4,80	2,67	2,03	4,75	2,34
-5°C	1,42	6,09	4,29	1,48	5,79	3,91	1,57	5,48	3,50	1,63	5,40	3,30	1,70	5,31	3,12	1,78	4,70	2,64	2,06	4,65	2,26
-6°C	1,47	6,12	4,17	1,52	5,79	3,81	1,59	5,45	3,42	1,64	5,37	3,26	1,70	5,28	3,12	1,76	4,60	2,62	2,09	4,56	2,19
-7°C	1,52	6,15	4,05	1,56	5,79	3,70	1,62	5,42	3,34	1,66	5,34	3,22	1,69	5,26	3,11	1,74	4,50	2,59	2,12	4,47	2,11
-8°C	1,51	6,03	3,98	1,56	5,66	3,63	1,61	5,28	3,27	1,65	5,12	3,10	1,69	4,95	2,94	1,73	4,34	2,50	2,00	4,21	2,10
-9°C	1,51	5,91	3,92	1,55	5,53	3,56	1,60	5,14	3,21	1,64	4,90	2,98	1,68	4,65	2,76	1,73	4,18	2,42	1,89	3,96	2,10
-10°C	1,50	5,80	3,85	1,55	5,40	3,49	1,59	5,00	3,14	1,64	4,68	2,86	1,68	4,35	2,59	1,73	4,03	2,33	1,77	3,70	2,09
-11°C	1,48	5,52	3,72	1,54	5,19	3,36	1,60	4,85	3,03	1,65	4,57	2,76	1,71	4,29	2,51	1,76	4,00	2,27	1,82	3,66	2,01
-12°C	1,46	5,25	3,59	1,54	4,97	3,24	1,61	4,70	2,92	1,67	4,47	2,67	1,73	4,24	2,44	1,80	3,98	2,21	1,86	3,62	1,94
-13°C	1,44	4,97	3,45	1,53	4,76	3,11	1,62	4,55	2,81	1,69	4,37	2,58	1,76	4,18	2,37	1,83	3,96	2,16	1,91	3,57	1,88
-14°C	1,42	4,70	3,31	1,52	4,55	2,99	1,63	4,40	2,71	1,71	4,26	2,50	1,79	4,13	2,31	1,87	3,94	2,11	1,95	3,53	1,81
-15°C	1,40	4,42	3,16	1,52	4,34	2,86	1,63	4,25	2,60	1,75	4,16	2,38	1,87	4,07	2,18	1,97	3,91	1,99	2,00	3,49	1,75
-16°C	1,37	4,28	3,12	1,49	4,19	2,82	1,61	4,11	2,56	1,70	4,03	2,37	1,80	3,95	2,20	1,89	3,81	2,01	1,99	3,43	1,73

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,98	6,39	3,22	2,30	6,39	2,78	2,66	6,39	2,40	0,00	0,00	0,00	35°C
1,98	6,37	3,22	2,30	6,37	2,78	2,66	6,38	2,40	0,00	0,00	0,00	34°C
1,98	6,36	3,22	2,29	6,36	2,77	2,66	6,36	2,39	0,00	0,00	0,00	33°C
1,98	6,35	3,21	2,29	6,35	2,77	2,66	6,35	2,39	0,00	0,00	0,00	32°C
1,97	6,34	3,21	2,29	6,34	2,77	2,65	6,34	2,39	0,00	0,00	0,00	31°C
1,97	6,32	3,21	2,29	6,32	2,77	2,65	6,32	2,39	0,00	0,00	0,00	30°C
1,97	6,31	3,20	2,28	6,31	2,76	2,65	6,31	2,38	0,00	0,00	0,00	29°C
1,97	6,30	3,20	2,28	6,30	2,76	2,65	6,30	2,38	0,00	0,00	0,00	28°C
1,97	6,28	3,20	2,28	6,29	2,76	2,64	6,29	2,38	0,00	0,00	0,00	27°C
1,96	6,27	3,19	2,28	6,27	2,75	2,64	6,27	2,38	0,00	0,00	0,00	26°C
1,96	6,26	3,19	2,28	6,26	2,75	2,64	6,26	2,37	0,00	0,00	0,00	25°C
1,96	6,25	3,19	2,27	6,25	2,75	2,63	6,25	2,37	0,00	0,00	0,00	24°C
1,96	6,23	3,18	2,27	6,24	2,75	2,63	6,24	2,37	0,00	0,00	0,00	23°C
1,96	6,22	3,18	2,27	6,22	2,74	2,63	6,22	2,37	0,00	0,00	0,00	22°C
1,95	6,21	3,18	2,27	6,21	2,74	2,63	6,21	2,36	0,00	0,00	0,00	21°C
1,95	6,20	3,17	2,26	6,20	2,74	2,62	6,20	2,36	0,00	0,00	0,00	20°C
1,95	6,19	3,17	2,26	6,19	2,74	2,62	6,19	2,36	3,04	6,19	2,04	19°C
1,95	6,17	3,17	2,26	6,17	2,73	2,62	6,17	2,36	3,04	6,18	2,03	18°C
1,95	6,16	3,16	2,26	6,16	2,73	2,62	6,16	2,36	3,03	6,16	2,03	17°C
1,94	6,15	3,16	2,25	6,15	2,73	2,61	6,15	2,35	3,03	6,15	2,03	16°C
1,94	6,14	3,16	2,25	6,14	2,72	2,61	6,14	2,35	3,03	6,14	2,03	15°C
1,94	6,12	3,15	2,25	6,12	2,72	2,61	6,13	2,35	3,02	6,13	2,03	14°C
1,94	6,11	3,15	2,25	6,11	2,72	2,61	6,11	2,35	3,02	6,11	2,02	13°C
1,94	6,10	3,15	2,25	6,10	2,72	2,60	6,10	2,34	3,02	6,10	2,02	12°C
1,94	6,07	3,14	2,24	6,07	2,71	2,60	6,07	2,33	3,01	6,07	2,01	11°C
1,93	6,04	3,13	2,24	6,04	2,70	2,60	6,04	2,33	3,01	6,05	2,01	10°C
1,93	6,01	3,11	2,24	6,01	2,69	2,60	6,02	2,32	3,01	6,02	2,00	9°C
1,93	5,99	3,10	2,24	5,99	2,68	2,59	5,99	2,31	3,01	6,00	1,99	8°C
1,93	5,98	3,10	2,23	5,99	2,68	2,59	5,99	2,31	3,00	6,00	2,00	7°C
1,98	5,78	2,91	2,22	5,75	2,59	2,50	5,73	2,30	2,80	5,71	2,03	6°C
2,03	5,60	2,76	2,22	5,55	2,51	2,42	5,51	2,27	2,65	5,46	2,06	5°C
2,06	5,46	2,65	2,21	5,39	2,44	2,37	5,32	2,25	2,54	5,26	2,07	4°C
2,08	5,34	2,57	2,21	5,26	2,38	2,34	5,18	2,22	2,47	5,10	2,06	3°C
2,08	5,20	2,49	2,21	5,10	2,31	2,33	5,00	2,15	2,45	4,90	2,00	2°C
2,09	5,11	2,45	2,22	5,02	2,26	2,34	4,93	2,10	2,47	4,88	1,97	1°C
2,11	5,03	2,38	2,25	4,94	2,19	2,40	4,86	2,03	2,54	4,86	1,91	0°C
2,15	4,94	2,30	2,32	4,87	2,10	2,48	4,79	1,93	2,65	4,83	1,82	-1°C
2,20	4,86	2,21	2,40	4,79	1,99	2,60	4,72	1,81	2,81	4,81	1,71	-2°C
2,26	4,77	2,11	2,51	4,71	1,88	2,76	4,65	1,68	3,02	4,79	1,59	-3°C
2,34	4,69	2,01	2,64	4,63	1,75	2,95	4,58	1,55	3,27	4,77	1,46	-4°C
2,43	4,60	1,90	2,80	4,56	1,63	3,17	4,51	1,42	3,57	4,75	1,33	-5°C
2,54	4,52	1,78	2,98	4,48	1,50	3,43	4,44	1,29	3,91	4,72	1,21	-6°C
2,66	4,44	1,67	3,19	4,40	1,38	3,73	4,37	1,17	4,30	4,70	1,09	-7°C
2,34	3,97	1,69	2,68	3,73	1,39	3,02	3,48	1,15	3,42	3,64	1,06	-8°C
2,03	3,50	1,73	2,18	3,05	1,40	2,32	2,60	1,12	2,54	2,58	1,02	-9°C
1,72	3,04	1,77	1,67	2,38	1,42	1,62	1,72	1,06	1,66	1,51	0,91	-10°C
1,78	3,04	1,71	1,75	2,43	1,39	1,71	1,82	1,06	0,00	0,00	0,00	-11°C
1,84	3,05	1,66	1,82	2,48	1,36	1,80	1,92	1,06	0,00	0,00	0,00	-12°C
1,90	3,05	1,61	1,90	2,53	1,33	1,90	2,02	1,06	0,00	0,00	0,00	-13°C
1,96	3,06	1,56	1,98	2,59	1,31	1,99	2,11	1,06	0,00	0,00	0,00	-14°C
2,03	3,06	1,51	2,05	2,64	1,28	2,08	2,21	1,06	0,00	0,00	0,00	-15°C
2,01	3,01	1,49	2,04	2,58	1,26	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,00	2,95	1,47	2,02	2,52	1,24	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
1,99	2,89	1,46	2,01	2,46	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
1,97	2,83	1,44	1,99	2,40	1,20	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
1,96	2,77	1,42	1,97	2,34	1,18	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
1,95	2,71	1,39	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
1,93	2,66	1,37	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
1,92	2,60	1,35	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
1,91	2,54	1,33	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
1,89	2,48	1,31	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 COMPACT 5

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1,26	8,92	7,08	1,45	8,83	6,09	1,59	8,59	5,39	1,79	8,48	4,75	1,98	8,40	4,24	2,17	8,31	3,83	2,37	8,23	3,48
34°C	1,26	8,90	7,09	1,44	8,81	6,10	1,59	8,58	5,40	1,78	8,46	4,74	1,98	8,38	4,24	2,17	8,30	3,82	2,37	8,21	3,47
33°C	1,25	8,89	7,11	1,44	8,80	6,12	1,58	8,56	5,41	1,78	8,45	4,74	1,98	8,36	4,23	2,17	8,28	3,82	2,36	8,20	3,47
32°C	1,25	8,87	7,12	1,43	8,78	6,13	1,57	8,54	5,43	1,78	8,43	4,73	1,97	8,35	4,23	2,17	8,26	3,81	2,36	8,18	3,47
31°C	1,24	8,85	7,14	1,43	8,76	6,14	1,57	8,52	5,44	1,78	8,41	4,73	1,97	8,33	4,22	2,17	8,25	3,81	2,36	8,16	3,46
30°C	1,24	8,83	7,15	1,42	8,74	6,15	1,56	8,51	5,45	1,78	8,39	4,72	1,97	8,31	4,22	2,16	8,23	3,80	2,36	8,15	3,46
29°C	1,23	8,82	7,16	1,42	8,73	6,16	1,56	8,49	5,46	1,78	8,38	4,72	1,97	8,30	4,21	2,16	8,21	3,80	2,35	8,13	3,45
28°C	1,23	8,80	7,18	1,41	8,71	6,18	1,55	8,47	5,47	1,77	8,36	4,71	1,97	8,28	4,21	2,16	8,20	3,80	2,35	8,11	3,45
27°C	1,22	8,78	7,19	1,40	8,69	6,19	1,54	8,46	5,48	1,77	8,34	4,71	1,96	8,26	4,21	2,16	8,18	3,79	2,35	8,10	3,45
26°C	1,22	8,76	7,21	1,40	8,67	6,20	1,54	8,44	5,49	1,77	8,33	4,70	1,96	8,24	4,20	2,15	8,16	3,79	2,35	8,08	3,44
25°C	1,21	8,75	7,22	1,39	8,66	6,21	1,53	8,42	5,50	1,77	8,31	4,70	1,96	8,23	4,20	2,15	8,15	3,78	2,34	8,06	3,44
24°C	1,21	8,73	7,24	1,39	8,64	6,23	1,52	8,41	5,51	1,77	8,29	4,69	1,96	8,21	4,19	2,15	8,13	3,78	2,34	8,05	3,44
23°C	1,20	8,71	7,25	1,38	8,62	6,24	1,52	8,39	5,52	1,76	8,28	4,69	1,96	8,19	4,19	2,15	8,11	3,78	2,34	8,03	3,43
22°C	1,20	8,69	7,26	1,38	8,60	6,25	1,51	8,37	5,53	1,76	8,26	4,69	1,95	8,18	4,18	2,15	8,10	3,77	2,34	8,01	3,43
21°C	1,19	8,68	7,28	1,37	8,59	6,26	1,51	8,36	5,55	1,76	8,24	4,68	1,95	8,16	4,18	2,14	8,08	3,77	2,33	8,00	3,43
20°C	1,19	8,66	7,29	1,37	8,57	6,28	1,50	8,34	5,56	1,76	8,23	4,68	1,95	8,14	4,18	2,14	8,06	3,77	2,33	7,98	3,42
19°C	1,18	8,64	7,31	1,36	8,55	6,29	1,49	8,32	5,57	1,76	8,21	4,67	1,95	8,13	4,17	2,14	8,05	3,76	2,33	7,96	3,42
18°C	1,18	8,62	7,32	1,35	8,54	6,30	1,49	8,31	5,58	1,76	8,19	4,67	1,95	8,11	4,17	2,14	8,03	3,76	2,33	7,95	3,41
17°C	1,17	8,61	7,34	1,35	8,52	6,31	1,48	8,29	5,59	1,75	8,18	4,66	1,94	8,10	4,16	2,13	8,01	3,75	2,33	7,93	3,41
16°C	1,17	8,59	7,35	1,34	8,50	6,33	1,48	8,27	5,60	1,75	8,16	4,66	1,94	8,08	4,16	2,13	8,00	3,75	2,32	7,91	3,41
15°C	1,16	8,57	7,37	1,34	8,49	6,34	1,47	8,26	5,61	1,75	8,15	4,65	1,94	8,06	4,15	2,13	7,98	3,75	2,32	7,90	3,40
14°C	1,16	8,56	7,38	1,33	8,47	6,35	1,47	8,24	5,62	1,75	8,13	4,65	1,94	8,05	4,15	2,13	7,96	3,74	2,32	7,88	3,40
13°C	1,15	8,54	7,40	1,33	8,45	6,36	1,46	8,22	5,64	1,75	8,11	4,64	1,94	8,03	4,15	2,13	7,95	3,74	2,32	7,86	3,40
12°C	1,15	8,52	7,41	1,32	8,43	6,38	1,45	8,21	5,65	1,75	8,10	4,64	1,93	8,01	4,14	2,12	7,93	3,73	2,31	7,85	3,39
11°C	1,19	8,44	7,12	1,35	8,35	6,19	1,48	8,16	5,52	1,74	8,05	4,62	1,93	7,97	4,12	2,12	7,89	3,72	2,31	7,80	3,38
10°C	1,22	8,36	6,84	1,38	8,27	6,01	1,51	8,12	5,39	1,74	8,01	4,60	1,93	7,92	4,10	2,12	7,84	3,70	2,31	7,76	3,36
9°C	1,26	8,28	6,58	1,40	8,19	5,84	1,53	8,07	5,27	1,74	7,96	4,57	1,93	7,88	4,08	2,12	7,79	3,68	2,31	7,71	3,34
8°C	1,29	8,20	6,33	1,43	8,11	5,67	1,56	8,03	5,15	1,74	7,91	4,55	1,93	7,83	4,06	2,12	7,75	3,66	2,30	7,67	3,33
7°C	1,33	8,12	6,10	1,46	8,03	5,51	1,57	7,95	5,05	1,74	7,87	4,53	1,93	7,79	4,04	2,11	7,70	3,64	2,30	7,62	3,31
6°C	1,48	7,70	5,20	1,60	7,65	4,77	1,73	7,59	4,38	1,89	7,54	3,99	2,07	7,48	3,62	2,24	7,43	3,32	2,42	7,38	3,05
5°C	1,60	7,35	4,60	1,72	7,32	4,27	1,85	7,29	3,93	2,01	7,26	3,61	2,17	7,23	3,32	2,34	7,20	3,08	2,50	7,17	2,86
4°C	1,68	7,06	4,20	1,80	7,05	3,92	1,94	7,04	3,63	2,10	7,03	3,36	2,25	7,02	3,12	2,41	7,01	2,91	2,57	7,00	2,73
3°C	1,73	6,84	3,95	1,84	6,84	3,71	1,99	6,85	3,43	2,15	6,85	3,19	2,30	6,86	2,98	2,45	6,86	2,80	2,60	6,87	2,64
2°C	1,75	6,55	3,75	1,86	6,57	3,53	2,01	6,60	3,28	2,16	6,62	3,06	2,31	6,65	2,87	2,47	6,68	2,71	2,62	6,70	2,56
1°C	1,75	6,57	3,75	1,87	6,58	3,53	2,02	6,59	3,27	2,17	6,60	3,05	2,32	6,61	2,85	2,47	6,64	2,69	2,61	6,57	2,51
0°C	1,77	6,58	3,72	1,88	6,59	3,50	2,03	6,58	3,24	2,18	6,58	3,02	2,33	6,58	2,82	2,48	6,61	2,66	2,61	6,43	2,47
-1°C	1,80	6,60	3,67	1,91	6,60	3,45	2,05	6,57	3,20	2,20	6,56	2,98	2,35	6,54	2,79	2,50	6,58	2,63	2,59	6,30	2,43
-2°C	1,83	6,62	3,61	1,95	6,61	3,39	2,09	6,56	3,14	2,23	6,53	2,93	2,37	6,51	2,74	2,52	6,54	2,59	2,57	6,17	2,40
-3°C	1,88	6,63	3,52	2,00	6,61	3,31	2,13	6,56	3,08	2,27	6,51	2,87	2,41	6,47	2,69	2,56	6,51	2,55	2,55	6,03	2,37
-4°C	1,94	6,65	3,42	2,06	6,62	3,22	2,18	6,55	3,00	2,31	6,49	2,80	2,45	6,43	2,63	2,60	6,48	2,49	2,52	5,90	2,34
-5°C	2,02	6,67	3,31	2,13	6,63	3,11	2,25	6,54	2,91	2,37	6,47	2,73	2,49	6,40	2,57	2,64	6,44	2,44	2,48	5,77	2,32
-6°C	2,10	6,68	3,19	2,21	6,64	3,00	2,32	6,53	2,82	2,43	6,44	2,65	2,55	6,36	2,50	2,70	6,41	2,38	2,44	5,63	2,31
-7°C	2,19	6,70	3,06	2,31	6,64	2,88	2,40	6,52	2,72	2,50	6,42	2,57	2,61	6,32	2,42	2,76	6,38	2,31	2,39	5,50	2,30
-8°C	2,13	6,50	3,06	2,26	6,35	2,81	2,37	6,15	2,59	2,49	6,14	2,46	2,62	6,13	2,34	2,77	6,23	2,25	2,58	5,70	2,21
-9°C	2,07	6,31	3,05	2,21	6,05	2,74	2,34	5,77	2,46	2,48	5,86	2,36	2,62	5,94	2,26	2,78	6,08	2,19	2,76	5,90	2,14
-10°C	2,00	6,11	3,05	2,16	5,76	2,66	2,32	5,40	2,33	2,47	5,58	2,25	2,63	5,75	2,18	2,79	5,93	2,12	2,95	6,10	2,07
-11°C	2,03	6,07	2,99	2,18	5,74	2,63	2,33	5,42	2,32	2,48	5,51	2,22	2,62	5,61	2,14	2,77	5,70	2,06	2,91	5,72	1,96
-12°C	2,05	6,02	2,93	2,20	5,73	2,60	2,35	5,43	2,31	2,48	5,45	2,20	2,62	5,48	2,09	2,75	5,47	1,99	2,88	5,34	1,85
-13°C	2,08	5,98	2,88	2,22	5,71	2,57	2,36	5,45	2,30	2,49	5,39	2,17	2,61	5,34	2,05	2,73	5,24	1,92	2,85	4,96	1,74
-14°C	2,10	5,93	2,82	2,24	5,70	2,54	2,38	5,46	2,30	2,49	5,33	2,14	2,60	5,20	2,00	2,71	5,01	1,85	2,82	4,58	1,63
-15°C	2,13	5,89	2,77	2,26	5,68	2,51	2,39	5,48	2,29	2,53	5,27	2,09	2,66	5,06	1,90	2,77	4,78	1,73	2,79	4,20	1,51
-16°C	2,12	5,63	2,65	2,25	5,44	2,42	2,38	5,25	2,20	2,48	5,06	2,04	2,58	4,87	1,88	2,68	4,61	1,72	2,78	4,10	1,47
-17°C	2,12	5,38																			

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,49	8,15	3,28	2,88	8,07	2,80	3,34	7,98	2,39	0,00	0,00	0,00	35°C
2,49	8,13	3,27	2,88	8,05	2,79	3,34	7,97	2,39	0,00	0,00	0,00	34°C
2,48	8,11	3,27	2,88	8,03	2,79	3,34	7,95	2,38	0,00	0,00	0,00	33°C
2,48	8,10	3,27	2,88	8,02	2,79	3,33	7,93	2,38	0,00	0,00	0,00	32°C
2,48	8,08	3,26	2,87	8,00	2,78	3,33	7,92	2,38	0,00	0,00	0,00	31°C
2,48	8,06	3,26	2,87	7,98	2,78	3,33	7,90	2,37	0,00	0,00	0,00	30°C
2,47	8,05	3,25	2,87	7,96	2,78	3,32	7,88	2,37	0,00	0,00	0,00	29°C
2,47	8,03	3,25	2,86	7,95	2,78	3,32	7,86	2,37	0,00	0,00	0,00	28°C
2,47	8,01	3,25	2,86	7,93	2,77	3,32	7,85	2,37	0,00	0,00	0,00	27°C
2,47	8,00	3,24	2,86	7,91	2,77	3,31	7,83	2,36	0,00	0,00	0,00	26°C
2,46	7,98	3,24	2,86	7,90	2,77	3,31	7,81	2,36	0,00	0,00	0,00	25°C
2,46	7,96	3,24	2,85	7,88	2,76	3,31	7,80	2,36	0,00	0,00	0,00	24°C
2,46	7,95	3,23	2,85	7,86	2,76	3,30	7,78	2,36	0,00	0,00	0,00	23°C
2,46	7,93	3,23	2,85	7,85	2,76	3,30	7,76	2,35	0,00	0,00	0,00	22°C
2,45	7,91	3,23	2,84	7,83	2,75	3,30	7,75	2,35	0,00	0,00	0,00	21°C
2,45	7,90	3,22	2,84	7,81	2,75	3,29	7,73	2,35	0,00	0,00	0,00	20°C
2,45	7,88	3,22	2,84	7,80	2,75	3,29	7,71	2,34	3,81	7,63	2,00	19°C
2,45	7,86	3,22	2,84	7,78	2,74	3,29	7,70	2,34	3,81	7,62	2,00	18°C
2,44	7,85	3,21	2,83	7,76	2,74	3,28	7,68	2,34	3,81	7,60	2,00	17°C
2,44	7,83	3,21	2,83	7,75	2,74	3,28	7,67	2,34	3,80	7,58	1,99	16°C
2,44	7,81	3,20	2,83	7,73	2,74	3,28	7,65	2,33	3,80	7,57	1,99	15°C
2,44	7,80	3,20	2,82	7,72	2,73	3,27	7,63	2,33	3,80	7,55	1,99	14°C
2,43	7,78	3,20	2,82	7,70	2,73	3,27	7,62	2,33	3,79	7,53	1,99	13°C
2,43	7,77	3,19	2,82	7,68	2,73	3,27	7,60	2,33	3,79	7,52	1,98	12°C
2,43	7,72	3,18	2,82	7,64	2,71	3,26	7,55	2,31	3,78	7,47	1,97	11°C
2,43	7,67	3,16	2,81	7,59	2,70	3,26	7,51	2,30	3,78	7,43	1,96	10°C
2,42	7,63	3,15	2,81	7,55	2,69	3,26	7,46	2,29	3,78	7,38	1,95	9°C
2,42	7,58	3,13	2,81	7,50	2,67	3,25	7,42	2,28	3,77	7,34	1,94	8°C
2,42	7,54	3,12	2,80	7,45	2,66	3,25	7,37	2,27	3,77	7,29	1,93	7°C
2,54	7,32	2,88	2,85	7,27	2,55	3,19	7,21	2,26	3,57	7,16	2,00	6°C
2,64	7,14	2,70	2,88	7,11	2,47	3,14	7,08	2,26	3,42	7,05	2,06	5°C
2,71	6,99	2,58	2,90	6,98	2,41	3,10	6,97	2,25	3,31	6,96	2,10	4°C
2,75	6,87	2,50	2,92	6,88	2,36	3,08	6,89	2,24	3,24	6,89	2,12	3°C
2,77	6,73	2,43	2,92	6,75	2,31	3,07	6,78	2,21	3,22	6,80	2,11	2°C
2,75	6,41	2,33	2,90	6,26	2,16	3,04	6,11	2,01	3,18	6,00	1,89	1°C
2,71	6,10	2,25	2,82	5,77	2,04	2,93	5,44	1,85	3,04	5,21	1,71	0°C
2,65	5,79	2,19	2,70	5,28	1,95	2,76	4,77	1,73	2,82	4,41	1,57	-1°C
2,55	5,48	2,15	2,53	4,79	1,89	2,51	4,10	1,63	2,50	3,61	1,45	-2°C
2,43	5,16	2,13	2,31	4,30	1,86	2,20	3,43	1,56	2,09	2,81	1,35	-3°C
2,28	4,85	2,13	2,05	3,81	1,86	1,81	2,76	1,52	1,59	2,02	1,26	-4°C
2,11	4,54	2,16	1,73	3,31	1,91	1,36	2,09	1,54	1,01	1,22	1,21	-5°C
1,90	4,23	2,22	1,37	2,82	2,06	0,83	1,42	1,70	0,33	0,42	1,28	-6°C
1,67	3,92	2,34	0,96	2,33	2,44	0,24	0,75	3,15	0,44	0,38	0,85	-7°C
2,09	4,43	2,12	1,61	3,16	1,96	1,13	1,89	1,68	0,72	1,18	1,64	-8°C
2,51	4,94	1,97	2,27	3,99	1,76	2,02	3,03	1,50	1,88	2,73	1,45	-9°C
2,93	5,46	1,86	2,92	4,82	1,65	2,91	4,17	1,44	3,04	4,28	1,41	-10°C
2,91	5,09	1,75	2,90	4,46	1,54	2,89	3,83	1,33	0,00	0,00	0,00	-11°C
2,88	4,72	1,64	2,88	4,11	1,43	2,88	3,49	1,21	0,00	0,00	0,00	-12°C
2,85	4,36	1,53	2,86	3,75	1,31	2,86	3,15	1,10	0,00	0,00	0,00	-13°C
2,83	3,99	1,41	2,84	3,40	1,20	2,85	2,80	0,99	0,00	0,00	0,00	-14°C
2,80	3,62	1,29	2,82	3,04	1,08	0,00	0,00	0,00	0,00	0,00	0,00	-15°C
2,79	3,53	1,26	2,80	2,96	1,06	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,78	3,44	1,24	2,78	2,87	1,03	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
2,77	3,34	1,21	2,76	2,79	1,01	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
2,76	3,25	1,18	2,75	2,70	0,98	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
2,75	3,16	1,15	2,73	2,62	0,96	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
2,75	3,07	1,12	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
2,74	2,97	1,09	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
2,73	2,88	1,06	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
2,72	2,79	1,03	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
2,71	2,70	1,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 COMPACT 7 / 7TRI

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	1,12	9,21	8,20	1,46	9,21	6,33	1,68	9,15	5,44	2,04	9,14	4,49	2,39	9,21	3,86	2,73	9,33	3,42	3,08	9,58	3,11
	34°C	1,12	9,19	8,22	1,45	9,19	6,34	1,67	9,13	5,45	2,04	9,13	4,48	2,38	9,19	3,86	2,73	9,31	3,41	3,08	9,58	3,11
	33°C	1,11	9,18	8,23	1,44	9,18	6,35	1,67	9,11	5,46	2,03	9,11	4,48	2,38	9,18	3,85	2,73	9,31	3,42	3,07	9,58	3,12
	32°C	1,11	9,16	8,25	1,44	9,16	6,37	1,66	9,10	5,48	2,03	9,09	4,47	2,38	9,16	3,85	2,72	9,31	3,42	3,07	9,58	3,12
	31°C	1,11	9,14	8,27	1,43	9,14	6,38	1,65	9,08	5,49	2,03	9,07	4,47	2,38	9,14	3,85	2,72	9,31	3,42	3,07	9,58	3,12
	30°C	1,10	9,12	8,28	1,43	9,12	6,39	1,65	9,06	5,50	2,03	9,05	4,46	2,37	9,12	3,84	2,72	9,31	3,43	3,06	9,58	3,13
	29°C	1,10	9,10	8,30	1,42	9,10	6,40	1,64	9,04	5,51	2,03	9,03	4,46	2,37	9,10	3,84	2,72	9,31	3,43	3,06	9,58	3,13
	28°C	1,09	9,09	8,32	1,42	9,09	6,42	1,64	9,02	5,52	2,02	9,02	4,45	2,37	9,09	3,84	2,71	9,31	3,43	3,06	9,58	3,13
	27°C	1,09	9,07	8,33	1,41	9,07	6,43	1,63	9,01	5,53	2,02	9,00	4,45	2,37	9,07	3,83	2,71	9,31	3,44	3,05	9,58	3,14
	26°C	1,08	9,05	8,35	1,40	9,05	6,44	1,62	8,99	5,54	2,02	8,98	4,45	2,36	9,05	3,83	2,71	9,31	3,44	3,05	9,58	3,14
	25°C	1,08	9,03	8,37	1,40	9,03	6,46	1,62	8,97	5,55	2,02	8,96	4,44	2,36	9,04	3,83	2,70	9,31	3,44	3,05	9,58	3,14
	24°C	1,08	9,01	8,38	1,39	9,01	6,47	1,61	8,95	5,56	2,02	8,94	4,44	2,36	9,04	3,83	2,70	9,31	3,45	3,05	9,58	3,15
	23°C	1,07	9,00	8,40	1,39	9,00	6,48	1,60	8,93	5,57	2,01	8,93	4,43	2,36	9,04	3,84	2,70	9,31	3,45	3,04	9,58	3,15
	22°C	1,07	8,98	8,42	1,38	8,98	6,49	1,60	8,92	5,59	2,01	8,91	4,43	2,35	9,04	3,84	2,70	9,31	3,45	3,04	9,58	3,15
	21°C	1,06	8,96	8,43	1,38	8,96	6,51	1,59	8,90	5,60	2,01	8,89	4,42	2,35	9,04	3,85	2,69	9,31	3,46	3,04	9,58	3,16
	20°C	1,06	8,94	8,45	1,37	8,94	6,52	1,58	8,88	5,61	2,01	8,87	4,42	2,35	9,04	3,85	2,69	9,31	3,46	3,03	9,58	3,16
	19°C	1,05	8,92	8,47	1,37	8,92	6,53	1,58	8,86	5,62	2,01	8,86	4,41	2,35	9,04	3,85	2,69	9,31	3,46	3,03	9,58	3,16
	18°C	1,05	8,91	8,48	1,36	8,91	6,55	1,57	8,85	5,63	2,00	8,84	4,41	2,35	9,04	3,86	2,69	9,31	3,47	3,03	9,58	3,17
	17°C	1,05	8,89	8,50	1,35	8,89	6,56	1,56	8,83	5,64	2,00	8,82	4,41	2,34	9,04	3,86	2,68	9,31	3,47	3,02	9,58	3,17
	16°C	1,04	8,87	8,52	1,35	8,87	6,57	1,56	8,81	5,65	2,00	8,80	4,40	2,34	9,04	3,86	2,68	9,31	3,47	3,02	9,58	3,17
	15°C	1,04	8,85	8,53	1,34	8,85	6,59	1,55	8,79	5,66	2,00	8,79	4,40	2,34	9,04	3,87	2,68	9,31	3,48	3,02	9,58	3,17
	14°C	1,03	8,83	8,55	1,34	8,83	6,60	1,55	8,78	5,68	2,00	8,78	4,40	2,34	9,04	3,87	2,68	9,31	3,48	3,01	9,58	3,18
	13°C	1,03	8,82	8,57	1,33	8,82	6,61	1,54	8,76	5,69	1,99	8,78	4,40	2,33	9,04	3,88	2,67	9,31	3,48	3,01	9,58	3,18
	12°C	1,02	8,80	8,59	1,33	8,80	6,63	1,53	8,74	5,70	1,99	8,78	4,41	2,33	9,04	3,88	2,67	9,31	3,49	3,01	9,58	3,18
	11°C	1,10	8,77	7,95	1,38	8,77	6,36	1,58	8,73	5,54	1,99	8,78	4,41	2,33	9,04	3,88	2,67	9,31	3,49	3,01	9,58	3,19
10°C	1,18	8,75	7,41	1,43	8,75	6,12	1,62	8,72	5,39	1,99	8,78	4,41	2,33	9,04	3,89	2,66	9,31	3,49	3,00	9,58	3,19	
9°C	1,26	8,72	6,93	1,48	8,72	5,89	1,66	8,70	5,25	1,99	8,78	4,42	2,32	9,04	3,89	2,66	9,31	3,50	3,00	9,58	3,19	
8°C	1,34	8,70	6,50	1,53	8,70	5,68	1,70	8,69	5,12	1,98	8,78	4,42	2,32	9,04	3,90	2,66	9,31	3,50	3,00	9,58	3,20	
7°C	1,42	8,67	6,12	1,58	8,67	5,48	1,72	8,67	5,05	1,98	8,78	4,43	2,32	9,04	3,90	2,66	9,31	3,51	2,99	9,58	3,20	
6°C	1,56	8,11	5,20	1,68	8,11	4,82	1,82	8,12	4,45	2,05	8,21	4,01	2,32	8,41	3,63	2,59	8,61	3,33	2,86	8,82	3,08	
5°C	1,67	7,63	4,57	1,76	7,64	4,34	1,91	7,66	4,02	2,10	7,72	3,68	2,32	7,87	3,40	2,53	8,02	3,16	2,75	8,17	2,97	
4°C	1,75	7,24	4,13	1,82	7,26	4,00	1,96	7,27	3,70	2,13	7,33	3,43	2,32	7,43	3,21	2,50	7,54	3,02	2,68	7,64	2,85	
3°C	1,80	6,94	3,86	1,85	6,96	3,76	2,00	6,98	3,49	2,16	7,02	3,26	2,31	7,09	3,06	2,47	7,16	2,89	2,63	7,23	2,75	
2°C	1,82	6,55	3,61	1,86	6,57	3,53	2,01	6,60	3,28	2,16	6,62	3,06	2,31	6,65	2,87	2,47	6,68	2,71	2,62	6,70	2,56	
1°C	1,82	6,80	3,73	1,87	6,77	3,62	2,02	6,75	3,34	2,17	6,76	3,11	2,32	6,77	2,92	2,47	6,69	2,71	2,62	6,68	2,55	
0°C	1,85	7,05	3,82	1,89	6,97	3,68	2,04	6,90	3,38	2,19	6,89	3,15	2,33	6,88	2,95	2,48	6,70	2,70	2,63	6,66	2,53	
-1°C	1,88	7,30	3,88	1,93	7,17	3,71	2,08	7,05	3,39	2,22	7,02	3,17	2,36	7,00	2,97	2,50	6,71	2,68	2,65	6,64	2,50	
-2°C	1,94	7,55	3,90	1,99	7,36	3,71	2,13	7,19	3,38	2,26	7,16	3,17	2,39	7,12	2,98	2,53	6,72	2,66	2,68	6,61	2,46	
-3°C	2,00	7,80	3,89	2,06	7,56	3,68	2,19	7,34	3,35	2,31	7,29	3,15	2,44	7,23	2,97	2,57	6,73	2,62	2,72	6,59	2,42	
-4°C	2,09	8,05	3,86	2,14	7,76	3,62	2,27	7,49	3,30	2,38	7,42	3,12	2,49	7,35	2,95	2,61	6,74	2,58	2,77	6,57	2,37	
-5°C	2,18	8,30	3,80	2,25	7,96	3,54	2,36	7,64	3,23	2,46	7,56	3,07	2,55	7,47	2,93	2,66	6,75	2,54	2,82	6,55	2,32	
-6°C	2,30	8,55	3,72	2,36	8,16	3,45	2,47	7,79	3,15	2,55	7,69	3,02	2,62	7,58	2,89	2,72	6,76	2,49	2,88	6,52	2,26	
-7°C	2,42	8,80	3,63	2,50	8,36	3,35	2,59	7,94	3,06	2,65	7,82	2,95	2,71	7,70	2,85	2,79	6,77	2,43	2,95	6,50	2,20	
-8°C	2,42	8,64	3,57	2,50	8,17	3,27	2,59	7,73	2,98	2,66	7,55	2,84	2,73	7,37	2,70	2,81	6,65	2,37	2,95	6,37	2,16	
-9°C	2,41	8,48	3,51	2,50	7,99	3,20	2,59	7,51	2,90	2,67	7,27	2,73	2,75	7,03	2,56	2,83	6,52	2,30	2,95	6,23	2,11	
-10°C	2,41	8,32	3,45	2,50	7,81	3,13	2,59	7,30	2,82	2,68	7,00	2,61	2,77	6,70	2,42	2,86	6,40	2,24	2,95	6,10	2,07	
-11°C	2,35	7,84	3,33	2,45	7,39	3,01	2,55	6,94	2,72	2,64	6,65	2,52	2,73	6,37	2,33	2,82	6,08	2,15	2,91	5,72	1,96	
-12°C	2,30	7,35	3,20	2,40	6,96	2,90	2,51	6,57	2,62	2,60	6,31	2,42	2,70	6,05	2,24	2,79	5,75	2,06	2,88	5,34	1,85	
-13°C	2,24	6,86	3,06	2,36	6,53	2,77	2,47	6,21	2,51	2,57	5,96	2,32	2,66	5,72	2,15	2,76	5,43	1,97	2,85	4,96	1,74	
-14°C	2,18	6,38	2,92	2,31	6,11	2,65	2,43	5,84	2,40	2,53	5,62	2,22	2,63	5,39	2,05	2,72	5,11	1,88	2,82	4,58	1,63	
-15°C	2,13	5,89	2,77	2,26	5,68	2,51	2,39	5,48	2,29	2,53	5,27	2,09	2,66	5,06	1,90	2,77	4,78	1,73	2,79	4,20	1,51	
-16°C	2,12	5,63																				

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
3,23	9,85	3,04	3,75	10,12	2,70	4,35	10,38	2,39	0,00	0,00	0,00	35°C
3,23	9,85	3,05	3,75	10,12	2,70	4,34	10,38	2,39	0,00	0,00	0,00	34°C
3,23	9,85	3,05	3,74	10,12	2,70	4,34	10,38	2,39	0,00	0,00	0,00	33°C
3,23	9,85	3,05	3,74	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	32°C
3,22	9,85	3,06	3,74	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	31°C
3,22	9,85	3,06	3,73	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	30°C
3,22	9,85	3,06	3,73	10,12	2,71	4,32	10,38	2,40	0,00	0,00	0,00	29°C
3,21	9,85	3,07	3,72	10,12	2,72	4,32	10,38	2,41	0,00	0,00	0,00	28°C
3,21	9,85	3,07	3,72	10,12	2,72	4,31	10,38	2,41	0,00	0,00	0,00	27°C
3,21	9,85	3,07	3,72	10,12	2,72	4,31	10,38	2,41	0,00	0,00	0,00	26°C
3,20	9,85	3,07	3,71	10,12	2,72	4,30	10,38	2,41	0,00	0,00	0,00	25°C
3,20	9,85	3,08	3,71	10,12	2,73	4,30	10,38	2,41	0,00	0,00	0,00	24°C
3,20	9,85	3,08	3,71	10,12	2,73	4,30	10,38	2,42	0,00	0,00	0,00	23°C
3,19	9,85	3,08	3,70	10,12	2,73	4,29	10,38	2,42	0,00	0,00	0,00	22°C
3,19	9,85	3,09	3,70	10,12	2,74	4,29	10,38	2,42	0,00	0,00	0,00	21°C
3,19	9,85	3,09	3,69	10,12	2,74	4,28	10,38	2,42	0,00	0,00	0,00	20°C
3,18	9,85	3,09	3,69	10,12	2,74	4,28	10,38	2,43	4,96	10,65	2,15	19°C
3,18	9,85	3,10	3,69	10,12	2,74	4,27	10,38	2,43	4,96	10,65	2,15	18°C
3,18	9,85	3,10	3,68	10,12	2,75	4,27	10,38	2,43	4,95	10,65	2,15	17°C
3,17	9,85	3,10	3,68	10,12	2,75	4,27	10,38	2,43	4,95	10,65	2,15	16°C
3,17	9,85	3,11	3,68	10,12	2,75	4,26	10,38	2,44	4,94	10,65	2,16	15°C
3,17	9,85	3,11	3,67	10,12	2,75	4,26	10,38	2,44	4,94	10,65	2,16	14°C
3,16	9,85	3,11	3,67	10,12	2,76	4,25	10,38	2,44	4,93	10,65	2,16	13°C
3,16	9,85	3,11	3,66	10,12	2,76	4,25	10,38	2,44	4,93	10,65	2,16	12°C
3,16	9,85	3,12	3,66	10,12	2,76	4,24	10,38	2,45	4,92	10,65	2,16	11°C
3,16	9,85	3,12	3,66	10,12	2,77	4,24	10,38	2,45	4,92	10,65	2,17	10°C
3,15	9,85	3,12	3,65	10,12	2,77	4,24	10,38	2,45	4,91	10,65	2,17	9°C
3,15	9,85	3,13	3,65	10,12	2,77	4,23	10,38	2,45	4,91	10,65	2,17	8°C
3,15	9,85	3,13	3,65	10,12	2,77	4,23	10,38	2,46	4,90	10,65	2,17	7°C
3,01	9,02	3,00	3,38	9,22	2,72	3,81	9,43	2,47	4,30	9,63	2,24	6°C
2,90	8,32	2,86	3,18	8,47	2,66	3,49	8,62	2,47	3,83	8,77	2,29	5°C
2,83	7,75	2,74	3,04	7,85	2,59	3,26	7,96	2,44	3,49	8,06	2,31	4°C
2,78	7,30	2,62	2,95	7,37	2,50	3,12	7,44	2,39	3,29	7,51	2,28	3°C
2,77	6,73	2,43	2,92	6,75	2,31	3,07	6,78	2,21	3,22	6,81	2,11	2°C
2,77	6,66	2,40	2,92	6,63	2,27	3,08	6,61	2,15	3,23	6,65	2,06	1°C
2,79	6,59	2,36	2,94	6,51	2,22	3,09	6,44	2,08	3,24	6,49	2,00	0°C
2,81	6,51	2,32	2,96	6,39	2,16	3,11	6,27	2,01	3,27	6,33	1,93	-1°C
2,84	6,44	2,27	2,99	6,27	2,10	3,15	6,10	1,94	3,31	6,17	1,86	-2°C
2,88	6,37	2,21	3,03	6,15	2,03	3,19	5,93	1,86	3,36	6,01	1,79	-3°C
2,92	6,30	2,15	3,08	6,03	1,96	3,24	5,76	1,78	3,42	5,85	1,71	-4°C
2,98	6,23	2,09	3,14	5,91	1,88	3,30	5,59	1,69	3,49	5,69	1,63	-5°C
3,05	6,16	2,02	3,21	5,79	1,80	3,37	5,42	1,61	3,57	5,53	1,55	-6°C
3,12	6,08	1,95	3,28	5,67	1,73	3,45	5,25	1,52	3,66	5,38	1,47	-7°C
3,04	5,78	1,90	3,12	5,18	1,66	3,21	4,59	1,43	3,38	4,61	1,37	-8°C
2,96	5,47	1,85	2,96	4,70	1,59	2,97	3,93	1,32	3,09	3,85	1,24	-9°C
2,88	5,16	1,79	2,80	4,22	1,50	2,73	3,28	1,20	2,81	3,09	1,10	-10°C
2,86	4,85	1,70	2,81	3,98	1,42	2,75	3,11	1,13	0,00	0,00	0,00	-11°C
2,85	4,54	1,60	2,81	3,75	1,33	2,77	2,95	1,06	0,00	0,00	0,00	-12°C
2,83	4,24	1,50	2,81	3,51	1,25	2,79	2,79	1,00	0,00	0,00	0,00	-13°C
2,82	3,93	1,40	2,81	3,28	1,16	2,81	2,62	0,93	0,00	0,00	0,00	-14°C
2,80	3,62	1,29	2,82	3,04	1,08	2,83	2,46	0,87	0,00	0,00	0,00	-15°C
2,79	3,53	1,26	2,80	2,96	1,06	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,78	3,44	1,24	2,78	2,87	1,03	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
2,77	3,34	1,21	2,76	2,79	1,01	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
2,76	3,25	1,18	2,75	2,70	0,98	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
2,75	3,16	1,15	2,73	2,62	0,96	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
2,75	3,07	1,12	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
2,74	2,97	1,09	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
2,73	2,88	1,06	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
2,72	2,79	1,03	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
2,71	2,70	1,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 COMPACT 9 / 9TRI

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1.82	13.38	7.36	2.29	13.38	5.85	2.61	13.20	5.06	3.15	13.17	4.19	3.62	13.22	3.65	4.10	13.32	3.25	4.57	13.44	2.94
34°C	1.81	13.35	7.37	2.28	13.35	5.86	2.60	13.17	5.07	3.14	13.14	4.18	3.62	13.20	3.65	4.09	13.29	3.25	4.57	13.41	2.93
33°C	1.80	13.33	7.39	2.27	13.33	5.87	2.59	13.15	5.08	3.14	13.11	4.18	3.61	13.17	3.64	4.09	13.26	3.24	4.56	13.38	2.93
32°C	1.80	13.30	7.40	2.26	13.30	5.88	2.58	13.12	5.09	3.14	13.09	4.17	3.61	13.14	3.64	4.09	13.24	3.24	4.56	13.36	2.93
31°C	1.79	13.27	7.42	2.25	13.27	5.90	2.57	13.09	5.10	3.13	13.06	4.17	3.61	13.12	3.64	4.08	13.21	3.24	4.56	13.33	2.93
30°C	1.78	13.25	7.43	2.24	13.25	5.91	2.56	13.07	5.11	3.13	13.04	4.16	3.60	13.09	3.63	4.08	13.19	3.23	4.55	13.30	2.92
29°C	1.78	13.22	7.45	2.23	13.22	5.92	2.55	13.04	5.12	3.13	13.01	4.16	3.60	13.07	3.63	4.07	13.16	3.23	4.55	13.28	2.92
28°C	1.77	13.19	7.46	2.22	13.19	5.93	2.54	13.02	5.13	3.12	12.98	4.16	3.60	13.04	3.63	4.07	13.13	3.23	4.54	13.25	2.92
27°C	1.76	13.17	7.48	2.22	13.17	5.94	2.53	12.99	5.14	3.12	12.96	4.15	3.59	13.01	3.62	4.07	13.11	3.22	4.54	13.23	2.92
26°C	1.75	13.14	7.49	2.21	13.14	5.96	2.52	12.96	5.15	3.12	12.93	4.15	3.59	12.99	3.62	4.06	13.08	3.22	4.53	13.20	2.91
25°C	1.75	13.12	7.51	2.20	13.12	5.97	2.51	12.94	5.16	3.11	12.91	4.14	3.59	12.96	3.61	4.06	13.06	3.22	4.53	13.17	2.91
24°C	1.74	13.09	7.52	2.19	13.09	5.98	2.50	12.91	5.17	3.11	12.88	4.14	3.58	12.94	3.61	4.05	13.03	3.22	4.52	13.15	2.91
23°C	1.73	13.06	7.54	2.18	13.06	5.99	2.49	12.89	5.18	3.11	12.86	4.14	3.58	12.91	3.61	4.05	13.01	3.21	4.52	13.12	2.90
22°C	1.73	13.04	7.55	2.17	13.04	6.00	2.48	12.86	5.19	3.11	12.83	4.13	3.57	12.88	3.60	4.04	12.98	3.21	4.51	13.12	2.91
21°C	1.72	13.01	7.57	2.16	13.01	6.02	2.47	12.84	5.20	3.10	12.80	4.13	3.57	12.86	3.60	4.04	12.95	3.21	4.51	13.12	2.91
20°C	1.71	12.99	7.58	2.15	12.99	6.03	2.46	12.81	5.21	3.10	12.78	4.12	3.57	12.83	3.60	4.04	12.93	3.20	4.51	13.12	2.91
19°C	1.71	12.96	7.60	2.15	12.96	6.04	2.45	12.78	5.22	3.10	12.75	4.12	3.56	12.81	3.59	4.03	12.91	3.20	4.50	13.12	2.91
18°C	1.70	12.93	7.61	2.14	12.93	6.05	2.44	12.76	5.23	3.09	12.73	4.12	3.56	12.78	3.59	4.03	12.91	3.20	4.50	13.12	2.92
17°C	1.69	12.91	7.63	2.13	12.91	6.06	2.43	12.73	5.24	3.09	12.70	4.11	3.56	12.76	3.59	4.02	12.91	3.21	4.49	13.12	2.92
16°C	1.69	12.88	7.64	2.12	12.88	6.08	2.42	12.71	5.25	3.09	12.68	4.11	3.55	12.73	3.58	4.02	12.91	3.21	4.49	13.12	2.92
15°C	1.68	12.86	7.66	2.11	12.86	6.09	2.41	12.68	5.26	3.08	12.65	4.10	3.55	12.71	3.58	4.02	12.91	3.21	4.48	13.12	2.93
14°C	1.67	12.83	7.67	2.10	12.83	6.10	2.40	12.66	5.27	3.08	12.63	4.10	3.55	12.70	3.58	4.01	12.91	3.22	4.48	13.12	2.93
13°C	1.67	12.80	7.69	2.10	12.80	6.11	2.39	12.63	5.28	3.08	12.60	4.09	3.54	12.70	3.58	4.01	12.91	3.22	4.47	13.12	2.93
12°C	1.66	12.78	7.70	2.09	12.78	6.12	2.38	12.61	5.29	3.07	12.58	4.09	3.54	12.70	3.59	4.00	12.91	3.22	4.47	13.12	2.94
11°C	1.72	12.70	7.37	2.13	12.70	5.95	2.44	12.57	5.15	3.07	12.54	4.08	3.54	12.70	3.59	4.00	12.91	3.23	4.47	13.12	2.94
10°C	1.79	12.63	7.06	2.18	12.63	5.79	2.50	12.54	5.01	3.07	12.51	4.08	3.53	12.70	3.59	4.00	12.91	3.23	4.46	13.12	2.94
9°C	1.85	12.55	6.77	2.23	12.55	5.63	2.56	12.50	4.89	3.07	12.48	4.07	3.53	12.70	3.60	3.99	12.91	3.23	4.46	13.12	2.94
8°C	1.92	12.48	6.51	2.28	12.48	5.48	2.62	12.47	4.76	3.06	12.48	4.08	3.53	12.70	3.60	3.99	12.91	3.24	4.45	13.12	2.95
7°C	1.98	12.40	6.25	2.33	12.40	5.33	2.65	12.40	4.69	3.06	12.48	4.08	3.52	12.70	3.61	3.98	12.91	3.24	4.45	13.12	2.95
6°C	2.29	12.20	5.33	2.60	12.15	4.67	2.90	12.11	4.17	3.26	12.12	3.71	3.66	12.23	3.34	4.05	12.34	3.05	4.44	12.45	2.80
5°C	2.53	12.03	4.76	2.82	11.95	4.24	3.11	11.86	3.82	3.43	11.82	3.45	3.76	11.84	3.15	4.10	11.86	2.89	4.44	11.89	2.68
4°C	2.70	11.89	4.41	2.97	11.78	3.96	3.25	11.66	3.59	3.54	11.57	3.27	3.84	11.52	3.00	4.14	11.47	2.77	4.44	11.42	2.57
3°C	2.80	11.79	4.21	3.06	11.64	3.80	3.33	11.50	3.45	3.61	11.37	3.15	3.88	11.27	2.90	4.16	11.17	2.68	4.44	11.06	2.49
2°C	2.83	11.65	4.11	3.10	11.47	3.71	3.36	11.30	3.36	3.63	11.12	3.06	3.90	10.95	2.81	4.17	10.78	2.59	4.44	10.60	2.39
1°C	2.84	11.61	4.08	3.10	11.41	3.68	3.37	11.22	3.33	3.64	11.05	3.04	3.90	10.87	2.79	4.17	10.63	2.55	4.44	10.39	2.34
0°C	2.87	11.57	4.03	3.13	11.35	3.63	3.39	11.14	3.28	3.65	10.97	3.00	3.91	10.80	2.76	4.17	10.49	2.52	4.45	10.19	2.29
-1°C	2.93	11.53	3.94	3.17	11.29	3.56	3.43	11.06	3.22	3.68	10.89	2.96	3.92	10.72	2.73	4.17	10.35	2.48	4.48	9.98	2.23
-2°C	3.00	11.49	3.83	3.23	11.22	3.47	3.48	10.98	3.15	3.71	10.81	2.91	3.94	10.64	2.70	4.18	10.21	2.44	4.51	9.78	2.17
-3°C	3.09	11.46	3.70	3.31	11.16	3.38	3.55	10.90	3.07	3.76	10.73	2.85	3.97	10.57	2.66	4.18	10.07	2.41	4.55	9.57	2.10
-4°C	3.21	11.42	3.56	3.40	11.10	3.26	3.64	10.82	2.98	3.82	10.66	2.79	4.00	10.49	2.63	4.19	9.93	2.37	4.60	9.37	2.04
-5°C	3.34	11.38	3.41	3.51	11.04	3.14	3.73	10.74	2.88	3.88	10.58	2.72	4.03	10.42	2.58	4.20	9.79	2.33	4.66	9.16	1.97
-6°C	3.50	11.34	3.24	3.64	10.97	3.02	3.85	10.66	2.77	3.96	10.50	2.65	4.07	10.34	2.54	4.21	9.64	2.29	4.73	8.96	1.89
-7°C	3.67	11.30	3.08	3.78	10.91	2.89	3.98	10.58	2.66	4.05	10.42	2.57	4.12	10.26	2.49	4.22	9.50	2.25	4.81	8.75	1.82
-8°C	3.87	11.15	2.88	3.94	10.73	2.72	4.08	10.35	2.54	4.13	10.10	2.44	4.19	9.84	2.35	4.26	9.19	2.16	4.66	8.53	1.83
-9°C	4.06	10.99	2.71	4.11	10.55	2.57	4.18	10.13	2.42	4.22	9.77	2.32	4.25	9.42	2.22	4.30	8.87	2.06	4.51	8.32	1.85
-10°C	4.25	10.84	2.55	4.27	10.37	2.43	4.29	9.90	2.31	4.30	9.45	2.20	4.32	9.00	2.08	4.34	8.55	1.97	4.35	8.10	1.86
-11°C	4.09	10.42	2.55	4.15	10.02	2.42	4.20	9.63	2.29	4.25	9.25	2.18	4.29	8.87	2.07	4.34	8.47	1.95	4.38	7.94	1.81
-12°C	3.93	9.99	2.54	4.02	9.68	2.41	4.12	9.36	2.27	4.19	9.05	2.16	4.26	8.75	2.05	4.34	8.38	1.93	4.41	7.78	1.77
-13°C	3.77	9.57	2.54	3.90	9.33	2.39	4.03	9.09	2.25	4.13	8.86	2.14	4.23	8.62	2.04	4.33	8.30	1.92	4.43	7.63	1.72
-14°C	3.60	9.15	2.54	3.78	8.98	2.38	3.95	8.82	2.23	4.08	8.66	2.12	4.21	8.50	2.02	4.33	8.22	1.90	4.46	7.47	1.67
-15°C	3.44	8.72	2.53	3.65	8.64	2.36	3.87	8.55	2.21												

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,81	13,57	2,82	5,57	13,71	2,46	6,46	13,87	2,15	0,00	0,00	0,00	35°C
4,80	13,54	2,82	5,57	13,69	2,46	6,45	13,84	2,15	0,00	0,00	0,00	34°C
4,80	13,52	2,82	5,56	13,66	2,46	6,45	13,82	2,14	0,00	0,00	0,00	33°C
4,79	13,49	2,82	5,55	13,64	2,45	6,44	13,79	2,14	0,00	0,00	0,00	32°C
4,79	13,46	2,81	5,55	13,61	2,45	6,43	13,76	2,14	0,00	0,00	0,00	31°C
4,78	13,44	2,81	5,54	13,58	2,45	6,43	13,76	2,14	0,00	0,00	0,00	30°C
4,78	13,41	2,81	5,54	13,56	2,45	6,42	13,76	2,14	0,00	0,00	0,00	29°C
4,77	13,39	2,80	5,53	13,54	2,45	6,41	13,76	2,14	0,00	0,00	0,00	28°C
4,77	13,36	2,80	5,53	13,54	2,45	6,41	13,76	2,15	0,00	0,00	0,00	27°C
4,76	13,33	2,80	5,52	13,54	2,45	6,40	13,76	2,15	0,00	0,00	0,00	26°C
4,76	13,33	2,80	5,52	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	25°C
4,75	13,33	2,80	5,51	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	24°C
4,75	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	23°C
4,74	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	22°C
4,74	13,33	2,81	5,49	13,54	2,47	6,37	13,76	2,16	0,00	0,00	0,00	21°C
4,73	13,33	2,82	5,49	13,54	2,47	6,36	13,76	2,16	0,00	0,00	0,00	20°C
4,73	13,33	2,82	5,48	13,54	2,47	6,36	13,76	2,16	7,37	13,97	1,90	19°C
4,72	13,33	2,82	5,48	13,54	2,47	6,35	13,76	2,17	7,36	13,97	1,90	18°C
4,72	13,33	2,82	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	17°C
4,72	13,33	2,83	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	16°C
4,71	13,33	2,83	5,46	13,54	2,48	6,33	13,76	2,17	7,34	13,97	1,90	15°C
4,71	13,33	2,83	5,46	13,54	2,48	6,32	13,76	2,17	7,33	13,97	1,90	14°C
4,70	13,33	2,84	5,45	13,54	2,48	6,32	13,76	2,18	7,32	13,97	1,91	13°C
4,70	13,33	2,84	5,44	13,54	2,49	6,31	13,76	2,18	7,32	13,97	1,91	12°C
4,69	13,33	2,84	5,44	13,54	2,49	6,31	13,76	2,18	7,31	13,97	1,91	11°C
4,69	13,33	2,84	5,43	13,54	2,49	6,30	13,76	2,18	7,30	13,97	1,91	10°C
4,68	13,33	2,85	5,43	13,54	2,49	6,29	13,76	2,19	7,30	13,97	1,91	9°C
4,68	13,33	2,85	5,42	13,54	2,50	6,29	13,76	2,19	7,29	13,97	1,92	8°C
4,67	13,33	2,85	5,42	13,54	2,50	6,28	13,76	2,19	7,28	13,97	1,92	7°C
4,68	12,56	2,68	5,26	12,67	2,41	5,91	12,78	2,16	6,64	12,89	1,94	6°C
4,69	11,91	2,54	5,13	11,93	2,32	5,61	11,95	2,13	6,15	11,97	1,95	5°C
4,70	11,37	2,42	5,04	11,33	2,25	5,41	11,28	2,09	5,79	11,23	1,94	4°C
4,70	10,96	2,33	4,99	10,85	2,18	5,28	10,75	2,04	5,58	10,65	1,91	3°C
4,70	10,43	2,22	4,97	10,25	2,06	5,24	10,08	1,92	5,51	9,90	1,80	2°C
4,71	10,10	2,14	4,99	9,80	1,96	5,26	9,50	1,80	5,54	9,28	1,68	1°C
4,75	9,77	2,06	5,04	9,34	1,85	5,33	8,92	1,67	5,63	8,66	1,54	0°C
4,80	9,44	1,96	5,13	8,89	1,73	5,45	8,34	1,53	5,79	8,04	1,39	-1°C
4,88	9,11	1,87	5,25	8,44	1,61	5,62	7,76	1,38	6,01	7,42	1,23	-2°C
4,98	8,78	1,76	5,41	7,98	1,48	5,84	7,19	1,23	6,29	6,80	1,08	-3°C
5,10	8,45	1,66	5,60	7,53	1,34	6,10	6,61	1,08	6,63	6,18	0,93	-4°C
5,24	8,12	1,55	5,83	7,07	1,21	6,41	6,03	0,94	7,04	5,55	0,79	-5°C
5,41	7,79	1,44	6,09	6,62	1,09	6,77	5,45	0,81	7,51	4,93	0,66	-6°C
5,60	7,46	1,33	6,38	6,17	0,97	7,17	4,88	0,68	8,04	4,31	0,54	-7°C
5,11	7,24	1,42	5,57	5,96	1,07	6,03	4,67	0,77	6,61	4,20	0,63	-8°C
4,63	7,03	1,52	4,76	5,75	1,21	4,89	4,46	0,91	5,19	4,08	0,79	-9°C
4,15	6,82	1,64	3,95	5,54	1,40	3,75	4,25	1,14	3,76	3,97	1,06	-10°C
4,22	6,75	1,60	4,07	5,56	1,37	3,91	4,37	1,12	0,00	0,00	0,00	-11°C
4,29	6,68	1,56	4,18	5,59	1,34	4,07	4,49	1,10	0,00	0,00	0,00	-12°C
4,37	6,62	1,52	4,30	5,61	1,31	4,23	4,60	1,09	0,00	0,00	0,00	-13°C
4,44	6,55	1,48	4,41	5,64	1,28	4,39	4,72	1,07	0,00	0,00	0,00	-14°C
4,51	6,49	1,44	4,53	5,66	1,25	4,55	4,84	1,06	0,00	0,00	0,00	-15°C
4,52	6,39	1,41	4,54	5,55	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
4,54	6,30	1,39	4,55	5,43	1,19	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
4,55	6,21	1,36	4,56	5,32	1,17	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
4,57	6,11	1,34	4,57	5,21	1,14	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
4,58	6,02	1,31	4,57	5,09	1,11	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
4,59	5,93	1,29	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
4,61	5,83	1,27	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
4,62	5,74	1,24	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
4,64	5,65	1,22	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
4,65	5,55	1,19	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 COMPACT 12 / 12TRI

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	2,04	15,54	7,63	2,54	15,54	6,11	2,89	15,39	5,32	3,44	15,36	4,46	3,96	15,46	3,90	4,49	15,63	3,48	5,01	15,83	3,16
	34°C	2,03	15,50	7,64	2,53	15,50	6,12	2,88	15,36	5,33	3,44	15,33	4,46	3,96	15,43	3,90	4,48	15,59	3,48	5,00	15,80	3,16
	33°C	2,02	15,47	7,66	2,52	15,47	6,14	2,87	15,33	5,34	3,44	15,30	4,45	3,96	15,40	3,89	4,48	15,56	3,48	5,00	15,78	3,16
	32°C	2,01	15,44	7,67	2,51	15,44	6,15	2,86	15,30	5,35	3,43	15,27	4,45	3,95	15,37	3,89	4,47	15,53	3,47	4,99	15,78	3,16
	31°C	2,00	15,41	7,69	2,50	15,41	6,16	2,85	15,27	5,36	3,43	15,24	4,45	3,95	15,34	3,88	4,47	15,50	3,47	4,99	15,78	3,16
	30°C	2,00	15,38	7,71	2,49	15,38	6,17	2,84	15,24	5,37	3,43	15,21	4,44	3,94	15,31	3,88	4,46	15,47	3,47	4,98	15,78	3,17
	29°C	1,99	15,35	7,72	2,48	15,35	6,18	2,83	15,20	5,38	3,42	15,18	4,44	3,94	15,28	3,88	4,46	15,44	3,46	4,98	15,78	3,17
	28°C	1,98	15,32	7,74	2,47	15,32	6,20	2,81	15,17	5,39	3,42	15,15	4,43	3,94	15,25	3,87	4,46	15,41	3,46	4,97	15,78	3,17
	27°C	1,97	15,29	7,75	2,46	15,29	6,21	2,80	15,14	5,40	3,42	15,12	4,43	3,93	15,22	3,87	4,45	15,41	3,46	4,97	15,78	3,18
	26°C	1,96	15,26	7,77	2,45	15,26	6,22	2,79	15,11	5,41	3,41	15,09	4,42	3,93	15,19	3,87	4,45	15,41	3,47	4,96	15,78	3,18
	25°C	1,96	15,23	7,78	2,44	15,23	6,23	2,78	15,08	5,43	3,41	15,06	4,42	3,93	15,16	3,86	4,44	15,41	3,47	4,96	15,78	3,18
	24°C	1,95	15,20	7,80	2,43	15,20	6,25	2,77	15,05	5,44	3,40	15,03	4,41	3,92	15,13	3,86	4,44	15,41	3,47	4,95	15,78	3,19
	23°C	1,94	15,17	7,81	2,42	15,17	6,26	2,76	15,02	5,45	3,40	15,00	4,41	3,92	15,10	3,85	4,43	15,41	3,48	4,95	15,78	3,19
	22°C	1,93	15,14	7,83	2,41	15,14	6,27	2,75	14,99	5,46	3,40	14,97	4,41	3,91	15,07	3,85	4,43	15,41	3,48	4,94	15,78	3,19
	21°C	1,93	15,11	7,84	2,40	15,11	6,28	2,74	14,96	5,47	3,39	14,94	4,40	3,91	15,04	3,85	4,42	15,41	3,48	4,94	15,78	3,19
	20°C	1,92	15,08	7,86	2,39	15,08	6,30	2,73	14,93	5,48	3,39	14,91	4,40	3,91	15,04	3,85	4,42	15,41	3,49	4,93	15,78	3,20
	19°C	1,91	15,05	7,88	2,38	15,05	6,31	2,71	14,90	5,49	3,39	14,88	4,39	3,90	15,04	3,86	4,42	15,41	3,49	4,93	15,78	3,20
	18°C	1,90	15,02	7,89	2,38	15,02	6,32	2,70	14,87	5,50	3,38	14,85	4,39	3,90	15,04	3,86	4,41	15,41	3,49	4,92	15,78	3,20
	17°C	1,90	14,99	7,91	2,37	14,99	6,33	2,69	14,84	5,51	3,38	14,82	4,38	3,89	15,04	3,86	4,41	15,41	3,50	4,92	15,78	3,21
	16°C	1,89	14,96	7,92	2,36	14,96	6,35	2,68	14,81	5,52	3,38	14,79	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
	15°C	1,88	14,93	7,94	2,35	14,93	6,36	2,67	14,79	5,53	3,37	14,76	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
	14°C	1,87	14,90	7,96	2,34	14,90	6,37	2,66	14,76	5,55	3,37	14,73	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
	13°C	1,87	14,87	7,97	2,33	14,87	6,38	2,65	14,73	5,56	3,37	14,70	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
	12°C	1,86	14,84	7,99	2,32	14,84	6,40	2,64	14,70	5,57	3,36	14,68	4,36	3,87	15,04	3,88	4,38	15,41	3,52	4,89	15,78	3,22
	11°C	1,96	14,78	7,54	2,39	14,78	6,19	2,70	14,67	5,43	3,36	14,68	4,37	3,87	15,04	3,89	4,38	15,41	3,52	4,89	15,78	3,23
	10°C	2,06	14,71	7,14	2,46	14,71	5,99	2,77	14,64	5,29	3,36	14,68	4,37	3,87	15,04	3,89	4,38	15,41	3,52	4,88	15,78	3,23
	9°C	2,16	14,65	6,78	2,53	14,65	5,80	2,83	14,61	5,16	3,35	14,68	4,38	3,86	15,04	3,89	4,37	15,41	3,53	4,88	15,78	3,23
	8°C	2,26	14,59	6,45	2,59	14,59	5,62	2,90	14,58	5,04	3,35	14,68	4,38	3,86	15,04	3,90	4,37	15,41	3,53	4,88	15,78	3,24
	7°C	2,36	14,53	6,15	2,66	14,53	5,45	2,93	14,53	4,96	3,35	14,68	4,38	3,86	15,04	3,90	4,36	15,41	3,53	4,87	15,78	3,24
	6°C	2,71	14,49	5,35	3,17	14,48	4,56	3,46	14,47	4,18	3,84	14,56	3,79	4,28	14,82	3,46	4,72	15,08	3,19	5,16	15,33	2,97
	5°C	2,98	14,47	4,86	3,57	14,44	4,05	3,87	14,42	3,73	4,23	14,47	3,42	4,62	14,63	3,17	5,00	14,79	2,96	5,39	14,96	2,77
	4°C	3,17	14,44	4,55	3,85	14,41	3,74	4,16	14,37	3,45	4,50	14,39	3,20	4,85	14,48	2,98	5,20	14,56	2,80	5,56	14,65	2,64
	3°C	3,29	14,42	4,39	4,02	14,38	3,58	4,34	14,34	3,30	4,67	14,33	3,07	5,00	14,36	2,87	5,32	14,38	2,70	5,65	14,41	2,55
	2°C	3,33	14,40	4,33	4,08	14,35	3,52	4,40	14,30	3,25	4,72	14,25	3,02	5,04	14,20	2,82	5,36	14,15	2,64	5,69	14,10	2,48
	1°C	3,32	14,19	4,27	4,07	14,15	3,48	4,39	14,09	3,21	4,72	14,02	2,97	5,04	13,96	2,77	5,36	13,97	2,60	5,68	13,87	2,44
0°C	3,31	13,99	4,23	4,05	13,96	3,45	4,37	13,88	3,17	4,70	13,80	2,93	5,03	13,72	2,73	5,37	13,79	2,57	5,67	13,63	2,41	
-1°C	3,28	13,78	4,20	4,01	13,76	3,43	4,34	13,67	3,15	4,68	13,57	2,90	5,01	13,48	2,69	5,37	13,60	2,53	5,64	13,40	2,37	
-2°C	3,24	13,58	4,18	3,95	13,56	3,43	4,30	13,46	3,13	4,64	13,35	2,87	4,99	13,23	2,65	5,38	13,42	2,50	5,61	13,17	2,35	
-3°C	3,20	13,37	4,18	3,88	13,37	3,45	4,24	13,24	3,13	4,60	13,12	2,85	4,96	12,99	2,62	5,39	13,24	2,46	5,57	12,93	2,32	
-4°C	3,14	13,17	4,19	3,79	13,17	3,47	4,17	13,03	3,13	4,55	12,89	2,84	4,93	12,75	2,59	5,40	13,06	2,42	5,52	12,70	2,30	
-5°C	3,08	12,96	4,21	3,69	12,97	3,52	4,08	12,82	3,14	4,48	12,67	2,82	4,89	12,51	2,56	5,41	12,87	2,38	5,46	12,47	2,28	
-6°C	3,00	12,76	4,25	3,57	12,77	3,58	3,99	12,61	3,16	4,41	12,44	2,82	4,84	12,27	2,54	5,42	12,69	2,34	5,39	12,23	2,27	
-7°C	2,91	12,55	4,31	3,43	12,58	3,67	3,88	12,40	3,20	4,33	12,21	2,82	4,79	12,03	2,51	5,44	12,51	2,30	5,31	12,00	2,26	
-8°C	3,08	12,49	4,06	3,56	12,48	3,51	3,99	12,33	3,09	4,43	12,16	2,74	4,87	11,99	2,46	5,44	12,26	2,25	5,49	11,87	2,16	
-9°C	3,24	12,43	3,84	3,68	12,38	3,36	4,11	12,27	2,99	4,53	12,10	2,67	4,96	11,94	2,41	5,44	12,00	2,20	5,68	11,73	2,07	
-10°C	3,40	12,37	3,64	3,81	12,28	3,22	4,22	12,20	2,89	4,63	12,05	2,60	5,04	11,90	2,36	5,45	11,75	2,16	5,86	11,60	1,98	
-11°C	3,41	11,64	3,41	3,78	11,55	3,06	4,15	11,47	2,76	4,51	11,33	2,51	4,87	11,19	2,30	5,23	11,03	2,11	5,58	10,74	1,92	
-12°C	3,42	10,91	3,19	3,75	10,82	2,89	4,08	10,74	2,63	4,39	10,61	2,42	4,69	10,49	2,23	5,00	10,30	2,06	5,31	9,88	1,86	
-13°C	3,43	10,18	2,97	3,72	10,10	2,72	4,01	10,01	2,50	4,27	9,90	2,32	4,52	9,78	2,16	4,78	9,58	2,00	5,04	9,03	1,79	
-14°C	3,43	9,45	2,75	3,69	9,37	2,54	3,94	9,28	2,36	4,14	9,18	2,21	4,35	9,08	2,09	4,56	8,86	1,94	4,76	8,17	1,72	
-15°C	3,44	8,72	2,53	3,65	8,64	2,36	3,87	8,55	2,2													

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
5,26	16,15	3,07	6,10	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	35°C
5,26	16,15	3,07	6,09	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	34°C
5,25	16,15	3,07	6,09	16,52	2,71	7,06	16,88	2,39	0,00	0,00	0,00	33°C
5,25	16,15	3,08	6,08	16,52	2,72	7,05	16,88	2,39	0,00	0,00	0,00	32°C
5,24	16,15	3,08	6,08	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	31°C
5,24	16,15	3,08	6,07	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	30°C
5,23	16,15	3,09	6,06	16,52	2,72	7,03	16,88	2,40	0,00	0,00	0,00	29°C
5,23	16,15	3,09	6,06	16,52	2,73	7,02	16,88	2,40	0,00	0,00	0,00	28°C
5,22	16,15	3,09	6,05	16,52	2,73	7,02	16,88	2,41	0,00	0,00	0,00	27°C
5,22	16,15	3,10	6,05	16,52	2,73	7,01	16,88	2,41	0,00	0,00	0,00	26°C
5,21	16,15	3,10	6,04	16,52	2,73	7,00	16,88	2,41	0,00	0,00	0,00	25°C
5,21	16,15	3,10	6,03	16,52	2,74	7,00	16,88	2,41	0,00	0,00	0,00	24°C
5,20	16,15	3,11	6,03	16,52	2,74	6,99	16,88	2,42	0,00	0,00	0,00	23°C
5,19	16,15	3,11	6,02	16,52	2,74	6,98	16,88	2,42	0,00	0,00	0,00	22°C
5,19	16,15	3,11	6,02	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	21°C
5,18	16,15	3,11	6,01	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	20°C
5,18	16,15	3,12	6,00	16,52	2,75	6,96	16,88	2,43	8,07	17,25	2,14	19°C
5,17	16,15	3,12	6,00	16,52	2,75	6,95	16,88	2,43	8,06	17,25	2,14	18°C
5,17	16,15	3,12	5,99	16,52	2,76	6,95	16,88	2,43	8,05	17,25	2,14	17°C
5,16	16,15	3,13	5,99	16,52	2,76	6,94	16,88	2,43	8,05	17,25	2,14	16°C
5,16	16,15	3,13	5,98	16,52	2,76	6,93	16,88	2,44	8,04	17,25	2,15	15°C
5,15	16,15	3,13	5,97	16,52	2,76	6,93	16,88	2,44	8,03	17,25	2,15	14°C
5,15	16,15	3,14	5,97	16,52	2,77	6,92	16,88	2,44	8,02	17,25	2,15	13°C
5,14	16,15	3,14	5,96	16,52	2,77	6,91	16,88	2,44	8,01	17,25	2,15	12°C
5,14	16,15	3,14	5,96	16,52	2,77	6,91	16,88	2,45	8,00	17,25	2,16	11°C
5,13	16,15	3,15	5,95	16,52	2,78	6,90	16,88	2,45	8,00	17,25	2,16	10°C
5,13	16,15	3,15	5,94	16,52	2,78	6,89	16,88	2,45	7,99	17,25	2,16	9°C
5,12	16,15	3,15	5,94	16,52	2,78	6,88	16,88	2,45	7,98	17,25	2,16	8°C
5,12	16,15	3,16	5,93	16,52	2,78	6,88	16,88	2,45	7,97	17,25	2,16	7°C
5,44	15,59	2,87	6,08	15,85	2,61	6,80	16,11	2,37	7,61	16,36	2,15	6°C
5,69	15,12	2,66	6,19	15,28	2,47	6,73	15,45	2,29	7,33	15,61	2,13	5°C
5,86	14,74	2,51	6,26	14,82	2,37	6,69	14,91	2,23	7,13	14,99	2,10	4°C
5,97	14,44	2,42	6,31	14,46	2,29	6,66	14,49	2,18	7,01	14,52	2,07	3°C
6,01	14,05	2,34	6,33	14,00	2,21	6,65	13,95	2,10	6,97	13,90	1,99	2°C
5,99	13,61	2,27	6,30	13,36	2,12	6,61	13,11	1,98	6,92	12,97	1,87	1°C
5,94	13,18	2,22	6,21	12,72	2,05	6,48	12,27	1,89	6,76	12,03	1,78	0°C
5,85	12,74	2,18	6,06	12,08	1,99	6,27	11,43	1,82	6,49	11,10	1,71	-1°C
5,73	12,31	2,15	5,85	11,44	1,96	5,97	10,58	1,77	6,11	10,17	1,66	-2°C
5,58	11,87	2,13	5,58	10,81	1,94	5,59	9,74	1,74	5,62	9,23	1,64	-3°C
5,39	11,43	2,12	5,25	10,17	1,93	5,12	8,90	1,74	5,03	8,30	1,65	-4°C
5,16	11,00	2,13	4,87	9,53	1,96	4,57	8,06	1,76	4,33	7,37	1,70	-5°C
4,90	10,56	2,15	4,42	8,89	2,01	3,93	7,22	1,83	3,52	6,43	1,83	-6°C
4,61	10,13	2,20	3,91	8,25	2,11	3,21	6,38	1,98	2,60	5,50	2,11	-7°C
5,05	10,11	2,00	4,60	8,35	1,82	4,15	6,59	1,59	3,86	5,98	1,55	-8°C
5,48	10,09	1,84	5,28	8,45	1,60	5,09	6,81	1,34	5,12	6,45	1,26	-9°C
5,91	10,07	1,70	5,97	8,55	1,43	6,02	7,02	1,17	6,37	6,93	1,09	-10°C
5,63	9,36	1,66	5,68	7,97	1,40	5,73	6,59	1,15	0,00	0,00	0,00	-11°C
5,35	8,64	1,61	5,39	7,39	1,37	5,44	6,15	1,13	0,00	0,00	0,00	-12°C
5,07	7,92	1,56	5,11	6,82	1,34	5,14	5,71	1,11	0,00	0,00	0,00	-13°C
4,79	7,20	1,50	4,82	6,24	1,29	4,85	5,27	1,09	0,00	0,00	0,00	-14°C
4,51	6,49	1,44	4,53	5,66	1,25	4,55	4,84	1,06	0,00	0,00	0,00	-15°C
4,52	6,39	1,41	4,54	5,55	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
4,54	6,30	1,39	4,55	5,43	1,19	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
4,55	6,21	1,36	4,56	5,32	1,17	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
4,57	6,11	1,34	4,57	5,21	1,14	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
4,58	6,02	1,31	4,57	5,09	1,11	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
4,59	5,93	1,29	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
4,61	5,83	1,27	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
4,62	5,74	1,24	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
4,64	5,65	1,22	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
4,65	5,55	1,19	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 3

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	0.67	5.57	8.37	0.82	5.55	6.79	0.92	5.43	5.87	1.07	5.39	5.02	1.24	5.38	4.35	1.40	5.37	3.84	1.56	5.35	3.43
34°C	0.66	5.56	8.38	0.81	5.54	6.81	0.92	5.42	5.88	1.07	5.38	5.01	1.24	5.37	4.35	1.40	5.36	3.83	1.56	5.34	3.43
33°C	0.66	5.55	8.40	0.81	5.53	6.82	0.92	5.41	5.89	1.07	5.37	5.01	1.23	5.36	4.34	1.40	5.35	3.83	1.56	5.33	3.43
32°C	0.66	5.54	8.42	0.81	5.52	6.83	0.91	5.40	5.90	1.07	5.36	5.00	1.23	5.35	4.34	1.39	5.33	3.83	1.56	5.32	3.42
31°C	0.65	5.52	8.43	0.80	5.51	6.85	0.91	5.38	5.92	1.07	5.35	5.00	1.23	5.34	4.33	1.39	5.32	3.82	1.55	5.31	3.42
30°C	0.65	5.51	8.45	0.80	5.50	6.86	0.91	5.37	5.93	1.07	5.34	4.99	1.23	5.33	4.33	1.39	5.31	3.82	1.55	5.30	3.42
29°C	0.65	5.50	8.47	0.80	5.49	6.87	0.90	5.36	5.94	1.07	5.33	4.99	1.23	5.32	4.32	1.39	5.30	3.82	1.55	5.29	3.41
28°C	0.65	5.49	8.49	0.80	5.48	6.89	0.90	5.35	5.95	1.07	5.32	4.98	1.23	5.30	4.32	1.39	5.29	3.81	1.55	5.28	3.41
27°C	0.64	5.48	8.50	0.79	5.47	6.90	0.90	5.34	5.96	1.07	5.31	4.98	1.23	5.29	4.32	1.39	5.28	3.81	1.55	5.27	3.40
26°C	0.64	5.47	8.52	0.79	5.46	6.92	0.89	5.33	5.98	1.07	5.30	4.97	1.23	5.28	4.31	1.39	5.27	3.80	1.55	5.26	3.40
25°C	0.64	5.46	8.54	0.79	5.45	6.93	0.89	5.32	5.99	1.06	5.29	4.97	1.22	5.27	4.31	1.38	5.26	3.80	1.54	5.25	3.40
24°C	0.64	5.45	8.55	0.78	5.43	6.94	0.89	5.31	6.00	1.06	5.27	4.96	1.22	5.26	4.30	1.38	5.25	3.80	1.54	5.24	3.39
23°C	0.63	5.44	8.57	0.78	5.42	6.96	0.88	5.30	6.01	1.06	5.26	4.96	1.22	5.25	4.30	1.38	5.24	3.79	1.54	5.23	3.39
22°C	0.63	5.43	8.59	0.78	5.41	6.97	0.88	5.29	6.02	1.06	5.25	4.95	1.22	5.24	4.29	1.38	5.23	3.79	1.54	5.22	3.39
21°C	0.63	5.42	8.60	0.77	5.40	6.98	0.87	5.28	6.04	1.06	5.24	4.95	1.22	5.23	4.29	1.38	5.22	3.78	1.54	5.21	3.38
20°C	0.63	5.40	8.62	0.77	5.39	7.00	0.87	5.27	6.05	1.06	5.23	4.94	1.22	5.22	4.29	1.38	5.21	3.78	1.54	5.19	3.38
19°C	0.62	5.39	8.64	0.77	5.38	7.01	0.87	5.26	6.06	1.06	5.22	4.94	1.22	5.21	4.28	1.38	5.20	3.78	1.54	5.18	3.38
18°C	0.62	5.38	8.66	0.76	5.37	7.03	0.86	5.25	6.07	1.06	5.21	4.93	1.22	5.20	4.28	1.37	5.19	3.77	1.53	5.17	3.37
17°C	0.62	5.37	8.67	0.76	5.36	7.04	0.86	5.24	6.08	1.06	5.20	4.93	1.21	5.19	4.27	1.37	5.18	3.77	1.53	5.16	3.37
16°C	0.62	5.36	8.69	0.76	5.35	7.05	0.86	5.23	6.10	1.05	5.19	4.92	1.21	5.18	4.27	1.37	5.17	3.77	1.53	5.15	3.37
15°C	0.61	5.35	8.71	0.76	5.34	7.07	0.85	5.22	6.11	1.05	5.18	4.92	1.21	5.17	4.26	1.37	5.16	3.76	1.53	5.14	3.36
14°C	0.61	5.34	8.73	0.75	5.33	7.08	0.85	5.20	6.12	1.05	5.17	4.91	1.21	5.16	4.26	1.37	5.14	3.76	1.53	5.13	3.36
13°C	0.61	5.33	8.74	0.75	5.32	7.10	0.85	5.19	6.13	1.05	5.16	4.91	1.21	5.15	4.26	1.37	5.13	3.75	1.53	5.12	3.36
12°C	0.61	5.32	8.76	0.75	5.31	7.11	0.84	5.18	6.14	1.05	5.15	4.90	1.21	5.14	4.25	1.37	5.12	3.75	1.52	5.11	3.35
11°C	0.65	5.27	8.05	0.78	5.26	6.77	0.86	5.16	5.98	1.05	5.13	4.88	1.21	5.11	4.24	1.36	5.10	3.74	1.52	5.09	3.34
10°C	0.70	5.22	7.43	0.81	5.20	6.45	0.88	5.14	5.82	1.05	5.10	4.87	1.21	5.09	4.22	1.36	5.08	3.72	1.52	5.06	3.33
9°C	0.75	5.17	6.90	0.84	5.15	6.16	0.90	5.11	5.66	1.05	5.08	4.85	1.20	5.06	4.20	1.36	5.05	3.71	1.52	5.04	3.32
8°C	0.80	5.12	6.42	0.87	5.10	5.89	0.92	5.09	5.52	1.05	5.05	4.83	1.20	5.04	4.19	1.36	5.03	3.69	1.52	5.01	3.30
7°C	0.84	5.07	6.00	0.90	5.05	5.63	0.93	5.04	5.41	1.05	5.03	4.81	1.20	5.02	4.17	1.36	5.00	3.68	1.52	4.99	3.29
6°C	0.91	4.95	5.45	0.97	4.92	5.09	1.03	4.89	4.77	1.14	4.86	4.28	1.27	4.83	3.80	1.41	4.80	3.41	1.55	4.77	3.08
5°C	0.96	4.86	5.06	1.02	4.81	4.71	1.10	4.77	4.33	1.21	4.72	3.92	1.33	4.67	3.52	1.45	4.63	3.20	1.57	4.58	2.92
4°C	1.00	4.78	4.80	1.06	4.72	4.45	1.15	4.66	4.05	1.26	4.61	3.67	1.37	4.55	3.33	1.48	4.49	3.04	1.59	4.43	2.79
3°C	1.02	4.72	4.64	1.09	4.65	4.28	1.18	4.58	3.87	1.29	4.52	3.51	1.39	4.45	3.20	1.49	4.38	2.93	1.60	4.31	2.70
2°C	1.02	4.64	4.53	1.09	4.56	4.17	1.19	4.48	3.75	1.30	4.40	3.40	1.40	4.32	3.09	1.50	4.24	2.83	1.60	4.16	2.60
1°C	1.03	4.67	4.55	1.10	4.58	4.18	1.20	4.46	3.73	1.30	4.38	3.37	1.40	4.30	3.07	1.50	4.21	2.80	1.60	4.11	2.57
0°C	1.03	4.70	4.56	1.10	4.60	4.17	1.20	4.43	3.70	1.30	4.35	3.35	1.40	4.28	3.05	1.51	4.18	2.77	1.61	4.06	2.53
-1°C	1.04	4.73	4.56	1.11	4.62	4.15	1.20	4.41	3.67	1.31	4.33	3.32	1.41	4.26	3.01	1.53	4.16	2.72	1.62	4.01	2.48
-2°C	1.05	4.76	4.54	1.13	4.64	4.11	1.20	4.38	3.64	1.31	4.31	3.28	1.42	4.24	2.97	1.55	4.13	2.67	1.63	3.96	2.43
-3°C	1.06	4.80	4.51	1.15	4.66	4.05	1.21	4.36	3.61	1.32	4.29	3.24	1.44	4.22	2.93	1.58	4.10	2.60	1.64	3.90	2.38
-4°C	1.08	4.83	4.47	1.17	4.68	3.98	1.21	4.33	3.57	1.34	4.26	3.19	1.46	4.19	2.88	1.61	4.07	2.53	1.66	3.85	2.32
-5°C	1.10	4.86	4.42	1.20	4.70	3.90	1.22	4.31	3.53	1.35	4.24	3.14	1.48	4.17	2.82	1.65	4.04	2.45	1.68	3.80	2.26
-6°C	1.12	4.89	4.35	1.24	4.72	3.81	1.23	4.28	3.49	1.37	4.22	3.09	1.51	4.15	2.76	1.70	4.02	2.37	1.71	3.75	2.20
-7°C	1.15	4.92	4.28	1.28	4.74	3.71	1.23	4.26	3.45	1.39	4.20	3.03	1.54	4.13	2.69	1.75	3.99	2.28	1.74	3.70	2.13
-8°C	1.16	4.83	4.16	1.28	4.63	3.61	1.29	4.23	3.28	1.43	4.14	2.90	1.56	4.05	2.59	1.74	3.91	2.24	1.77	3.67	2.07
-9°C	1.18	4.75	4.03	1.29	4.52	3.51	1.35	4.20	3.12	1.47	4.08	2.78	1.59	3.97	2.50	1.73	3.82	2.21	1.80	3.63	2.02
-10°C	1.19	4.66	3.92	1.30	4.41	3.40	1.40	4.17	2.97	1.51	4.02	2.67	1.61	3.88	2.40	1.72	3.74	2.17	1.83	3.60	1.97
-11°C	1.19	4.48	3.76	1.29	4.27	3.30	1.40	4.05	2.90	1.50	3.93	2.62	1.60	3.80	2.37	1.70	3.66	2.15	1.80	3.47	1.93
-12°C	1.19	4.30	3.61	1.29	4.12	3.19	1.40	3.94	2.82	1.49	3.83	2.57	1.59	3.71	2.34	1.68	3.58	2.13	1.78	3.35	1.89
-13°C	1.19	4.12	3.46	1.29	3.98	3.08	1.39	3.83	2.75	1.48	3.73	2.52	1.57	3.63	2.31	1.66	3.49	2.10	1.75	3.22	1.84
-14°C	1.19	3.94	3.31	1.29	3.83	2.97	1.39	3.72	2.67	1.47	3.63	2.46	1.56	3.54	2.28	1.64	3.41	2.08	1.72	3.09	1.80
-15°C	1.19	3.76	3.16	1.29	3.69	2.86	1.39	3.61	2.60	1.49	3.54	2.38	1.59	3.46	2.18	1.67	3.33	1.99	1.70	2.97	1.75
-16°C	1.16	3.64	3.12	1.26	3.57	2.82	1.36	3.50	2.56	1.45	3.42	2.37	1.53	3.35	2.20	1.61	3.23	2.01	1.69	2.92	1.73

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,64	5,34	3,26	1,90	5,33	2,80	2,20	5,32	2,41	0,00	0,00	0,00	35°C
1,64	5,33	3,26	1,90	5,32	2,80	2,20	5,31	2,41	0,00	0,00	0,00	34°C
1,64	5,32	3,25	1,90	5,31	2,80	2,20	5,29	2,41	0,00	0,00	0,00	33°C
1,63	5,31	3,25	1,89	5,30	2,80	2,20	5,28	2,41	0,00	0,00	0,00	32°C
1,63	5,30	3,25	1,89	5,29	2,79	2,19	5,27	2,40	0,00	0,00	0,00	31°C
1,63	5,29	3,24	1,89	5,28	2,79	2,19	5,26	2,40	0,00	0,00	0,00	30°C
1,63	5,28	3,24	1,89	5,26	2,79	2,19	5,25	2,40	0,00	0,00	0,00	29°C
1,63	5,27	3,24	1,89	5,25	2,78	2,19	5,24	2,40	0,00	0,00	0,00	28°C
1,63	5,26	3,23	1,88	5,24	2,78	2,19	5,23	2,39	0,00	0,00	0,00	27°C
1,62	5,25	3,23	1,88	5,23	2,78	2,18	5,22	2,39	0,00	0,00	0,00	26°C
1,62	5,23	3,23	1,88	5,22	2,78	2,18	5,21	2,39	0,00	0,00	0,00	25°C
1,62	5,22	3,22	1,88	5,21	2,77	2,18	5,20	2,39	0,00	0,00	0,00	24°C
1,62	5,21	3,22	1,88	5,20	2,77	2,18	5,19	2,38	0,00	0,00	0,00	23°C
1,62	5,20	3,22	1,88	5,19	2,77	2,17	5,18	2,38	0,00	0,00	0,00	22°C
1,62	5,19	3,21	1,87	5,18	2,76	2,17	5,17	2,38	0,00	0,00	0,00	21°C
1,61	5,18	3,21	1,87	5,17	2,76	2,17	5,16	2,38	0,00	0,00	0,00	20°C
1,61	5,17	3,21	1,87	5,16	2,76	2,17	5,15	2,37	2,51	5,13	2,04	19°C
1,61	5,16	3,20	1,87	5,15	2,76	2,17	5,14	2,37	2,51	5,12	2,04	18°C
1,61	5,15	3,20	1,87	5,14	2,75	2,16	5,13	2,37	2,51	5,11	2,04	17°C
1,61	5,14	3,20	1,86	5,13	2,75	2,16	5,12	2,37	2,51	5,10	2,04	16°C
1,61	5,13	3,19	1,86	5,12	2,75	2,16	5,10	2,36	2,50	5,09	2,03	15°C
1,60	5,12	3,19	1,86	5,11	2,74	2,16	5,09	2,36	2,50	5,08	2,03	14°C
1,60	5,11	3,19	1,86	5,10	2,74	2,15	5,08	2,36	2,50	5,07	2,03	13°C
1,60	5,10	3,18	1,86	5,09	2,74	2,15	5,07	2,36	2,50	5,06	2,03	12°C
1,60	5,07	3,17	1,85	5,06	2,73	2,15	5,05	2,35	2,49	5,04	2,02	11°C
1,60	5,05	3,16	1,85	5,04	2,72	2,15	5,03	2,34	2,49	5,01	2,01	10°C
1,60	5,03	3,15	1,85	5,01	2,71	2,15	5,00	2,33	2,49	4,99	2,00	9°C
1,60	5,00	3,14	1,85	4,99	2,70	2,14	4,98	2,32	2,49	4,96	2,00	8°C
1,59	4,98	3,12	1,85	4,96	2,69	2,14	4,95	2,31	2,48	4,94	1,99	7°C
1,63	4,74	2,90	1,83	4,71	2,57	2,06	4,68	2,28	2,31	4,65	2,01	6°C
1,66	4,54	2,73	1,82	4,49	2,47	1,99	4,45	2,23	2,18	4,40	2,02	5°C
1,68	4,37	2,60	1,81	4,31	2,38	1,94	4,26	2,19	2,08	4,20	2,02	4°C
1,70	4,24	2,50	1,80	4,18	2,31	1,91	4,11	2,15	2,02	4,04	2,00	3°C
1,70	4,08	2,40	1,80	4,00	2,22	1,90	3,92	2,06	2,01	3,84	1,91	2°C
1,70	4,01	2,36	1,80	3,91	2,18	1,90	3,81	2,01	1,99	3,73	1,87	1°C
1,69	3,94	2,33	1,78	3,82	2,15	1,87	3,71	1,98	1,96	3,61	1,85	0°C
1,68	3,87	2,30	1,75	3,74	2,13	1,82	3,60	1,97	1,90	3,50	1,85	-1°C
1,67	3,80	2,27	1,72	3,65	2,13	1,76	3,49	1,98	1,81	3,38	1,87	-2°C
1,65	3,73	2,26	1,67	3,56	2,13	1,68	3,39	2,02	1,70	3,27	1,92	-3°C
1,63	3,66	2,24	1,61	3,47	2,16	1,58	3,28	2,07	1,57	3,16	2,01	-4°C
1,61	3,59	2,23	1,54	3,38	2,20	1,46	3,17	2,17	1,41	3,04	2,16	-5°C
1,58	3,52	2,23	1,46	3,29	2,26	1,33	3,07	2,30	1,23	2,93	2,39	-6°C
1,55	3,45	2,23	1,36	3,21	2,35	1,18	2,96	2,51	1,02	2,81	2,76	-7°C
1,64	3,32	2,02	1,52	2,98	1,96	1,39	2,64	1,89	1,32	2,51	1,91	-8°C
1,73	3,20	1,84	1,67	2,76	1,65	1,61	2,32	1,44	1,62	2,21	1,37	-9°C
1,83	3,07	1,68	1,83	2,53	1,39	1,82	2,00	1,10	1,91	1,91	1,00	-10°C
1,81	2,97	1,65	1,81	2,48	1,37	1,81	1,98	1,09	0,00	0,00	0,00	-11°C
1,78	2,88	1,62	1,79	2,42	1,35	1,80	1,95	1,08	0,00	0,00	0,00	-12°C
1,76	2,79	1,58	1,78	2,36	1,33	1,79	1,93	1,08	0,00	0,00	0,00	-13°C
1,74	2,70	1,55	1,76	2,30	1,31	1,78	1,91	1,07	0,00	0,00	0,00	-14°C
1,72	2,60	1,51	1,75	2,24	1,28	1,77	1,88	1,06	0,00	0,00	0,00	-15°C
1,71	2,56	1,49	1,73	2,19	1,26	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
1,70	2,51	1,47	1,72	2,14	1,24	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
1,69	2,46	1,46	1,71	2,09	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
1,68	2,41	1,44	1,69	2,04	1,20	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
1,67	2,36	1,42	1,68	1,98	1,18	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
1,65	2,31	1,39	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
1,64	2,26	1,37	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
1,63	2,21	1,35	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
1,62	2,16	1,33	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
1,61	2,11	1,31	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 4

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	0.82	6.52	7.95	1.00	6.50	6.47	1.13	6.33	5.59	1.32	6.27	4.73	1.52	6.24	4.12	1.71	6.22	3.64	1.90	6.20	3.26
34°C	0.82	6.51	7.96	1.00	6.49	6.49	1.13	6.32	5.60	1.32	6.26	4.73	1.51	6.23	4.11	1.71	6.21	3.64	1.90	6.19	3.26
33°C	0.81	6.49	7.98	1.00	6.48	6.50	1.13	6.31	5.61	1.32	6.24	4.72	1.51	6.22	4.11	1.71	6.19	3.63	1.90	6.18	3.26
32°C	0.81	6.48	8.00	0.99	6.46	6.51	1.12	6.30	5.62	1.32	6.23	4.72	1.51	6.20	4.10	1.70	6.18	3.63	1.89	6.16	3.25
31°C	0.81	6.47	8.01	0.99	6.45	6.53	1.12	6.28	5.63	1.32	6.22	4.72	1.51	6.19	4.10	1.70	6.17	3.63	1.89	6.15	3.25
30°C	0.80	6.45	8.03	0.98	6.44	6.54	1.11	6.27	5.64	1.32	6.21	4.71	1.51	6.18	4.09	1.70	6.16	3.62	1.89	6.14	3.25
29°C	0.80	6.44	8.04	0.98	6.43	6.55	1.11	6.26	5.65	1.32	6.19	4.71	1.51	6.17	4.09	1.70	6.14	3.62	1.89	6.13	3.24
28°C	0.80	6.43	8.06	0.98	6.41	6.57	1.10	6.25	5.66	1.31	6.18	4.70	1.51	6.15	4.09	1.70	6.13	3.61	1.89	6.11	3.24
27°C	0.79	6.42	8.08	0.97	6.40	6.58	1.10	6.23	5.67	1.31	6.17	4.70	1.50	6.14	4.08	1.69	6.12	3.61	1.89	6.10	3.24
26°C	0.79	6.40	8.09	0.97	6.39	6.59	1.09	6.22	5.69	1.31	6.16	4.69	1.50	6.13	4.08	1.69	6.11	3.61	1.88	6.09	3.23
25°C	0.79	6.39	8.11	0.97	6.37	6.61	1.09	6.21	5.70	1.31	6.14	4.69	1.50	6.12	4.07	1.69	6.09	3.60	1.88	6.08	3.23
24°C	0.79	6.38	8.12	0.96	6.36	6.62	1.09	6.20	5.71	1.31	6.13	4.68	1.50	6.10	4.07	1.69	6.08	3.60	1.88	6.07	3.23
23°C	0.78	6.37	8.14	0.96	6.35	6.63	1.08	6.18	5.72	1.31	6.12	4.68	1.50	6.09	4.07	1.69	6.07	3.60	1.88	6.05	3.22
22°C	0.78	6.35	8.16	0.95	6.34	6.65	1.08	6.17	5.73	1.31	6.11	4.67	1.50	6.08	4.06	1.69	6.06	3.59	1.88	6.04	3.22
21°C	0.78	6.34	8.17	0.95	6.32	6.66	1.07	6.16	5.74	1.31	6.10	4.67	1.50	6.07	4.06	1.68	6.05	3.59	1.87	6.03	3.22
20°C	0.77	6.33	8.19	0.95	6.31	6.67	1.07	6.15	5.75	1.30	6.08	4.66	1.49	6.05	4.05	1.68	6.03	3.58	1.87	6.02	3.21
19°C	0.77	6.31	8.21	0.94	6.30	6.68	1.06	6.13	5.77	1.30	6.07	4.66	1.49	6.04	4.05	1.68	6.02	3.58	1.87	6.00	3.21
18°C	0.77	6.30	8.22	0.94	6.29	6.70	1.06	6.12	5.78	1.30	6.06	4.65	1.49	6.03	4.05	1.68	6.01	3.58	1.87	5.99	3.21
17°C	0.76	6.29	8.24	0.93	6.27	6.71	1.06	6.11	5.79	1.30	6.05	4.65	1.49	6.02	4.04	1.68	6.00	3.57	1.87	5.98	3.20
16°C	0.76	6.28	8.25	0.93	6.26	6.73	1.05	6.10	5.80	1.30	6.03	4.64	1.49	6.01	4.04	1.68	5.98	3.57	1.86	5.97	3.20
15°C	0.76	6.26	8.27	0.93	6.25	6.74	1.05	6.09	5.81	1.30	6.02	4.64	1.49	5.99	4.03	1.67	5.97	3.57	1.86	5.96	3.20
14°C	0.75	6.25	8.29	0.92	6.24	6.75	1.04	6.07	5.82	1.30	6.01	4.64	1.48	5.98	4.03	1.67	5.96	3.56	1.86	5.94	3.19
13°C	0.75	6.24	8.30	0.92	6.22	6.77	1.04	6.06	5.84	1.30	6.00	4.63	1.48	5.97	4.02	1.67	5.95	3.56	1.86	5.93	3.19
12°C	0.75	6.23	8.32	0.92	6.21	6.78	1.03	6.05	5.85	1.29	5.99	4.63	1.48	5.96	4.02	1.67	5.94	3.56	1.86	5.92	3.19
11°C	0.79	6.17	7.77	0.95	6.15	6.50	1.06	6.02	5.69	1.29	5.95	4.61	1.48	5.93	4.00	1.67	5.90	3.54	1.86	5.89	3.17
10°C	0.84	6.11	7.28	0.98	6.09	6.23	1.08	5.98	5.53	1.29	5.92	4.59	1.48	5.89	3.98	1.67	5.87	3.52	1.85	5.85	3.16
9°C	0.89	6.06	6.84	1.01	6.03	5.98	1.11	5.95	5.38	1.29	5.89	4.56	1.48	5.86	3.97	1.66	5.84	3.51	1.85	5.84	3.15
8°C	0.93	6.00	6.44	1.04	5.96	5.75	1.13	5.92	5.24	1.29	5.86	4.54	1.48	5.84	3.96	1.66	5.84	3.51	1.85	5.84	3.16
7°C	0.98	5.94	6.08	1.07	5.90	5.53	1.14	5.86	5.14	1.29	5.84	4.53	1.47	5.84	3.96	1.66	5.84	3.52	1.85	5.84	3.16
6°C	1.08	5.90	5.46	1.18	5.85	4.98	1.27	5.79	4.57	1.41	5.75	4.09	1.57	5.72	3.64	1.74	5.70	3.28	1.90	5.67	2.98
5°C	1.16	5.87	5.04	1.26	5.80	4.61	1.37	5.73	4.20	1.50	5.67	3.78	1.65	5.62	3.41	1.80	5.58	3.10	1.95	5.53	2.84
4°C	1.22	5.85	4.78	1.32	5.77	4.37	1.44	5.69	3.96	1.57	5.61	3.58	1.70	5.54	3.25	1.84	5.48	2.98	1.98	5.41	2.74
3°C	1.26	5.83	4.63	1.35	5.74	4.23	1.48	5.65	3.82	1.61	5.56	3.46	1.74	5.48	3.16	1.86	5.40	2.90	1.99	5.32	2.67
2°C	1.27	5.80	4.57	1.37	5.70	4.17	1.49	5.60	3.75	1.62	5.50	3.40	1.75	5.40	3.09	1.87	5.30	2.83	2.00	5.20	2.60
1°C	1.27	5.83	4.58	1.37	5.70	4.16	1.50	5.57	3.72	1.62	5.47	3.38	1.75	5.37	3.08	1.87	5.20	2.78	2.00	5.11	2.55
0°C	1.28	5.86	4.57	1.38	5.70	4.14	1.50	5.54	3.69	1.62	5.44	3.35	1.75	5.35	3.06	1.87	5.10	2.73	2.01	5.02	2.50
-1°C	1.30	5.88	4.53	1.39	5.70	4.10	1.51	5.51	3.65	1.63	5.41	3.33	1.74	5.32	3.05	1.86	5.00	2.68	2.02	4.93	2.44
-2°C	1.32	5.91	4.48	1.41	5.70	4.04	1.52	5.48	3.59	1.63	5.38	3.30	1.74	5.29	3.04	1.86	4.90	2.64	2.04	4.84	2.38
-3°C	1.35	5.94	4.40	1.43	5.69	3.97	1.54	5.44	3.53	1.64	5.36	3.26	1.74	5.27	3.03	1.85	4.80	2.60	2.06	4.76	2.31
-4°C	1.39	5.97	4.31	1.46	5.69	3.89	1.56	5.41	3.47	1.65	5.33	3.23	1.74	5.24	3.02	1.83	4.70	2.56	2.08	4.67	2.24
-5°C	1.43	5.99	4.20	1.50	5.69	3.80	1.59	5.38	3.39	1.66	5.30	3.19	1.73	5.21	3.01	1.82	4.60	2.53	2.11	4.58	2.17
-6°C	1.47	6.02	4.08	1.54	5.69	3.71	1.61	5.35	3.31	1.67	5.27	3.15	1.73	5.19	3.00	1.80	4.50	2.50	2.15	4.49	2.09
-7°C	1.53	6.05	3.96	1.58	5.69	3.60	1.65	5.32	3.23	1.69	5.24	3.11	1.73	5.16	2.99	1.78	4.40	2.47	2.19	4.40	2.01
-8°C	1.54	5.93	3.85	1.59	5.56	3.50	1.65	5.18	3.14	1.69	5.02	2.97	1.73	4.86	2.81	1.78	4.24	2.38	2.07	4.13	2.00
-9°C	1.55	5.81	3.75	1.60	5.43	3.40	1.65	5.04	3.06	1.69	4.80	2.84	1.73	4.55	2.63	1.78	4.08	2.29	1.95	3.87	1.98
-10°C	1.56	5.70	3.65	1.61	5.30	3.30	1.65	4.90	2.97	1.69	4.58	2.70	1.74	4.25	2.44	1.78	3.93	2.20	1.83	3.60	1.97
-11°C	1.53	5.44	3.56	1.59	5.11	3.22	1.65	4.77	2.90	1.70	4.49	2.64	1.75	4.21	2.40	1.81	3.92	2.17	1.86	3.58	1.92
-12°C	1.50	5.19	3.47	1.57	4.91	3.13	1.64	4.64	2.82	1.71	4.41	2.58	1.77	4.18	2.36	1.83	3.92	2.14	1.89	3.56	1.88
-13°C	1.46	4.93	3.37	1.55	4.72	3.04	1.64	4.51	2.75	1.71	4.33	2.53	1.78	4.14	2.32	1.86	3.92	2.11	1.93	3.53	1.83
-14°C	1.43	4.68	3.27	1.53	4.53	2.95	1.64	4.38	2.67	1.72	4.24	2.47	1.80	4.11	2.28	1.88	3.92	2.08	1.96	3.51	1.79
-15°C	1.40	4.42	3.16	1.52	4.34	2.86	1.63	4.25	2.60	1.75	4.16	2.38	1.87	4.07	2.18	1.97	3.91	1.99	2.00	3.49	1.75
-16°C	1.37	4.28	3.12	1.49	4.19	2.82	1.61	4.11	2.56	1.70	4.03	2.37	1.80	3.95	2.20	1.89	3.81	2.01	1.99	3.43	1.73
-17°C	1.34																				

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,00	6,19	3,10	2,32	6,18	2,67	2,68	6,17	2,30	0,00	0,00	0,00	35°C
2,00	6,18	3,10	2,31	6,16	2,66	2,68	6,15	2,29	0,00	0,00	0,00	34°C
1,99	6,16	3,09	2,31	6,15	2,66	2,68	6,14	2,29	0,00	0,00	0,00	33°C
1,99	6,15	3,09	2,31	6,14	2,66	2,68	6,13	2,29	0,00	0,00	0,00	32°C
1,99	6,14	3,09	2,31	6,13	2,66	2,67	6,12	2,29	0,00	0,00	0,00	31°C
1,99	6,13	3,08	2,30	6,11	2,65	2,67	6,10	2,29	0,00	0,00	0,00	30°C
1,99	6,11	3,08	2,30	6,10	2,65	2,67	6,09	2,28	0,00	0,00	0,00	29°C
1,98	6,10	3,08	2,30	6,09	2,65	2,67	6,08	2,28	0,00	0,00	0,00	28°C
1,98	6,09	3,07	2,30	6,08	2,65	2,66	6,07	2,28	0,00	0,00	0,00	27°C
1,98	6,08	3,07	2,29	6,06	2,64	2,66	6,05	2,28	0,00	0,00	0,00	26°C
1,98	6,06	3,07	2,29	6,05	2,64	2,66	6,04	2,27	0,00	0,00	0,00	25°C
1,98	6,05	3,06	2,29	6,04	2,64	2,65	6,03	2,27	0,00	0,00	0,00	24°C
1,97	6,04	3,06	2,29	6,03	2,63	2,65	6,02	2,27	0,00	0,00	0,00	23°C
1,97	6,03	3,06	2,29	6,01	2,63	2,65	6,00	2,27	0,00	0,00	0,00	22°C
1,97	6,01	3,05	2,28	6,00	2,63	2,65	5,99	2,26	0,00	0,00	0,00	21°C
1,97	6,00	3,05	2,28	5,99	2,63	2,64	5,98	2,26	0,00	0,00	0,00	20°C
1,97	5,99	3,05	2,28	5,98	2,62	2,64	5,97	2,26	3,06	5,96	1,95	19°C
1,96	5,98	3,04	2,28	5,97	2,62	2,64	5,95	2,26	3,06	5,95	1,94	18°C
1,96	5,97	3,04	2,27	5,95	2,62	2,64	5,94	2,25	3,06	5,93	1,94	17°C
1,96	5,95	3,04	2,27	5,94	2,62	2,63	5,93	2,25	3,05	5,92	1,94	16°C
1,96	5,94	3,04	2,27	5,93	2,61	2,63	5,92	2,25	3,05	5,91	1,94	15°C
1,96	5,93	3,03	2,27	5,92	2,61	2,63	5,91	2,25	3,05	5,90	1,94	14°C
1,95	5,92	3,03	2,26	5,90	2,61	2,63	5,89	2,25	3,04	5,88	1,93	13°C
1,95	5,91	3,03	2,26	5,89	2,60	2,62	5,88	2,24	3,04	5,87	1,93	12°C
1,95	5,87	3,01	2,26	5,86	2,59	2,62	5,85	2,23	3,04	5,84	1,92	11°C
1,95	5,84	3,00	2,26	5,84	2,59	2,62	5,84	2,23	3,03	5,84	1,92	10°C
1,95	5,84	3,00	2,26	5,84	2,59	2,61	5,84	2,23	3,03	5,84	1,93	9°C
1,94	5,84	3,00	2,25	5,84	2,59	2,61	5,84	2,24	3,03	5,84	1,93	8°C
1,94	5,84	3,01	2,25	5,84	2,59	2,61	5,84	2,24	3,03	5,84	1,93	7°C
2,01	5,64	2,81	2,25	5,62	2,49	2,53	5,59	2,21	2,84	5,56	1,96	6°C
2,06	5,48	2,66	2,25	5,43	2,41	2,46	5,38	2,18	2,69	5,33	1,98	5°C
2,10	5,34	2,55	2,25	5,27	2,34	2,42	5,21	2,15	2,59	5,14	1,98	4°C
2,12	5,24	2,47	2,25	5,15	2,29	2,39	5,07	2,12	2,53	4,99	1,97	3°C
2,13	5,10	2,40	2,25	5,00	2,22	2,38	4,90	2,06	2,51	4,80	1,91	2°C
2,13	5,02	2,35	2,27	4,94	2,18	2,40	4,85	2,02	2,53	4,80	1,90	1°C
2,16	4,95	2,29	2,31	4,87	2,11	2,45	4,79	1,95	2,61	4,80	1,84	0°C
2,20	4,87	2,22	2,37	4,81	2,03	2,55	4,74	1,86	2,73	4,80	1,76	-1°C
2,25	4,79	2,13	2,47	4,74	1,92	2,68	4,69	1,75	2,90	4,80	1,65	-2°C
2,32	4,72	2,03	2,59	4,68	1,81	2,85	4,64	1,63	3,12	4,80	1,54	-3°C
2,41	4,64	1,93	2,73	4,61	1,69	3,05	4,58	1,50	3,39	4,80	1,41	-4°C
2,51	4,56	1,82	2,90	4,55	1,57	3,30	4,53	1,37	3,72	4,80	1,29	-5°C
2,63	4,49	1,71	3,10	4,48	1,44	3,58	4,48	1,25	4,09	4,80	1,17	-6°C
2,76	4,41	1,60	3,33	4,42	1,33	3,90	4,43	1,14	4,50	4,80	1,07	-7°C
2,43	3,92	1,61	2,79	3,71	1,33	3,15	3,50	1,11	3,57	3,68	1,03	-8°C
2,10	3,44	1,63	2,26	3,01	1,33	2,41	2,58	1,07	2,64	2,57	0,97	-9°C
1,77	2,95	1,66	1,72	2,30	1,34	1,67	1,65	0,99	1,70	1,45	0,85	-10°C
1,82	2,97	1,63	1,79	2,37	1,33	1,75	1,77	1,01	0,00	0,00	0,00	-11°C
1,87	3,00	1,60	1,85	2,44	1,31	1,83	1,88	1,02	0,00	0,00	0,00	-12°C
1,92	3,02	1,57	1,92	2,50	1,30	1,92	1,99	1,04	0,00	0,00	0,00	-13°C
1,97	3,04	1,54	1,99	2,57	1,29	2,00	2,10	1,05	0,00	0,00	0,00	-14°C
2,03	3,06	1,51	2,05	2,64	1,28	2,08	2,21	1,06	0,00	0,00	0,00	-15°C
2,01	3,01	1,49	2,04	2,58	1,26	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,00	2,95	1,47	2,02	2,52	1,24	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
1,99	2,89	1,46	2,01	2,46	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
1,97	2,83	1,44	1,99	2,40	1,20	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
1,96	2,77	1,42	1,97	2,34	1,18	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
1,95	2,71	1,39	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
1,93	2,66	1,37	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
1,92	2,60	1,35	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
1,91	2,54	1,33	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
1,89	2,48	1,31	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 5

	Starting temperature																					
	25°C			30°C			35°C			40°C			45°C			50°C			55°C			
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
Outdoor temperature	35°C	1,30	8,87	6,85	1,48	8,76	5,91	1,63	8,52	5,24	1,82	8,39	4,61	2,01	8,29	4,12	2,20	8,19	3,73	2,39	8,09	3,39
	34°C	1,29	8,85	6,86	1,48	8,74	5,92	1,62	8,50	5,25	1,82	8,37	4,60	2,01	8,27	4,12	2,20	8,17	3,72	2,38	8,07	3,39
	33°C	1,29	8,84	6,87	1,47	8,73	5,93	1,61	8,48	5,26	1,82	8,35	4,60	2,01	8,25	4,12	2,19	8,15	3,72	2,38	8,05	3,38
	32°C	1,28	8,82	6,89	1,46	8,71	5,95	1,61	8,47	5,27	1,82	8,34	4,59	2,00	8,24	4,11	2,19	8,14	3,71	2,38	8,04	3,38
	31°C	1,28	8,80	6,90	1,46	8,69	5,96	1,60	8,45	5,28	1,81	8,32	4,59	2,00	8,22	4,11	2,19	8,12	3,71	2,38	8,02	3,37
	30°C	1,27	8,78	6,92	1,45	8,68	5,97	1,59	8,43	5,29	1,81	8,30	4,58	2,00	8,20	4,10	2,19	8,10	3,71	2,37	8,00	3,37
	29°C	1,27	8,77	6,93	1,45	8,66	5,98	1,59	8,41	5,30	1,81	8,29	4,58	2,00	8,19	4,10	2,18	8,09	3,70	2,37	7,99	3,37
	28°C	1,26	8,75	6,94	1,44	8,64	5,99	1,58	8,40	5,31	1,81	8,27	4,57	2,00	8,17	4,09	2,18	8,07	3,70	2,37	7,97	3,36
	27°C	1,26	8,73	6,96	1,44	8,62	6,01	1,57	8,38	5,32	1,81	8,25	4,57	1,99	8,15	4,09	2,18	8,05	3,69	2,37	7,95	3,36
	26°C	1,25	8,71	6,97	1,43	8,61	6,02	1,57	8,36	5,34	1,80	8,24	4,56	1,99	8,14	4,09	2,18	8,04	3,69	2,36	7,94	3,36
	25°C	1,25	8,70	6,99	1,42	8,59	6,03	1,56	8,35	5,35	1,80	8,22	4,56	1,99	8,12	4,08	2,18	8,02	3,69	2,36	7,92	3,35
	24°C	1,24	8,68	7,00	1,42	8,57	6,04	1,56	8,33	5,36	1,80	8,20	4,55	1,99	8,10	4,08	2,17	8,00	3,68	2,36	7,90	3,35
	23°C	1,24	8,66	7,01	1,41	8,55	6,05	1,55	8,31	5,37	1,80	8,19	4,55	1,99	8,09	4,07	2,17	7,99	3,68	2,36	7,89	3,35
	22°C	1,23	8,65	7,03	1,41	8,54	6,07	1,54	8,30	5,38	1,80	8,17	4,54	1,98	8,07	4,07	2,17	7,97	3,67	2,35	7,87	3,34
	21°C	1,23	8,63	7,04	1,40	8,52	6,08	1,54	8,28	5,39	1,80	8,15	4,54	1,98	8,05	4,06	2,17	7,95	3,67	2,35	7,85	3,34
	20°C	1,22	8,61	7,06	1,40	8,50	6,09	1,53	8,26	5,40	1,79	8,14	4,54	1,98	8,04	4,06	2,16	7,94	3,67	2,35	7,84	3,33
	19°C	1,22	8,59	7,07	1,39	8,49	6,10	1,52	8,25	5,41	1,79	8,12	4,53	1,98	8,02	4,06	2,16	7,92	3,66	2,35	7,82	3,33
	18°C	1,21	8,58	7,08	1,39	8,47	6,11	1,52	8,23	5,42	1,79	8,10	4,53	1,98	8,00	4,05	2,16	7,90	3,66	2,35	7,80	3,33
	17°C	1,21	8,56	7,10	1,38	8,45	6,13	1,51	8,22	5,43	1,79	8,09	4,52	1,97	7,99	4,05	2,16	7,89	3,65	2,34	7,79	3,32
	16°C	1,20	8,54	7,11	1,37	8,44	6,14	1,51	8,20	5,44	1,79	8,07	4,52	1,97	7,97	4,04	2,16	7,87	3,65	2,34	7,77	3,32
	15°C	1,20	8,52	7,13	1,37	8,42	6,15	1,50	8,18	5,45	1,79	8,06	4,51	1,97	7,96	4,04	2,15	7,85	3,65	2,34	7,75	3,32
	14°C	1,19	8,51	7,14	1,36	8,40	6,16	1,49	8,17	5,46	1,78	8,04	4,51	1,97	7,94	4,03	2,15	7,84	3,64	2,34	7,74	3,31
	13°C	1,19	8,49	7,15	1,36	8,39	6,18	1,49	8,15	5,48	1,78	8,02	4,50	1,97	7,92	4,03	2,15	7,82	3,64	2,33	7,72	3,31
	12°C	1,18	8,47	7,17	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63	2,33	7,71	3,31
	11°C	1,21	8,39	6,95	1,37	8,29	6,03	1,51	8,09	5,36	1,78	7,96	4,48	1,96	7,86	4,01	2,15	7,76	3,62	2,33	7,66	3,29
	10°C	1,23	8,31	6,73	1,40	8,21	5,88	1,53	8,04	5,24	1,78	7,91	4,45	1,96	7,81	3,99	2,14	7,71	3,60	2,33	7,61	3,27
	9°C	1,26	8,23	6,53	1,42	8,13	5,73	1,56	7,99	5,12	1,77	7,87	4,43	1,96	7,77	3,97	2,14	7,67	3,58	2,32	7,56	3,25
	8°C	1,29	8,15	6,33	1,44	8,05	5,59	1,59	7,95	5,01	1,77	7,82	4,41	1,96	7,72	3,95	2,14	7,62	3,56	2,32	7,52	3,24
	7°C	1,31	8,07	6,14	1,46	7,97	5,45	1,60	7,87	4,91	1,77	7,77	4,39	1,95	7,67	3,93	2,14	7,57	3,54	2,32	7,47	3,22
	6°C	1,47	7,64	5,18	1,61	7,57	4,70	1,76	7,51	4,27	1,92	7,44	3,87	2,10	7,37	3,52	2,27	7,31	3,22	2,44	7,24	2,96
	5°C	1,60	7,28	4,55	1,73	7,24	4,20	1,88	7,20	3,84	2,04	7,16	3,51	2,21	7,12	3,23	2,37	7,08	2,99	2,54	7,04	2,78
	4°C	1,69	6,98	4,13	1,81	6,96	3,85	1,96	6,95	3,54	2,12	6,93	3,27	2,28	6,92	3,03	2,45	6,90	2,82	2,61	6,88	2,64
3°C	1,74	6,75	3,87	1,86	6,75	3,63	2,01	6,75	3,35	2,17	6,75	3,11	2,33	6,76	2,90	2,49	6,76	2,72	2,65	6,76	2,55	
2°C	1,76	6,45	3,66	1,87	6,47	3,46	2,03	6,50	3,20	2,19	6,52	2,98	2,35	6,55	2,79	2,50	6,58	2,63	2,66	6,60	2,48	
1°C	1,77	6,49	3,67	1,88	6,50	3,46	2,04	6,49	3,19	2,19	6,50	2,97	2,35	6,51	2,77	2,51	6,53	2,61	2,66	6,48	2,44	
0°C	1,79	6,53	3,66	1,90	6,52	3,44	2,05	6,48	3,16	2,20	6,48	2,94	2,36	6,48	2,75	2,52	6,49	2,58	2,65	6,36	2,40	
-1°C	1,82	6,57	3,62	1,93	6,55	3,39	2,07	6,47	3,12	2,22	6,46	2,90	2,38	6,44	2,71	2,53	6,45	2,55	2,64	6,23	2,36	
-2°C	1,86	6,60	3,55	1,97	6,57	3,33	2,11	6,46	3,07	2,25	6,44	2,86	2,40	6,41	2,67	2,55	6,41	2,51	2,63	6,11	2,33	
-3°C	1,92	6,64	3,47	2,03	6,59	3,26	2,15	6,46	3,00	2,29	6,41	2,80	2,43	6,37	2,62	2,58	6,37	2,47	2,61	5,99	2,30	
-4°C	1,98	6,68	3,37	2,09	6,62	3,16	2,20	6,45	2,93	2,33	6,39	2,74	2,46	6,33	2,57	2,61	6,33	2,42	2,58	5,87	2,27	
-5°C	2,06	6,72	3,26	2,17	6,64	3,06	2,26	6,44	2,85	2,38	6,37	2,67	2,51	6,30	2,51	2,65	6,29	2,37	2,56	5,74	2,25	
-6°C	2,16	6,76	3,13	2,26	6,67	2,95	2,33	6,43	2,76	2,44	6,35	2,60	2,55	6,26	2,45	2,70	6,25	2,32	2,52	5,62	2,23	
-7°C	2,26	6,80	3,00	2,36	6,69	2,83	2,41	6,42	2,66	2,51	6,32	2,52	2,61	6,23	2,39	2,75	6,21	2,26	2,49	5,50	2,21	
-8°C	2,19	6,58	3,00	2,32	6,37	2,75	2,40	6,05	2,51	2,53	6,03	2,39	2,65	6,02	2,27	2,80	6,06	2,17	2,68	5,63	2,10	
-9°C	2,12	6,37	3,00	2,27	6,05	2,67	2,40	5,67	2,37	2,54	5,74	2,26	2,68	5,81	2,16	2,84	5,90	2,08	2,87	5,77	2,01	
-10°C	2,05	6,15	3,00	2,22	5,72	2,58	2,39	5,30	2,22	2,55	5,45	2,13	2,72	5,60	2,06	2,89	5,75	1,99	3,06	5,90	1,93	
-11°C	2,07	6,10	2,95	2,23	5,72	2,57	2,39	5,34	2,23	2,54	5,41	2,13	2,70	5,49	2,04	2,85	5,56	1,95	3,00	5,56	1,85	
-12°C	2,08	6,04	2,90	2,24	5,71	2,55	2,39	5,37	2,25	2,53	5,38	2,13	2,67	5,39	2,02	2,81	5,36	1,91	2,95	5,22	1,77	
-13°C	2,10	5,99	2,86	2,24	5,70	2,54	2,39	5,41	2,26	2,52	5,34	2,12	2,64	5,28	2,00	2,77	5,17	1,87	2,89	4,88	1,69	
-14°C	2,11	5,94	2,81	2,25	5,69	2,53	2,39	5,44	2,27	2,50	5,31	2,12	2,62	5,17	1,98	2,73	4,98	1,82	2,84	4,54	1,60	
-15°C	2,13	5,89	2,77	2,26	5,68	2,51	2,39	5,48	2,29	2,53	5,27	2,09	2,66	5,06	1,90	2,77	4,78	1,73	2,79	4,20	1,51	
-16°C	2,12	5,63	2,65	2,25	5,44	2,42	2,38	5,25	2,20	2,48	5,06	2,04	2,58	4,87	1,88	2,68	4,61	1,72	2,78	4,10	1,47	
-17°C	2,12	5,																				

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,51	7,99	3,19	2,91	7,89	2,71	3,37	7,79	2,31	0,00	0,00	0,00	35°C
2,50	7,97	3,18	2,90	7,87	2,71	3,37	7,77	2,31	0,00	0,00	0,00	34°C
2,50	7,95	3,18	2,90	7,85	2,71	3,36	7,75	2,31	0,00	0,00	0,00	33°C
2,50	7,94	3,18	2,90	7,84	2,70	3,36	7,73	2,30	0,00	0,00	0,00	32°C
2,50	7,92	3,17	2,89	7,82	2,70	3,36	7,72	2,30	0,00	0,00	0,00	31°C
2,49	7,90	3,17	2,89	7,80	2,70	3,35	7,70	2,30	0,00	0,00	0,00	30°C
2,49	7,89	3,16	2,89	7,78	2,69	3,35	7,68	2,29	0,00	0,00	0,00	29°C
2,49	7,87	3,16	2,89	7,77	2,69	3,35	7,67	2,29	0,00	0,00	0,00	28°C
2,49	7,85	3,16	2,88	7,75	2,69	3,34	7,65	2,29	0,00	0,00	0,00	27°C
2,48	7,84	3,15	2,88	7,73	2,69	3,34	7,63	2,29	0,00	0,00	0,00	26°C
2,48	7,82	3,15	2,88	7,72	2,68	3,34	7,62	2,28	0,00	0,00	0,00	25°C
2,48	7,80	3,15	2,87	7,70	2,68	3,33	7,60	2,28	0,00	0,00	0,00	24°C
2,48	7,79	3,14	2,87	7,69	2,68	3,33	7,58	2,28	0,00	0,00	0,00	23°C
2,47	7,77	3,14	2,87	7,67	2,67	3,33	7,57	2,28	0,00	0,00	0,00	22°C
2,47	7,75	3,14	2,87	7,65	2,67	3,32	7,55	2,27	0,00	0,00	0,00	21°C
2,47	7,74	3,13	2,86	7,64	2,67	3,32	7,54	2,27	0,00	0,00	0,00	20°C
2,47	7,72	3,13	2,86	7,62	2,66	3,32	7,52	2,27	3,84	7,42	1,93	19°C
2,46	7,70	3,13	2,86	7,60	2,66	3,31	7,50	2,27	3,84	7,40	1,93	18°C
2,46	7,69	3,12	2,85	7,59	2,66	3,31	7,49	2,26	3,84	7,39	1,93	17°C
2,46	7,67	3,12	2,85	7,57	2,65	3,31	7,47	2,26	3,83	7,37	1,92	16°C
2,46	7,65	3,12	2,85	7,55	2,65	3,30	7,45	2,26	3,83	7,35	1,92	15°C
2,45	7,64	3,11	2,85	7,54	2,65	3,30	7,44	2,25	3,82	7,34	1,92	14°C
2,45	7,62	3,11	2,84	7,52	2,65	3,30	7,42	2,25	3,82	7,32	1,92	13°C
2,45	7,61	3,10	2,84	7,51	2,64	3,29	7,41	2,25	3,82	7,30	1,91	12°C
2,45	7,56	3,09	2,84	7,46	2,63	3,29	7,36	2,24	3,81	7,26	1,90	11°C
2,44	7,51	3,07	2,83	7,41	2,61	3,29	7,31	2,23	3,81	7,21	1,89	10°C
2,44	7,46	3,06	2,83	7,36	2,60	3,28	7,26	2,21	3,81	7,16	1,88	9°C
2,44	7,42	3,04	2,83	7,32	2,59	3,28	7,22	2,20	3,80	7,12	1,87	8°C
2,44	7,37	3,02	2,83	7,27	2,57	3,28	7,17	2,19	3,80	7,07	1,86	7°C
2,57	7,17	2,79	2,88	7,11	2,47	3,22	7,04	2,18	3,62	6,97	1,93	6°C
2,68	7,01	2,61	2,92	6,97	2,38	3,18	6,93	2,18	3,47	6,89	1,98	5°C
2,76	6,87	2,49	2,95	6,85	2,32	3,16	6,84	2,17	3,37	6,82	2,02	4°C
2,80	6,76	2,41	2,97	6,76	2,28	3,14	6,77	2,16	3,31	6,77	2,04	3°C
2,82	6,63	2,35	2,98	6,65	2,23	3,13	6,68	2,13	3,29	6,70	2,04	2°C
2,81	6,35	2,26	2,96	6,23	2,11	3,11	6,10	1,96	3,26	6,03	1,85	1°C
2,78	6,08	2,19	2,90	5,80	2,00	3,02	5,53	1,83	3,15	5,35	1,70	0°C
2,72	5,81	2,13	2,80	5,38	1,92	2,88	4,95	1,72	2,97	4,68	1,58	-1°C
2,65	5,53	2,09	2,67	4,95	1,86	2,68	4,38	1,63	2,71	4,00	1,48	-2°C
2,55	5,26	2,06	2,49	4,53	1,82	2,43	3,80	1,56	2,39	3,33	1,39	-3°C
2,43	4,99	2,05	2,28	4,11	1,80	2,12	3,23	1,52	1,99	2,65	1,33	-4°C
2,29	4,71	2,06	2,02	3,68	1,82	1,76	2,65	1,51	1,52	1,98	1,30	-5°C
2,13	4,44	2,09	1,73	3,26	1,88	1,34	2,08	1,55	0,97	1,30	1,34	-6°C
1,95	4,17	2,14	1,40	2,83	2,02	0,86	1,50	1,74	0,36	0,62	1,74	-7°C
2,31	4,53	1,96	1,95	3,43	1,76	1,58	2,33	1,48	1,29	1,78	1,38	-8°C
2,68	4,90	1,83	2,49	4,03	1,62	2,30	3,17	1,37	2,23	2,94	1,32	-9°C
3,05	5,27	1,73	3,04	4,63	1,53	3,03	4,00	1,32	3,17	4,10	1,29	-10°C
3,00	4,94	1,65	2,99	4,32	1,44	2,99	3,69	1,24	0,00	0,00	0,00	-11°C
2,95	4,61	1,56	2,95	4,00	1,36	2,95	3,38	1,15	0,00	0,00	0,00	-12°C
2,90	4,28	1,48	2,90	3,68	1,27	2,91	3,08	1,06	0,00	0,00	0,00	-13°C
2,85	3,95	1,39	2,86	3,36	1,18	2,87	2,77	0,97	0,00	0,00	0,00	-14°C
2,80	3,62	1,29	2,82	3,04	1,08	2,83	2,46	0,87	0,00	0,00	0,00	-15°C
2,79	3,53	1,26	2,80	2,96	1,06	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,78	3,44	1,24	2,78	2,87	1,03	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
2,77	3,34	1,21	2,76	2,79	1,01	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
2,76	3,25	1,18	2,75	2,70	0,98	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
2,75	3,16	1,15	2,73	2,62	0,96	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
2,75	3,07	1,12	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
2,74	2,97	1,09	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
2,73	2,88	1,06	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
2,72	2,79	1,03	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
2,71	2,70	1,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 7 / 7TRI

	Starting temperature																					
	25°C			30°C			35°C			40°C			45°C			50°C			55°C			
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
Outdoor temperature	35°C	1,17	9,16	7,82	1,50	9,16	6,11	1,72	9,08	5,28	2,08	9,07	4,36	2,42	9,14	3,78	2,75	9,25	3,36	3,09	9,44	3,05
	34°C	1,17	9,14	7,83	1,49	9,14	6,12	1,71	9,07	5,29	2,08	9,06	4,36	2,41	9,12	3,78	2,75	9,23	3,36	3,09	9,44	3,06
	33°C	1,16	9,12	7,85	1,49	9,12	6,14	1,71	9,05	5,30	2,08	9,04	4,35	2,41	9,10	3,77	2,75	9,21	3,35	3,09	9,44	3,06
	32°C	1,16	9,10	7,86	1,48	9,10	6,15	1,70	9,03	5,31	2,07	9,02	4,35	2,41	9,09	3,77	2,75	9,20	3,35	3,08	9,44	3,06
	31°C	1,15	9,08	7,88	1,47	9,08	6,16	1,69	9,01	5,32	2,07	9,00	4,35	2,41	9,07	3,77	2,74	9,19	3,35	3,08	9,44	3,07
	30°C	1,15	9,06	7,89	1,47	9,06	6,17	1,69	8,99	5,33	2,07	8,98	4,34	2,41	9,05	3,76	2,74	9,19	3,35	3,08	9,44	3,07
	29°C	1,14	9,05	7,91	1,46	9,05	6,19	1,68	8,98	5,34	2,07	8,97	4,34	2,40	9,03	3,76	2,74	9,19	3,36	3,07	9,44	3,07
	28°C	1,14	9,03	7,93	1,46	9,03	6,20	1,67	8,96	5,35	2,07	8,95	4,33	2,40	9,01	3,75	2,74	9,19	3,36	3,07	9,44	3,07
	27°C	1,13	9,01	7,94	1,45	9,01	6,21	1,67	8,94	5,36	2,06	8,93	4,33	2,40	9,00	3,75	2,73	9,19	3,36	3,07	9,44	3,08
	26°C	1,13	8,99	7,96	1,45	8,99	6,22	1,66	8,92	5,37	2,06	8,91	4,32	2,40	8,98	3,75	2,73	9,19	3,37	3,06	9,44	3,08
	25°C	1,13	8,97	7,97	1,44	8,97	6,24	1,65	8,91	5,38	2,06	8,90	4,32	2,39	8,96	3,74	2,73	9,19	3,37	3,06	9,44	3,08
	24°C	1,12	8,96	7,99	1,43	8,96	6,25	1,65	8,89	5,40	2,06	8,88	4,32	2,39	8,94	3,74	2,72	9,19	3,37	3,06	9,44	3,09
	23°C	1,12	8,94	8,01	1,43	8,94	6,26	1,64	8,87	5,41	2,06	8,86	4,31	2,39	8,94	3,74	2,72	9,19	3,38	3,05	9,44	3,09
	22°C	1,11	8,92	8,02	1,42	8,92	6,27	1,63	8,85	5,42	2,05	8,84	4,31	2,39	8,94	3,75	2,72	9,19	3,38	3,05	9,44	3,09
	21°C	1,11	8,90	8,04	1,42	8,90	6,29	1,63	8,83	5,43	2,05	8,82	4,30	2,38	8,94	3,75	2,72	9,19	3,38	3,05	9,44	3,10
	20°C	1,10	8,89	8,05	1,41	8,89	6,30	1,62	8,82	5,44	2,05	8,81	4,30	2,38	8,94	3,76	2,71	9,19	3,39	3,05	9,44	3,10
	19°C	1,10	8,87	8,07	1,41	8,87	6,31	1,61	8,80	5,45	2,05	8,79	4,29	2,38	8,94	3,76	2,71	9,19	3,39	3,04	9,44	3,10
	18°C	1,09	8,85	8,09	1,40	8,85	6,32	1,61	8,78	5,46	2,05	8,77	4,29	2,38	8,94	3,76	2,71	9,19	3,39	3,04	9,44	3,11
	17°C	1,09	8,83	8,10	1,39	8,83	6,34	1,60	8,76	5,47	2,04	8,75	4,29	2,37	8,94	3,77	2,71	9,19	3,40	3,04	9,44	3,11
	16°C	1,09	8,81	8,12	1,39	8,81	6,35	1,60	8,75	5,48	2,04	8,74	4,28	2,37	8,94	3,77	2,70	9,19	3,40	3,03	9,44	3,11
	15°C	1,08	8,80	8,13	1,38	8,80	6,36	1,59	8,73	5,49	2,04	8,72	4,28	2,37	8,94	3,77	2,70	9,19	3,40	3,03	9,44	3,11
	14°C	1,08	8,78	8,15	1,38	8,78	6,37	1,58	8,71	5,50	2,04	8,70	4,27	2,37	8,94	3,78	2,70	9,19	3,41	3,03	9,44	3,12
	13°C	1,07	8,76	8,17	1,37	8,76	6,39	1,58	8,69	5,51	2,03	8,70	4,27	2,36	8,94	3,78	2,69	9,19	3,41	3,02	9,44	3,12
	12°C	1,07	8,74	8,18	1,37	8,74	6,40	1,57	8,68	5,53	2,03	8,70	4,28	2,36	8,94	3,79	2,69	9,19	3,41	3,02	9,44	3,12
	11°C	1,13	8,71	7,69	1,41	8,71	6,18	1,61	8,66	5,38	2,03	8,70	4,28	2,36	8,94	3,79	2,69	9,19	3,42	3,02	9,44	3,13
	10°C	1,20	8,68	7,25	1,45	8,68	5,97	1,65	8,65	5,24	2,03	8,70	4,29	2,36	8,94	3,79	2,69	9,19	3,42	3,02	9,44	3,13
	9°C	1,26	8,66	6,85	1,50	8,66	5,78	1,69	8,64	5,10	2,03	8,70	4,29	2,36	8,94	3,80	2,68	9,19	3,42	3,01	9,44	3,13
	8°C	1,33	8,63	6,50	1,54	8,63	5,60	1,73	8,62	4,97	2,02	8,70	4,29	2,35	8,94	3,80	2,68	9,19	3,43	3,01	9,44	3,14
	7°C	1,39	8,60	6,17	1,58	8,60	5,42	1,75	8,60	4,91	2,02	8,70	4,30	2,35	8,94	3,80	2,68	9,19	3,43	3,01	9,44	3,14
	6°C	1,55	8,03	5,19	1,69	8,03	4,76	1,85	8,04	4,34	2,08	8,12	3,90	2,35	8,31	3,54	2,62	8,50	3,25	2,88	8,69	3,01
	5°C	1,67	7,54	4,52	1,77	7,56	4,27	1,93	7,57	3,92	2,13	7,63	3,58	2,35	7,77	3,31	2,57	7,91	3,08	2,79	8,05	2,89
	4°C	1,75	7,15	4,07	1,83	7,17	3,92	1,99	7,18	3,62	2,16	7,23	3,35	2,35	7,33	3,12	2,53	7,43	2,93	2,72	7,53	2,77
3°C	1,81	6,84	3,79	1,86	6,86	3,69	2,02	6,88	3,41	2,18	6,92	3,17	2,35	6,99	2,98	2,51	7,06	2,81	2,68	7,12	2,66	
2°C	1,82	6,45	3,54	1,87	6,47	3,45	2,03	6,50	3,20	2,19	6,52	2,98	2,35	6,55	2,79	2,50	6,58	2,63	2,66	6,60	2,48	
1°C	1,83	6,70	3,66	1,88	6,67	3,55	2,04	6,65	3,26	2,19	6,66	3,03	2,35	6,67	2,84	2,51	6,58	2,62	2,67	6,59	2,47	
0°C	1,86	6,96	3,75	1,91	6,87	3,61	2,06	6,80	3,30	2,21	6,79	3,07	2,36	6,78	2,87	2,52	6,58	2,61	2,68	6,58	2,46	
-1°C	1,90	7,21	3,80	1,95	7,07	3,63	2,10	6,95	3,31	2,24	6,92	3,09	2,39	6,90	2,89	2,53	6,58	2,60	2,70	6,57	2,43	
-2°C	1,95	7,47	3,82	2,01	7,28	3,63	2,15	7,09	3,30	2,28	7,06	3,09	2,42	7,02	2,90	2,56	6,59	2,58	2,74	6,56	2,40	
-3°C	2,03	7,73	3,81	2,08	7,48	3,59	2,21	7,24	3,27	2,34	7,19	3,08	2,46	7,14	2,90	2,59	6,59	2,55	2,78	6,55	2,36	
-4°C	2,12	7,98	3,77	2,17	7,68	3,54	2,29	7,39	3,22	2,40	7,32	3,05	2,51	7,25	2,89	2,63	6,59	2,51	2,83	6,53	2,31	
-5°C	2,22	8,24	3,71	2,28	7,88	3,46	2,39	7,54	3,16	2,48	7,46	3,01	2,57	7,37	2,87	2,67	6,60	2,47	2,89	6,52	2,26	
-6°C	2,34	8,49	3,62	2,40	8,08	3,36	2,50	7,69	3,08	2,57	7,59	2,96	2,64	7,49	2,84	2,72	6,60	2,42	2,96	6,51	2,20	
-7°C	2,48	8,75	3,52	2,54	8,28	3,26	2,62	7,84	2,99	2,67	7,72	2,89	2,71	7,60	2,80	2,78	6,60	2,38	3,04	6,50	2,14	
-8°C	2,45	8,59	3,50	2,53	8,10	3,20	2,62	7,63	2,91	2,69	7,44	2,77	2,76	7,25	2,63	2,84	6,48	2,28	3,04	6,30	2,07	
-9°C	2,43	8,43	3,47	2,52	7,91	3,14	2,62	7,41	2,83	2,71	7,16	2,64	2,80	6,90	2,47	2,89	6,35	2,20	3,05	6,10	2,00	
-10°C	2,40	8,26	3,45	2,51	7,73	3,08	2,62	7,20	2,75	2,73	6,88	2,52	2,84	6,55	2,31	2,95	6,23	2,11	3,06	5,90	1,93	
-11°C	2,34	7,79	3,32	2,46	7,32	2,98	2,57	6,86	2,66	2,68	6,55	2,44	2,79	6,25	2,24	2,90	5,94	2,05	3,00	5,56	1,85	
-12°C	2,29	7,31	3,19	2,41	6,91	2,87	2,53	6,51	2,57	2,63	6,23	2,37	2,74	5,96	2,17	2,84	5,65	1,99	2,95	5,22	1,77	
-13°C	2,24	6,84	3,06	2,36	6,50	2,76	2,48	6,17	2,48	2,59	5,91	2,29	2,69	5,66	2,10	2,79	5,36	1,92	2,89	4,88	1,69	
-14°C	2,18	6,36	2,92	2,31	6,09	2,64	2,44	5,82	2,39	2,54	5,59	2,20	2,64	5,36	2,03	2,74	5,07	1,85	2,84	4,54	1,60	
-15°C	2,13	5,89	2,77	2,26	5,68	2,51	2,39	5,48	2,29	2,53	5,27	2,09	2,66	5,06	1,90	2,77	4,78	1,73	2,79	4,20	1,51	
-16°C	2,12	5,63	2,65	2,25	5,44	2,42	2,38	5,25	2,20	2,48	5,06	2,04	2,58	4,87	1,88	2,68	4,61	1,72	2,78	4,10	1,47	
-17°C	2,12	5,38	2,54</																			

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
3,25	9,69	2,98	3,77	9,94	2,64	4,37	10,18	2,33	0,00	0,00	0,00	35°C
3,25	9,69	2,99	3,76	9,94	2,64	4,36	10,18	2,34	0,00	0,00	0,00	34°C
3,24	9,69	2,99	3,76	9,94	2,64	4,36	10,18	2,34	0,00	0,00	0,00	33°C
3,24	9,69	2,99	3,75	9,94	2,65	4,35	10,18	2,34	0,00	0,00	0,00	32°C
3,24	9,69	2,99	3,75	9,94	2,65	4,35	10,18	2,34	0,00	0,00	0,00	31°C
3,23	9,69	3,00	3,75	9,94	2,65	4,34	10,18	2,34	0,00	0,00	0,00	30°C
3,23	9,69	3,00	3,74	9,94	2,65	4,34	10,18	2,35	0,00	0,00	0,00	29°C
3,23	9,69	3,00	3,74	9,94	2,66	4,34	10,18	2,35	0,00	0,00	0,00	28°C
3,22	9,69	3,01	3,74	9,94	2,66	4,33	10,18	2,35	0,00	0,00	0,00	27°C
3,22	9,69	3,01	3,73	9,94	2,66	4,33	10,18	2,35	0,00	0,00	0,00	26°C
3,22	9,69	3,01	3,73	9,94	2,66	4,32	10,18	2,36	0,00	0,00	0,00	25°C
3,21	9,69	3,02	3,72	9,94	2,67	4,32	10,18	2,36	0,00	0,00	0,00	24°C
3,21	9,69	3,02	3,72	9,94	2,67	4,31	10,18	2,36	0,00	0,00	0,00	23°C
3,21	9,69	3,02	3,72	9,94	2,67	4,31	10,18	2,36	0,00	0,00	0,00	22°C
3,20	9,69	3,02	3,71	9,94	2,68	4,31	10,18	2,37	0,00	0,00	0,00	21°C
3,20	9,69	3,03	3,71	9,94	2,68	4,30	10,18	2,37	0,00	0,00	0,00	20°C
3,20	9,69	3,03	3,71	9,94	2,68	4,30	10,18	2,37	4,98	10,43	2,09	19°C
3,19	9,69	3,03	3,70	9,94	2,68	4,29	10,18	2,37	4,98	10,43	2,10	18°C
3,19	9,69	3,04	3,70	9,94	2,69	4,29	10,18	2,38	4,97	10,43	2,10	17°C
3,19	9,69	3,04	3,70	9,94	2,69	4,28	10,18	2,38	4,97	10,43	2,10	16°C
3,18	9,69	3,04	3,69	9,94	2,69	4,28	10,18	2,38	4,96	10,43	2,10	15°C
3,18	9,69	3,05	3,69	9,94	2,69	4,28	10,18	2,38	4,96	10,43	2,11	14°C
3,18	9,69	3,05	3,68	9,94	2,70	4,27	10,18	2,38	4,95	10,43	2,11	13°C
3,17	9,69	3,05	3,68	9,94	2,70	4,27	10,18	2,39	4,95	10,43	2,11	12°C
3,17	9,69	3,05	3,68	9,94	2,70	4,26	10,18	2,39	4,94	10,43	2,11	11°C
3,17	9,69	3,06	3,67	9,94	2,71	4,26	10,18	2,39	4,94	10,43	2,11	10°C
3,17	9,69	3,06	3,67	9,94	2,71	4,25	10,18	2,39	4,93	10,43	2,12	9°C
3,16	9,69	3,06	3,67	9,94	2,71	4,25	10,18	2,40	4,93	10,43	2,12	8°C
3,16	9,69	3,07	3,66	9,94	2,71	4,25	10,18	2,40	4,92	10,43	2,12	7°C
3,04	8,88	2,92	3,42	9,07	2,65	3,85	9,25	2,41	4,33	9,44	2,18	6°C
2,94	8,19	2,78	3,22	8,33	2,58	3,53	8,47	2,40	3,88	8,61	2,22	5°C
2,87	7,63	2,65	3,09	7,73	2,50	3,31	7,82	2,36	3,55	7,92	2,23	4°C
2,83	7,19	2,54	3,00	7,26	2,42	3,18	7,32	2,30	3,36	7,39	2,20	3°C
2,82	6,63	2,35	2,98	6,65	2,24	3,13	6,68	2,13	3,29	6,71	2,04	2°C
2,83	6,60	2,33	2,98	6,60	2,21	3,14	6,60	2,10	3,30	6,67	2,02	1°C
2,85	6,56	2,31	3,01	6,55	2,17	3,18	6,53	2,06	3,34	6,63	1,98	0°C
2,88	6,53	2,27	3,05	6,49	2,13	3,23	6,45	2,00	3,41	6,60	1,93	-1°C
2,92	6,50	2,22	3,11	6,44	2,07	3,30	6,38	1,93	3,50	6,56	1,87	-2°C
2,98	6,46	2,17	3,19	6,38	2,00	3,40	6,30	1,86	3,62	6,52	1,80	-3°C
3,06	6,43	2,10	3,28	6,33	1,93	3,51	6,23	1,77	3,76	6,49	1,72	-4°C
3,14	6,40	2,04	3,40	6,27	1,85	3,65	6,15	1,69	3,93	6,45	1,64	-5°C
3,24	6,37	1,96	3,52	6,22	1,76	3,81	6,08	1,60	4,13	6,41	1,55	-6°C
3,35	6,33	1,89	3,67	6,17	1,68	3,99	6,00	1,50	4,35	6,38	1,46	-7°C
3,24	5,88	1,82	3,43	5,46	1,59	3,62	5,03	1,39	3,89	5,22	1,34	-8°C
3,12	5,42	1,74	3,18	4,75	1,49	3,25	4,07	1,25	3,43	4,06	1,18	-9°C
3,00	4,97	1,66	2,94	4,04	1,37	2,88	3,10	1,08	2,97	2,90	0,98	-10°C
2,96	4,70	1,59	2,91	3,84	1,32	2,87	2,97	1,04	0,00	0,00	0,00	-11°C
2,92	4,43	1,52	2,89	3,64	1,26	2,86	2,85	1,00	0,00	0,00	0,00	-12°C
2,88	4,16	1,44	2,86	3,44	1,20	2,85	2,72	0,95	0,00	0,00	0,00	-13°C
2,84	3,89	1,37	2,84	3,24	1,14	2,84	2,59	0,91	0,00	0,00	0,00	-14°C
2,80	3,62	1,29	2,82	3,04	1,08	2,83	2,46	0,87	0,00	0,00	0,00	-15°C
2,79	3,53	1,26	2,80	2,96	1,06	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
2,78	3,44	1,24	2,78	2,87	1,03	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
2,77	3,34	1,21	2,76	2,79	1,01	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
2,76	3,25	1,18	2,75	2,70	0,98	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
2,75	3,16	1,15	2,73	2,62	0,96	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
2,75	3,07	1,12	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
2,74	2,97	1,09	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
2,73	2,88	1,06	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
2,72	2,79	1,03	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
2,71	2,70	1,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 9 / 9TRI

	Starting temperature																					
	25°C			30°C			35°C			40°C			45°C			50°C			55°C			
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
Outdoor temperature	35°C	1,91	13,33	6,98	2,37	13,33	5,63	2,69	13,13	4,89	3,22	13,10	4,06	3,68	13,15	3,57	4,14	13,23	3,20	4,60	13,34	2,90
	34°C	1,90	13,30	6,99	2,36	13,30	5,64	2,68	13,11	4,90	3,22	13,07	4,06	3,68	13,12	3,57	4,14	13,21	3,19	4,59	13,31	2,90
	33°C	1,89	13,27	7,01	2,35	13,27	5,65	2,67	13,08	4,91	3,22	13,05	4,06	3,67	13,10	3,56	4,13	13,18	3,19	4,59	13,29	2,89
	32°C	1,89	13,25	7,02	2,34	13,25	5,66	2,65	13,06	4,92	3,21	13,02	4,05	3,67	13,07	3,56	4,13	13,16	3,19	4,59	13,26	2,89
	31°C	1,88	13,22	7,04	2,33	13,22	5,67	2,64	13,03	4,93	3,21	13,00	4,05	3,67	13,04	3,56	4,12	13,13	3,18	4,58	13,24	2,89
	30°C	1,87	13,19	7,05	2,32	13,19	5,69	2,63	13,00	4,94	3,21	12,97	4,04	3,66	13,02	3,55	4,12	13,10	3,18	4,58	13,21	2,89
	29°C	1,86	13,17	7,06	2,31	13,17	5,70	2,62	12,98	4,95	3,20	12,94	4,04	3,66	12,99	3,55	4,12	13,08	3,18	4,57	13,18	2,88
	28°C	1,86	13,14	7,08	2,30	13,14	5,71	2,61	12,95	4,96	3,20	12,92	4,04	3,66	12,97	3,55	4,11	13,05	3,17	4,57	13,16	2,88
	27°C	1,85	13,11	7,09	2,29	13,11	5,72	2,60	12,93	4,97	3,20	12,89	4,03	3,65	12,94	3,54	4,11	13,03	3,17	4,56	13,13	2,88
	26°C	1,84	13,09	7,11	2,28	13,09	5,73	2,59	12,90	4,98	3,19	12,87	4,03	3,65	12,92	3,54	4,10	13,00	3,17	4,56	13,11	2,88
	25°C	1,83	13,06	7,12	2,27	13,06	5,74	2,58	12,87	4,99	3,19	12,84	4,02	3,64	12,89	3,54	4,10	12,97	3,17	4,55	13,08	2,87
	24°C	1,83	13,04	7,13	2,27	13,04	5,75	2,57	12,85	5,00	3,19	12,81	4,02	3,64	12,86	3,53	4,10	12,95	3,16	4,55	13,05	2,87
	23°C	1,82	13,01	7,15	2,26	13,01	5,77	2,56	12,82	5,01	3,18	12,79	4,02	3,64	12,84	3,53	4,09	12,92	3,16	4,54	13,03	2,87
	22°C	1,81	12,98	7,16	2,25	12,98	5,78	2,55	12,80	5,02	3,18	12,76	4,01	3,63	12,81	3,53	4,09	12,90	3,16	4,54	13,00	2,86
	21°C	1,81	12,96	7,18	2,24	12,96	5,79	2,54	12,77	5,03	3,18	12,74	4,01	3,63	12,79	3,52	4,08	12,87	3,15	4,54	12,98	2,86
	20°C	1,80	12,93	7,19	2,23	12,93	5,80	2,53	12,75	5,04	3,17	12,71	4,00	3,63	12,76	3,52	4,08	12,85	3,15	4,53	12,97	2,86
	19°C	1,79	12,91	7,21	2,22	12,91	5,81	2,52	12,72	5,05	3,17	12,69	4,00	3,62	12,74	3,52	4,07	12,82	3,15	4,53	12,97	2,87
	18°C	1,78	12,88	7,22	2,21	12,88	5,82	2,51	12,70	5,06	3,17	12,66	4,00	3,62	12,71	3,51	4,07	12,80	3,14	4,52	12,97	2,87
	17°C	1,78	12,85	7,23	2,20	12,85	5,83	2,50	12,67	5,07	3,17	12,64	3,99	3,62	12,69	3,51	4,07	12,78	3,14	4,52	12,97	2,87
	16°C	1,77	12,83	7,25	2,19	12,83	5,85	2,49	12,65	5,08	3,16	12,61	3,99	3,61	12,66	3,50	4,06	12,78	3,15	4,51	12,97	2,87
	15°C	1,76	12,80	7,26	2,19	12,80	5,86	2,48	12,62	5,09	3,16	12,59	3,98	3,61	12,64	3,50	4,06	12,78	3,15	4,51	12,97	2,88
	14°C	1,76	12,78	7,28	2,18	12,78	5,87	2,47	12,59	5,10	3,16	12,56	3,98	3,61	12,61	3,50	4,05	12,78	3,15	4,50	12,97	2,88
	13°C	1,75	12,75	7,29	2,17	12,75	5,88	2,46	12,57	5,11	3,15	12,54	3,98	3,60	12,59	3,50	4,05	12,78	3,16	4,50	12,97	2,88
	12°C	1,74	12,73	7,31	2,16	12,73	5,89	2,45	12,54	5,12	3,15	12,51	3,97	3,60	12,59	3,50	4,05	12,78	3,16	4,49	12,97	2,89
	11°C	1,78	12,65	7,09	2,20	12,65	5,76	2,51	12,51	4,98	3,15	12,47	3,97	3,59	12,59	3,50	4,04	12,78	3,16	4,49	12,97	2,89
	10°C	1,83	12,57	6,88	2,23	12,57	5,63	2,57	12,47	4,86	3,14	12,44	3,96	3,59	12,59	3,51	4,04	12,78	3,16	4,49	12,97	2,89
	9°C	1,87	12,49	6,68	2,27	12,49	5,51	2,63	12,44	4,74	3,14	12,40	3,95	3,59	12,59	3,51	4,03	12,78	3,17	4,48	12,97	2,89
	8°C	1,91	12,41	6,49	2,30	12,41	5,39	2,68	12,40	4,62	3,14	12,40	3,95	3,58	12,59	3,51	4,03	12,78	3,17	4,48	12,97	2,90
	7°C	1,95	12,33	6,31	2,34	12,33	5,27	2,71	12,33	4,54	3,13	12,40	3,96	3,58	12,59	3,52	4,03	12,78	3,17	4,47	12,97	2,90
	6°C	2,29	12,17	5,32	2,65	12,11	4,58	2,98	12,05	4,05	3,34	12,05	3,61	3,71	12,13	3,27	4,09	12,21	2,99	4,46	12,29	2,75
	5°C	2,55	12,04	4,72	2,89	11,93	4,13	3,18	11,82	3,72	3,49	11,75	3,36	3,81	11,74	3,08	4,13	11,72	2,84	4,45	11,71	2,63
	4°C	2,74	11,94	4,36	3,06	11,79	3,85	3,33	11,64	3,50	3,61	11,51	3,19	3,89	11,42	2,94	4,17	11,33	2,72	4,45	11,24	2,53
	3°C	2,85	11,86	4,16	3,16	11,67	3,69	3,42	11,49	3,36	3,67	11,32	3,08	3,93	11,17	2,84	4,19	11,02	2,63	4,45	10,87	2,45
	2°C	2,89	11,75	4,07	3,20	11,52	3,61	3,45	11,30	3,28	3,69	11,07	3,00	3,94	10,85	2,75	4,19	10,63	2,53	4,44	10,40	2,34
	1°C	2,90	11,70	4,04	3,20	11,45	3,57	3,45	11,21	3,25	3,70	10,99	2,97	3,95	10,77	2,73	4,19	10,47	2,50	4,45	10,22	2,30
0°C	2,93	11,65	3,98	3,23	11,38	3,53	3,47	11,12	3,20	3,71	10,91	2,94	3,95	10,70	2,71	4,19	10,32	2,46	4,47	10,03	2,25	
-1°C	2,98	11,60	3,89	3,27	11,30	3,46	3,51	11,03	3,14	3,74	10,82	2,90	3,96	10,62	2,68	4,19	10,17	2,42	4,50	9,85	2,19	
-2°C	3,06	11,55	3,78	3,32	11,23	3,38	3,56	10,94	3,07	3,77	10,74	2,85	3,98	10,55	2,65	4,19	10,02	2,39	4,54	9,67	2,13	
-3°C	3,15	11,50	3,65	3,39	11,15	3,29	3,63	10,84	2,99	3,81	10,66	2,79	4,00	10,47	2,62	4,19	9,87	2,35	4,60	9,48	2,06	
-4°C	3,27	11,45	3,50	3,48	11,08	3,18	3,71	10,75	2,90	3,87	10,57	2,74	4,02	10,39	2,58	4,19	9,72	2,32	4,67	9,30	1,99	
-5°C	3,41	11,40	3,35	3,58	11,00	3,07	3,80	10,66	2,81	3,93	10,49	2,67	4,05	10,32	2,55	4,19	9,56	2,28	4,75	9,12	1,92	
-6°C	3,57	11,35	3,18	3,70	10,93	2,95	3,91	10,57	2,71	4,00	10,41	2,60	4,09	10,24	2,51	4,19	9,41	2,25	4,84	8,93	1,85	
-7°C	3,75	11,30	3,02	3,83	10,86	2,83	4,03	10,48	2,60	4,08	10,32	2,53	4,12	10,17	2,46	4,19	9,26	2,21	4,94	8,75	1,77	
-8°C	3,95	11,14	2,82	4,01	10,67	2,66	4,14	10,25	2,48	4,17	9,99	2,40	4,20	9,73	2,31	4,25	8,97	2,11	4,75	8,47	1,78	
-9°C	4,15	10,98	2,65	4,18	10,49	2,51	4,25	10,03	2,36	4,26	9,66	2,26	4,28	9,29	2,17	4,31	8,67	2,01	4,56	8,18	1,80	
-10°C	4,35	10,82	2,49	4,35	10,31	2,37	4,36	9,80	2,25	4,36	9,33	2,14	4,36	8,85	2,03	4,36	8,38	1,92	4,36	7,90	1,81	
-11°C	4,17	10,40	2,50	4,21	9,98	2,37	4,26	9,55	2,24	4,29	9,15	2,13	4,32	8,75	2,02	4,36	8,33	1,91	4,39	7,78	1,77	
-12°C	3,99	9,98	2,50	4,07	9,64	2,37	4,16	9,30	2,24	4,22	8,98	2,13	4,29	8,66	2,02	4,35	8,28	1,90	4,41	7,66	1,74	
-13°C	3,81	9,56	2,51	3,93	9,31	2,37	4,06	9,05	2,23	4,16	8,81	2,12	4,25	8,56	2,01	4,34	8,23	1,89	4,44	7,55	1,70	
-14°C	3,62	9,14	2,52	3,79	8,97	2,36	3,96	8,80	2,22	4,09	8,63	2,11	4,21	8,47	2,01	4,34	8,18	1,89	4,46	7,43	1,66	
-15°C	3,44	8,72	2,53	3,65	8,64	2,36	3,87	8,55	2,21	4,08	8,46	2,07										

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,83	13,46	2,78	5,60	13,59	2,43	6,49	13,73	2,11	0,00	0,00	0,00	35°C
4,83	13,43	2,78	5,60	13,56	2,42	6,49	13,70	2,11	0,00	0,00	0,00	34°C
4,82	13,41	2,78	5,59	13,54	2,42	6,48	13,67	2,11	0,00	0,00	0,00	33°C
4,82	13,38	2,78	5,59	13,51	2,42	6,48	13,65	2,11	0,00	0,00	0,00	32°C
4,81	13,35	2,77	5,58	13,48	2,42	6,47	13,62	2,11	0,00	0,00	0,00	31°C
4,81	13,33	2,77	5,57	13,46	2,41	6,46	13,60	2,10	0,00	0,00	0,00	30°C
4,80	13,30	2,77	5,57	13,43	2,41	6,46	13,57	2,10	0,00	0,00	0,00	29°C
4,80	13,28	2,77	5,56	13,41	2,41	6,45	13,54	2,10	0,00	0,00	0,00	28°C
4,79	13,25	2,76	5,56	13,38	2,41	6,44	13,54	2,10	0,00	0,00	0,00	27°C
4,79	13,23	2,76	5,55	13,36	2,41	6,44	13,54	2,10	0,00	0,00	0,00	26°C
4,78	13,20	2,76	5,55	13,35	2,41	6,43	13,54	2,11	0,00	0,00	0,00	25°C
4,78	13,17	2,76	5,54	13,35	2,41	6,42	13,54	2,11	0,00	0,00	0,00	24°C
4,78	13,16	2,76	5,54	13,35	2,41	6,42	13,54	2,11	0,00	0,00	0,00	23°C
4,77	13,16	2,76	5,53	13,35	2,41	6,41	13,54	2,11	0,00	0,00	0,00	22°C
4,77	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,11	0,00	0,00	0,00	21°C
4,76	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,12	0,00	0,00	0,00	20°C
4,76	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,41	13,73	1,85	19°C
4,75	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,40	13,73	1,85	18°C
4,75	13,16	2,77	5,50	13,35	2,43	6,38	13,54	2,12	7,40	13,73	1,86	17°C
4,74	13,16	2,78	5,50	13,35	2,43	6,37	13,54	2,12	7,39	13,73	1,86	16°C
4,74	13,16	2,78	5,49	13,35	2,43	6,37	13,54	2,13	7,38	13,73	1,86	15°C
4,73	13,16	2,78	5,49	13,35	2,43	6,36	13,54	2,13	7,37	13,73	1,86	14°C
4,73	13,16	2,78	5,48	13,35	2,44	6,35	13,54	2,13	7,37	13,73	1,86	13°C
4,72	13,16	2,79	5,48	13,35	2,44	6,35	13,54	2,13	7,36	13,73	1,87	12°C
4,72	13,16	2,79	5,47	13,35	2,44	6,34	13,54	2,14	7,35	13,73	1,87	11°C
4,71	13,16	2,79	5,46	13,35	2,44	6,33	13,54	2,14	7,34	13,73	1,87	10°C
4,71	13,16	2,79	5,46	13,35	2,45	6,33	13,54	2,14	7,34	13,73	1,87	9°C
4,70	13,16	2,80	5,45	13,35	2,45	6,32	13,54	2,14	7,33	13,73	1,87	8°C
4,70	13,16	2,80	5,45	13,35	2,45	6,32	13,54	2,14	7,32	13,73	1,87	7°C
4,70	12,37	2,63	5,27	12,45	2,36	5,91	12,53	2,12	6,65	12,61	1,90	6°C
4,70	11,70	2,49	5,13	11,68	2,28	5,60	11,67	2,08	6,12	11,66	1,90	5°C
4,70	11,15	2,37	5,02	11,06	2,20	5,37	10,97	2,04	5,74	10,88	1,89	4°C
4,69	10,72	2,28	4,96	10,57	2,13	5,24	10,43	1,99	5,52	10,28	1,86	3°C
4,69	10,18	2,17	4,94	9,95	2,01	5,19	9,73	1,87	5,44	9,50	1,75	2°C
4,71	9,91	2,10	4,97	9,61	1,93	5,23	9,31	1,78	5,49	9,09	1,66	1°C
4,76	9,65	2,03	5,05	9,28	1,84	5,34	8,90	1,67	5,63	8,68	1,54	0°C
4,84	9,39	1,94	5,18	8,94	1,73	5,52	8,48	1,54	5,87	8,27	1,41	-1°C
4,95	9,13	1,84	5,37	8,60	1,60	5,78	8,07	1,40	6,20	7,86	1,27	-2°C
5,10	8,87	1,74	5,60	8,26	1,48	6,10	7,66	1,25	6,63	7,45	1,12	-3°C
5,28	8,61	1,63	5,89	7,93	1,35	6,50	7,24	1,11	7,15	7,04	0,98	-4°C
5,49	8,35	1,52	6,23	7,59	1,22	6,98	6,83	0,98	7,77	6,63	0,85	-5°C
5,73	8,09	1,41	6,63	7,25	1,09	7,52	6,41	0,85	8,48	6,22	0,73	-6°C
6,01	7,83	1,30	7,08	6,92	0,98	8,14	6,00	0,74	9,29	5,81	0,63	-7°C
5,39	7,43	1,38	6,03	6,40	1,06	6,67	5,36	0,80	7,43	5,14	0,69	-8°C
4,77	7,03	1,47	4,98	5,87	1,18	5,19	4,72	0,91	5,58	4,46	0,80	-9°C
4,15	6,63	1,60	3,93	5,35	1,36	3,72	4,08	1,10	3,72	3,78	1,02	-10°C
4,22	6,60	1,56	4,05	5,41	1,34	3,88	4,23	1,09	0,00	0,00	0,00	-11°C
4,29	6,57	1,53	4,17	5,48	1,31	4,05	4,38	1,08	0,00	0,00	0,00	-12°C
4,37	6,54	1,50	4,29	5,54	1,29	4,22	4,53	1,07	0,00	0,00	0,00	-13°C
4,44	6,51	1,47	4,41	5,60	1,27	4,39	4,69	1,07	0,00	0,00	0,00	-14°C
4,51	6,49	1,44	4,53	5,66	1,25	4,55	4,84	1,06	0,00	0,00	0,00	-15°C
4,52	6,39	1,41	4,54	5,55	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
4,54	6,30	1,39	4,55	5,43	1,19	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
4,55	6,21	1,36	4,56	5,32	1,17	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
4,57	6,11	1,34	4,57	5,21	1,14	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
4,58	6,02	1,31	4,57	5,09	1,11	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
4,59	5,93	1,29	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
4,61	5,83	1,27	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
4,62	5,74	1,24	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
4,64	5,65	1,22	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
4,65	5,55	1,19	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 12 / 12TRI

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	2,16	15,48	7,16	2,65	15,48	5,84	3,00	15,32	5,11	3,54	15,30	4,32	4,04	15,39	3,81	4,54	15,54	3,42	5,04	15,73	3,12
34°C	2,15	15,45	7,18	2,64	15,45	5,85	2,98	15,29	5,12	3,54	15,27	4,31	4,04	15,36	3,80	4,54	15,51	3,42	5,03	15,70	3,12
33°C	2,14	15,42	7,19	2,63	15,42	5,86	2,97	15,26	5,13	3,54	15,24	4,31	4,03	15,33	3,80	4,53	15,48	3,42	5,03	15,67	3,12
32°C	2,14	15,39	7,21	2,62	15,39	5,87	2,96	15,23	5,14	3,53	15,21	4,30	4,03	15,30	3,79	4,53	15,45	3,41	5,02	15,64	3,11
31°C	2,13	15,36	7,22	2,61	15,36	5,89	2,95	15,20	5,16	3,53	15,18	4,30	4,03	15,27	3,79	4,52	15,42	3,41	5,02	15,63	3,11
30°C	2,12	15,33	7,23	2,60	15,33	5,90	2,94	15,17	5,17	3,53	15,15	4,29	4,02	15,24	3,79	4,52	15,39	3,41	5,01	15,63	3,12
29°C	2,11	15,30	7,25	2,59	15,30	5,91	2,93	15,14	5,18	3,52	15,12	4,29	4,02	15,20	3,78	4,51	15,36	3,40	5,01	15,63	3,12
28°C	2,10	15,27	7,26	2,58	15,27	5,92	2,91	15,11	5,19	3,52	15,08	4,29	4,01	15,17	3,78	4,51	15,33	3,40	5,00	15,63	3,12
27°C	2,09	15,23	7,28	2,57	15,23	5,93	2,90	15,08	5,20	3,52	15,05	4,28	4,01	15,14	3,78	4,50	15,30	3,40	5,00	15,63	3,13
26°C	2,08	15,20	7,29	2,56	15,20	5,94	2,89	15,05	5,21	3,51	15,02	4,28	4,01	15,11	3,77	4,50	15,28	3,40	4,99	15,63	3,13
25°C	2,08	15,17	7,31	2,55	15,17	5,96	2,88	15,02	5,22	3,51	14,99	4,27	4,00	15,08	3,77	4,50	15,28	3,40	4,99	15,63	3,13
24°C	2,07	15,14	7,32	2,54	15,14	5,97	2,87	14,99	5,23	3,51	14,96	4,27	4,00	15,05	3,77	4,49	15,28	3,40	4,98	15,63	3,14
23°C	2,06	15,11	7,34	2,53	15,11	5,98	2,86	14,96	5,24	3,50	14,94	4,26	3,99	15,02	3,76	4,49	15,28	3,41	4,98	15,63	3,14
22°C	2,05	15,08	7,35	2,52	15,08	5,99	2,84	14,93	5,25	3,50	14,91	4,26	3,99	15,00	3,76	4,48	15,28	3,41	4,97	15,63	3,14
21°C	2,04	15,05	7,37	2,51	15,05	6,00	2,83	14,90	5,26	3,50	14,88	4,26	3,99	14,97	3,75	4,48	15,28	3,41	4,97	15,63	3,15
20°C	2,04	15,02	7,38	2,50	15,02	6,02	2,82	14,87	5,27	3,49	14,85	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
19°C	2,03	14,99	7,40	2,49	14,99	6,03	2,81	14,84	5,28	3,49	14,82	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
18°C	2,02	14,96	7,41	2,48	14,96	6,04	2,80	14,81	5,29	3,48	14,79	4,24	3,97	14,94	3,76	4,46	15,28	3,42	4,95	15,63	3,16
17°C	2,01	14,93	7,42	2,47	14,93	6,05	2,79	14,78	5,30	3,48	14,76	4,24	3,97	14,94	3,76	4,46	15,28	3,43	4,95	15,63	3,16
16°C	2,00	14,90	7,44	2,46	14,90	6,06	2,78	14,75	5,31	3,48	14,73	4,23	3,97	14,94	3,77	4,46	15,28	3,43	4,94	15,63	3,16
15°C	2,00	14,87	7,45	2,45	14,87	6,08	2,77	14,72	5,32	3,47	14,70	4,23	3,96	14,94	3,77	4,45	15,28	3,43	4,94	15,63	3,16
14°C	1,99	14,84	7,47	2,44	14,84	6,09	2,76	14,69	5,33	3,47	14,67	4,23	3,96	14,94	3,77	4,45	15,28	3,44	4,93	15,63	3,17
13°C	1,98	14,81	7,48	2,43	14,81	6,10	2,74	14,66	5,34	3,47	14,64	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,93	15,63	3,17
12°C	1,97	14,78	7,50	2,42	14,78	6,11	2,73	14,63	5,35	3,46	14,61	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,92	15,63	3,17
11°C	2,04	14,72	7,20	2,47	14,72	5,95	2,80	14,60	5,22	3,46	14,59	4,22	3,95	14,94	3,78	4,43	15,28	3,45	4,92	15,63	3,18
10°C	2,11	14,65	6,93	2,52	14,65	5,80	2,86	14,57	5,10	3,46	14,59	4,22	3,94	14,94	3,79	4,43	15,28	3,45	4,91	15,63	3,18
9°C	2,19	14,59	6,67	2,58	14,59	5,66	2,92	14,54	4,98	3,45	14,59	4,23	3,94	14,94	3,79	4,42	15,28	3,45	4,91	15,63	3,18
8°C	2,26	14,52	6,43	2,63	14,52	5,52	2,99	14,51	4,86	3,45	14,59	4,23	3,94	14,94	3,80	4,42	15,28	3,46	4,90	15,63	3,19
7°C	2,33	14,45	6,21	2,68	14,45	5,39	3,02	14,45	4,79	3,45	14,59	4,23	3,93	14,94	3,80	4,42	15,28	3,46	4,90	15,63	3,19
6°C	2,72	14,45	5,32	3,24	14,43	4,46	3,55	14,41	4,05	3,94	14,50	3,68	4,35	14,73	3,38	4,77	14,96	3,14	5,18	15,20	2,93
5°C	3,02	14,45	4,79	3,66	14,42	3,93	3,97	14,38	3,62	4,32	14,41	3,34	4,68	14,55	3,11	5,04	14,69	2,91	5,41	14,83	2,74
4°C	3,24	14,45	4,47	3,97	14,40	3,63	4,27	14,35	3,36	4,59	14,35	3,13	4,91	14,41	2,93	5,24	14,47	2,76	5,56	14,53	2,61
3°C	3,36	14,45	4,29	4,15	14,39	3,46	4,45	14,33	3,22	4,75	14,29	3,01	5,05	14,29	2,83	5,36	14,30	2,67	5,66	14,30	2,53
2°C	3,41	14,45	4,24	4,22	14,37	3,41	4,51	14,30	3,17	4,81	14,22	2,96	5,10	14,15	2,77	5,40	14,08	2,61	5,69	14,00	2,46
1°C	3,40	14,25	4,19	4,21	14,18	3,37	4,50	14,08	3,13	4,80	13,99	2,91	5,10	13,90	2,73	5,40	13,88	2,57	5,69	13,78	2,42
0°C	3,39	14,05	4,14	4,18	13,99	3,34	4,48	13,85	3,09	4,78	13,75	2,87	5,09	13,65	2,68	5,40	13,69	2,54	5,68	13,56	2,39
-1°C	3,37	13,85	4,11	4,14	13,79	3,33	4,45	13,63	3,07	4,76	13,52	2,84	5,07	13,41	2,65	5,40	13,49	2,50	5,66	13,33	2,35
-2°C	3,34	13,65	4,09	4,08	13,60	3,33	4,40	13,41	3,05	4,72	13,28	2,81	5,04	13,16	2,61	5,40	13,30	2,46	5,64	13,11	2,32
-3°C	3,30	13,45	4,07	4,01	13,40	3,34	4,33	13,18	3,04	4,67	13,05	2,79	5,01	12,91	2,58	5,41	13,11	2,42	5,61	12,89	2,30
-4°C	3,26	13,25	4,07	3,92	13,21	3,37	4,25	12,96	3,05	4,61	12,81	2,78	4,97	12,66	2,55	5,41	12,91	2,39	5,57	12,67	2,27
-5°C	3,20	13,05	4,08	3,81	13,01	3,41	4,16	12,74	3,06	4,54	12,58	2,77	4,92	12,42	2,52	5,42	12,72	2,35	5,53	12,44	2,25
-6°C	3,14	12,85	4,10	3,69	12,82	3,47	4,05	12,51	3,09	4,46	12,34	2,77	4,87	12,17	2,50	5,42	12,53	2,31	5,48	12,22	2,23
-7°C	3,07	12,65	4,13	3,55	12,62	3,56	3,93	12,29	3,13	4,37	12,11	2,77	4,80	11,92	2,48	5,43	12,33	2,27	5,43	12,00	2,21
-8°C	3,21	12,57	3,92	3,66	12,50	3,41	4,05	12,23	3,02	4,47	12,05	2,69	4,90	11,86	2,42	5,45	12,08	2,22	5,58	11,80	2,12
-9°C	3,35	12,49	3,72	3,78	12,38	3,27	4,17	12,16	2,92	4,58	11,99	2,62	4,99	11,81	2,37	5,46	11,83	2,16	5,73	11,60	2,03
-10°C	3,50	12,40	3,55	3,89	12,25	3,15	4,29	12,10	2,82	4,69	11,93	2,54	5,08	11,75	2,31	5,48	11,58	2,11	5,88	11,40	1,94
-11°C	3,49	11,67	3,35	3,85	11,53	3,00	4,21	11,39	2,71	4,55	11,23	2,47	4,90	11,07	2,26	5,25	10,89	2,07	5,60	10,58	1,89
-12°C	3,48	10,93	3,15	3,80	10,81	2,84	4,12	10,68	2,59	4,42	10,54	2,38	4,72	10,40	2,20	5,02	10,20	2,03	5,32	9,76	1,84
-13°C	3,46	10,20	2,94	3,75	10,08	2,69	4,04	9,97	2,47	4,29	9,85	2,30	4,54	9,72	2,14	4,79	9,51	1,98	5,04	8,95	1,77
-14°C	3,45	9,46	2,74	3,70	9,36	2,53	3,95	9,26	2,34	4,16	9,15	2,20	4,36	9,05	2,08	4,56	8,82	1,93	4,77	8,13	1,71
-15°C	3,44	8,72	2,53	3,65	8,64	2,36															

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
5,29	15,98	3,02	6,14	16,32	2,66	7,12	16,67	2,34	0,00	0,00	0,00	35°C
5,29	15,98	3,02	6,13	16,32	2,66	7,11	16,67	2,34	0,00	0,00	0,00	34°C
5,28	15,98	3,02	6,13	16,32	2,66	7,10	16,67	2,35	0,00	0,00	0,00	33°C
5,28	15,98	3,03	6,12	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	32°C
5,27	15,98	3,03	6,11	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	31°C
5,27	15,98	3,03	6,11	16,32	2,67	7,08	16,67	2,35	0,00	0,00	0,00	30°C
5,26	15,98	3,04	6,10	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	29°C
5,26	15,98	3,04	6,09	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	28°C
5,25	15,98	3,04	6,09	16,32	2,68	7,06	16,67	2,36	0,00	0,00	0,00	27°C
5,25	15,98	3,04	6,08	16,32	2,68	7,05	16,67	2,36	0,00	0,00	0,00	26°C
5,24	15,98	3,05	6,08	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	25°C
5,24	15,98	3,05	6,07	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	24°C
5,23	15,98	3,05	6,06	16,32	2,69	7,03	16,67	2,37	0,00	0,00	0,00	23°C
5,23	15,98	3,06	6,06	16,32	2,69	7,02	16,67	2,37	0,00	0,00	0,00	22°C
5,22	15,98	3,06	6,05	16,32	2,70	7,02	16,67	2,38	0,00	0,00	0,00	21°C
5,22	15,98	3,06	6,05	16,32	2,70	7,01	16,67	2,38	0,00	0,00	0,00	20°C
5,21	15,98	3,07	6,04	16,32	2,70	7,00	16,67	2,38	8,12	17,01	2,10	19°C
5,21	15,98	3,07	6,03	16,32	2,70	7,00	16,67	2,38	8,11	17,01	2,10	18°C
5,20	15,98	3,07	6,03	16,32	2,71	6,99	16,67	2,38	8,10	17,01	2,10	17°C
5,19	15,98	3,08	6,02	16,32	2,71	6,98	16,67	2,39	8,09	17,01	2,10	16°C
5,19	15,98	3,08	6,02	16,32	2,71	6,97	16,67	2,39	8,09	17,01	2,10	15°C
5,18	15,98	3,08	6,01	16,32	2,72	6,97	16,67	2,39	8,08	17,01	2,11	14°C
5,18	15,98	3,08	6,00	16,32	2,72	6,96	16,67	2,39	8,07	17,01	2,11	13°C
5,17	15,98	3,09	6,00	16,32	2,72	6,95	16,67	2,40	8,06	17,01	2,11	12°C
5,17	15,98	3,09	5,99	16,32	2,72	6,95	16,67	2,40	8,05	17,01	2,11	11°C
5,16	15,98	3,09	5,99	16,32	2,73	6,94	16,67	2,40	8,05	17,01	2,11	10°C
5,16	15,98	3,10	5,98	16,32	2,73	6,93	16,67	2,40	8,04	17,01	2,12	9°C
5,15	15,98	3,10	5,97	16,32	2,73	6,93	16,67	2,41	8,03	17,01	2,12	8°C
5,15	15,98	3,10	5,97	16,32	2,73	6,92	16,67	2,41	8,02	17,01	2,12	7°C
5,45	15,43	2,83	6,08	15,67	2,58	6,80	15,90	2,34	7,61	16,13	2,12	6°C
5,68	14,97	2,63	6,17	15,11	2,45	6,70	15,25	2,28	7,29	15,39	2,11	5°C
5,85	14,59	2,49	6,23	14,66	2,35	6,63	14,72	2,22	7,06	14,78	2,10	4°C
5,95	14,30	2,40	6,27	14,30	2,28	6,59	14,31	2,17	6,92	14,31	2,07	3°C
5,99	13,93	2,33	6,28	13,85	2,21	6,58	13,78	2,09	6,87	13,70	1,99	2°C
5,97	13,53	2,27	6,26	13,28	2,12	6,54	13,04	1,99	6,83	12,90	1,89	1°C
5,93	13,14	2,21	6,19	12,72	2,05	6,45	12,30	1,91	6,71	12,10	1,80	0°C
5,87	12,74	2,17	6,08	12,15	2,00	6,29	11,56	1,84	6,50	11,30	1,74	-1°C
5,78	12,35	2,14	5,92	11,58	1,96	6,06	10,82	1,79	6,22	10,50	1,69	-2°C
5,66	11,95	2,11	5,72	11,02	1,93	5,77	10,08	1,75	5,85	9,70	1,66	-3°C
5,52	11,56	2,09	5,47	10,45	1,91	5,41	9,34	1,73	5,40	8,90	1,65	-4°C
5,35	11,16	2,09	5,17	9,88	1,91	4,99	8,60	1,72	4,87	8,10	1,66	-5°C
5,16	10,77	2,09	4,84	9,32	1,93	4,51	7,86	1,74	4,26	7,30	1,71	-6°C
4,94	10,38	2,10	4,45	8,75	1,97	3,96	7,13	1,80	3,56	6,50	1,82	-7°C
5,27	10,21	1,94	4,95	8,62	1,74	4,64	7,03	1,51	4,49	6,58	1,47	-8°C
5,59	10,05	1,80	5,46	8,50	1,56	5,32	6,94	1,30	5,42	6,66	1,23	-9°C
5,92	9,88	1,67	5,96	8,37	1,40	6,01	6,85	1,14	6,34	6,74	1,06	-10°C
5,64	9,20	1,63	5,68	7,83	1,38	5,71	6,45	1,13	0,00	0,00	0,00	-11°C
5,36	8,52	1,59	5,39	7,29	1,35	5,42	6,05	1,11	0,00	0,00	0,00	-12°C
5,07	7,85	1,55	5,10	6,74	1,32	5,13	5,64	1,10	0,00	0,00	0,00	-13°C
4,79	7,17	1,50	4,82	6,20	1,29	4,84	5,24	1,08	0,00	0,00	0,00	-14°C
4,51	6,49	1,44	4,53	5,66	1,25	4,55	4,84	1,06	0,00	0,00	0,00	-15°C
4,52	6,39	1,41	4,54	5,55	1,22	0,00	0,00	0,00	0,00	0,00	0,00	-16°C
4,54	6,30	1,39	4,55	5,43	1,19	0,00	0,00	0,00	0,00	0,00	0,00	-17°C
4,55	6,21	1,36	4,56	5,32	1,17	0,00	0,00	0,00	0,00	0,00	0,00	-18°C
4,57	6,11	1,34	4,57	5,21	1,14	0,00	0,00	0,00	0,00	0,00	0,00	-19°C
4,58	6,02	1,31	4,57	5,09	1,11	0,00	0,00	0,00	0,00	0,00	0,00	-20°C
4,59	5,93	1,29	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-21°C
4,61	5,83	1,27	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-22°C
4,62	5,74	1,24	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-23°C
4,64	5,65	1,22	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-24°C
4,65	5,55	1,19	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	-25°C

► Performances tables in heating mode including progressively electrical backup

▼ AUREA 2 COMPACT 3 (backup 3kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	0,65	5,60	8,60	0,80	5,60	7,02	0,91	5,48	6,06	1,05	5,46	5,19	1,22	5,46	4,49	1,38	5,46	3,96	1,55	5,46	3,54
	34°C	0,65	5,59	8,61	0,80	5,59	7,03	0,90	5,47	6,07	1,05	5,45	5,18	1,22	5,45	4,48	1,38	5,45	3,95	1,54	5,45	3,53
	33°C	0,65	5,58	8,63	0,79	5,58	7,05	0,90	5,46	6,08	1,05	5,44	5,18	1,21	5,44	4,48	1,38	5,44	3,95	1,54	5,44	3,53
	32°C	0,64	5,57	8,65	0,79	5,57	7,06	0,89	5,45	6,09	1,05	5,43	5,17	1,21	5,43	4,48	1,38	5,43	3,94	1,54	5,43	3,52
	31°C	0,64	5,56	8,67	0,79	5,56	7,08	0,89	5,44	6,11	1,05	5,42	5,17	1,21	5,42	4,47	1,38	5,42	3,94	1,54	5,42	3,52
	30°C	0,64	5,55	8,68	0,78	5,55	7,09	0,89	5,43	6,12	1,05	5,41	5,16	1,21	5,41	4,47	1,37	5,41	3,94	1,54	5,41	3,52
	29°C	0,64	5,54	8,70	0,78	5,54	7,10	0,88	5,42	6,13	1,05	5,40	5,16	1,21	5,40	4,46	1,37	5,40	3,93	1,54	5,40	3,51
	28°C	0,63	5,53	8,72	0,78	5,53	7,12	0,88	5,41	6,14	1,04	5,38	5,15	1,21	5,39	4,46	1,37	5,39	3,93	1,53	5,39	3,51
	27°C	0,63	5,52	8,73	0,77	5,52	7,13	0,88	5,40	6,15	1,04	5,37	5,15	1,21	5,37	4,45	1,37	5,38	3,92	1,53	5,38	3,51
	26°C	0,63	5,50	8,75	0,77	5,50	7,15	0,87	5,39	6,17	1,04	5,36	5,14	1,21	5,36	4,45	1,37	5,37	3,92	1,53	5,37	3,50
	25°C	0,63	5,49	8,77	0,77	5,49	7,16	0,87	5,38	6,18	1,04	5,35	5,14	1,20	5,35	4,44	1,37	5,35	3,92	1,53	5,36	3,50
	24°C	0,62	5,48	8,79	0,76	5,48	7,17	0,87	5,37	6,19	1,04	5,34	5,13	1,20	5,34	4,44	1,37	5,34	3,91	1,53	5,35	3,50
	23°C	0,62	5,47	8,80	0,76	5,47	7,19	0,86	5,35	6,20	1,04	5,33	5,13	1,20	5,33	4,44	1,36	5,33	3,91	1,53	5,33	3,49
	22°C	0,62	5,46	8,82	0,76	5,46	7,20	0,86	5,34	6,22	1,04	5,32	5,12	1,20	5,32	4,43	1,36	5,32	3,90	1,53	5,32	3,49
	21°C	0,62	5,45	8,84	0,76	5,45	7,22	0,86	5,33	6,23	1,04	5,31	5,12	1,20	5,31	4,43	1,36	5,31	3,90	1,52	5,31	3,49
	20°C	0,61	5,44	8,86	0,75	5,44	7,23	0,85	5,32	6,24	1,04	5,30	5,11	1,20	5,30	4,42	1,36	5,30	3,90	1,52	5,30	3,48
	19°C	0,61	5,43	8,88	0,75	5,43	7,25	0,85	5,31	6,25	1,04	5,29	5,11	1,20	5,29	4,42	1,36	5,29	3,89	1,52	5,29	3,48
	18°C	0,61	5,42	8,89	0,75	5,42	7,26	0,85	5,30	6,27	1,03	5,28	5,10	1,20	5,28	4,41	1,36	5,28	3,89	1,52	5,28	3,48
	17°C	0,61	5,41	8,91	0,74	5,41	7,28	0,84	5,29	6,28	1,03	5,27	5,10	1,20	5,27	4,41	1,36	5,27	3,88	1,52	5,27	3,47
	16°C	0,60	5,40	8,93	0,74	5,40	7,29	0,84	5,28	6,29	1,03	5,26	5,09	1,19	5,26	4,40	1,36	5,26	3,88	1,52	5,26	3,47
	15°C	0,60	5,38	8,95	0,74	5,38	7,30	0,84	5,27	6,30	1,03	5,25	5,09	1,19	5,25	4,40	1,35	5,25	3,88	1,52	5,25	3,47
	14°C	0,60	5,37	8,96	0,73	5,37	7,32	0,83	5,26	6,32	1,03	5,24	5,08	1,19	5,24	4,40	1,35	5,24	3,87	1,51	5,24	3,46
	13°C	0,60	5,36	8,98	0,73	5,36	7,33	0,83	5,25	6,33	1,03	5,23	5,08	1,19	5,23	4,39	1,35	5,23	3,87	1,51	5,23	3,46
	12°C	0,59	5,35	9,00	0,73	5,35	7,35	0,83	5,24	6,34	1,03	5,22	5,07	1,19	5,22	4,39	1,35	5,22	3,87	1,51	5,22	3,46
	11°C	0,75	5,41	7,19	0,87	5,41	6,24	0,95	5,32	5,60	1,13	5,30	4,68	1,29	5,30	4,10	1,45	5,30	3,65	1,61	5,30	3,28
	10°C	0,89	5,45	6,09	0,99	5,45	5,50	1,06	5,39	5,08	1,22	5,36	4,39	1,38	5,37	3,88	1,54	5,37	3,48	1,70	5,37	3,15
	9°C	1,05	5,50	5,23	1,13	5,50	4,87	1,18	5,47	4,62	1,33	5,45	4,11	1,49	5,45	3,67	1,65	5,45	3,31	1,81	5,45	3,02
	8°C	1,19	5,54	4,64	1,25	5,54	4,42	1,29	5,54	4,28	1,41	5,51	3,90	1,57	5,51	3,50	1,73	5,52	3,18	1,89	5,52	2,91
	7°C	1,40	5,64	4,04	1,44	5,64	3,93	1,45	5,64	3,88	1,56	5,64	3,61	1,72	5,64	3,28	1,88	5,65	3,00	2,04	5,65	2,77
	6°C	2,12	6,20	2,93	2,16	6,18	2,86	2,21	6,16	2,79	2,32	6,14	2,65	2,45	6,12	2,49	2,59	6,10	2,35	2,73	6,08	2,23
	5°C	2,70	6,65	2,46	2,76	6,62	2,40	2,83	6,58	2,33	2,93	6,54	2,23	3,05	6,50	2,13	3,17	6,46	2,04	3,29	6,42	1,95
	4°C	3,18	7,03	2,21	3,24	6,98	2,15	3,33	6,93	2,08	3,43	6,87	2,01	3,54	6,82	1,93	3,64	6,77	1,86	3,75	6,71	1,79
3°C	3,56	7,34	2,06	3,63	7,27	2,01	3,72	7,21	1,94	3,82	7,14	1,87	3,92	7,08	1,81	4,02	7,01	1,75	4,12	6,95	1,69	
2°C	4,02	7,72	1,92	4,08	7,64	1,87	4,18	7,56	1,81	4,28	7,48	1,75	4,38	7,40	1,69	4,47	7,32	1,64	4,57	7,24	1,58	
1°C	4,02	7,75	1,93	4,09	7,66	1,87	4,18	7,53	1,80	4,28	7,46	1,74	4,38	7,38	1,69	4,48	7,30	1,63	4,57	7,18	1,57	
0°C	4,03	7,77	1,93	4,09	7,68	1,88	4,18	7,51	1,80	4,28	7,43	1,74	4,38	7,36	1,68	4,49	7,28	1,62	4,58	7,12	1,56	
-1°C	4,03	7,80	1,93	4,10	7,69	1,88	4,19	7,48	1,79	4,29	7,41	1,73	4,39	7,33	1,67	4,50	7,26	1,61	4,58	7,06	1,54	
-2°C	4,04	7,83	1,94	4,12	7,71	1,87	4,19	7,46	1,78	4,30	7,38	1,72	4,40	7,31	1,66	4,52	7,23	1,60	4,59	7,00	1,53	
-3°C	4,05	7,85	1,94	4,14	7,73	1,87	4,19	7,43	1,77	4,31	7,36	1,71	4,42	7,29	1,65	4,55	7,21	1,58	4,60	6,94	1,51	
-4°C	4,07	7,88	1,94	4,16	7,75	1,86	4,20	7,41	1,76	4,32	7,34	1,70	4,44	7,27	1,64	4,59	7,19	1,57	4,61	6,88	1,49	
-5°C	4,09	7,91	1,94	4,19	7,77	1,85	4,20	7,38	1,76	4,33	7,31	1,69	4,46	7,24	1,62	4,63	7,17	1,55	4,63	6,82	1,47	
-6°C	4,10	7,94	1,93	4,22	7,78	1,84	4,21	7,36	1,75	4,35	7,29	1,68	4,49	7,22	1,61	4,68	7,15	1,53	4,65	6,76	1,45	
-7°C	4,13	7,96	1,93	4,26	7,80	1,83	4,22	7,33	1,74	4,37	7,27	1,66	4,52	7,20	1,59	4,74	7,13	1,51	4,67	6,70	1,44	
-8°C	4,12	7,88	1,91	4,25	7,70	1,81	4,26	7,30	1,71	4,41	7,25	1,64	4,55	7,19	1,58	4,74	7,13	1,51	4,74	6,83	1,44	
-9°C	4,11	7,79	1,90	4,23	7,59	1,79	4,31	7,28	1,69	4,44	7,23	1,63	4,58	7,18	1,57	4,74	7,13	1,51	4,80	6,97	1,45	
-10°C	4,09	7,71	1,88	4,22	7,48	1,77	4,35	7,25	1,67	4,48	7,21	1,61	4,61	7,18	1,56	4,74	7,14	1,51	4,87	7,10	1,46	
-11°C	4,11	7,52	1,83	4,24	7,32	1,73	4,36	7,12	1,63	4,48	7,08	1,58	4,60	7,03	1,53	4,72	6,98	1,48	4,84	6,87	1,42	
-12°C	4,13	7,33	1,77	4,25	7,16	1,69	4,37	6,99	1,60	4,48	6,94	1,55	4,58	6,89	1,50	4,69	6,81	1,45	4,80	6,65	1,38	
-13°C	4,15	7,14	1,72	4,26	7,00	1,64	4,37	6,87	1,57	4,47	6,81	1,52	4,57	6,75	1,48	4,67	6,65	1,42	4,77	6,42	1,35	
-14°C	4,17	6,95	1,67	4,28	6,84	1,60	4,38	6,74	1,54	4,47	6,67	1,49	4,56	6,60	1,45	4,64	6,49	1,40	4,73	6,19	1,31	
-15°C	4,19	6,76	1,61	4,29	6,69	1,56	4,39	6,61	1,51	4,49	6,54	1,46	4,59	6,46	1,41	4,67	6,33	1,35	4,70	5,97	1,27	
-16°C	4,16	6,64	1,59	4,26	6,57	1,54	4,36	6,50	1,49	4,45	6,42	1,45	4,53	6,35	1,40	4,61	6,23	1,35	4,69	5,92	1,26	
-17°C	4,14	6,51																				

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,62	5,47	3,37	1,88	5,47	2,90	2,18	5,47	2,51	0,00	0,00	0,00	35°C
1,62	5,45	3,36	1,88	5,46	2,90	2,18	5,46	2,50	0,00	0,00	0,00	34°C
1,62	5,44	3,36	1,88	5,45	2,90	2,18	5,45	2,50	0,00	0,00	0,00	33°C
1,62	5,43	3,36	1,88	5,43	2,90	2,18	5,44	2,50	0,00	0,00	0,00	32°C
1,62	5,42	3,35	1,88	5,42	2,89	2,17	5,43	2,50	0,00	0,00	0,00	31°C
1,62	5,41	3,35	1,87	5,41	2,89	2,17	5,42	2,49	0,00	0,00	0,00	30°C
1,61	5,40	3,35	1,87	5,40	2,89	2,17	5,40	2,49	0,00	0,00	0,00	29°C
1,61	5,39	3,34	1,87	5,39	2,88	2,17	5,39	2,49	0,00	0,00	0,00	28°C
1,61	5,38	3,34	1,87	5,38	2,88	2,17	5,38	2,49	0,00	0,00	0,00	27°C
1,61	5,37	3,34	1,87	5,37	2,88	2,16	5,37	2,48	0,00	0,00	0,00	26°C
1,61	5,36	3,33	1,86	5,36	2,88	2,16	5,36	2,48	0,00	0,00	0,00	25°C
1,61	5,35	3,33	1,86	5,35	2,87	2,16	5,35	2,48	0,00	0,00	0,00	24°C
1,60	5,34	3,33	1,86	5,34	2,87	2,16	5,34	2,48	0,00	0,00	0,00	23°C
1,60	5,33	3,32	1,86	5,33	2,87	2,15	5,33	2,47	0,00	0,00	0,00	22°C
1,60	5,32	3,32	1,86	5,32	2,86	2,15	5,32	2,47	0,00	0,00	0,00	21°C
1,60	5,30	3,32	1,85	5,31	2,86	2,15	5,31	2,47	0,00	0,00	0,00	20°C
1,60	5,29	3,31	1,85	5,30	2,86	2,15	5,30	2,47	2,49	5,30	2,13	19°C
1,60	5,28	3,31	1,85	5,29	2,86	2,15	5,29	2,46	2,49	5,29	2,13	18°C
1,60	5,27	3,31	1,85	5,27	2,85	2,14	5,28	2,46	2,49	5,28	2,12	17°C
1,59	5,26	3,30	1,85	5,26	2,85	2,14	5,27	2,46	2,48	5,27	2,12	16°C
1,59	5,25	3,30	1,85	5,25	2,85	2,14	5,26	2,46	2,48	5,26	2,12	15°C
1,59	5,24	3,30	1,84	5,24	2,84	2,14	5,25	2,45	2,48	5,25	2,12	14°C
1,59	5,23	3,29	1,84	5,23	2,84	2,14	5,23	2,45	2,48	5,24	2,12	13°C
1,59	5,22	3,29	1,84	5,22	2,84	2,13	5,22	2,45	2,47	5,23	2,11	12°C
1,69	5,30	3,14	1,94	5,30	2,73	2,24	5,31	2,37	2,58	5,31	2,06	11°C
1,78	5,37	3,02	2,03	5,37	2,64	2,32	5,37	2,31	2,66	5,38	2,02	10°C
1,88	5,45	2,90	2,13	5,45	2,56	2,43	5,46	2,25	2,77	5,46	1,97	9°C
1,97	5,52	2,80	2,22	5,52	2,48	2,51	5,52	2,20	2,85	5,52	1,94	8°C
2,12	5,65	2,67	2,37	5,66	2,39	2,66	5,66	2,13	3,00	5,66	1,89	7°C
2,81	6,06	2,16	3,01	6,04	2,01	3,23	6,02	1,86	3,48	6,00	1,72	6°C
3,38	6,39	1,89	3,53	6,35	1,80	3,70	6,31	1,71	3,88	6,27	1,62	5°C
3,84	6,66	1,73	3,97	6,61	1,67	4,09	6,55	1,60	4,23	6,50	1,54	4°C
4,21	6,88	1,63	4,32	6,82	1,58	4,42	6,76	1,53	4,53	6,69	1,48	3°C
4,67	7,16	1,53	4,76	7,08	1,49	4,86	7,00	1,44	4,96	6,92	1,40	2°C
4,66	7,08	1,52	4,76	6,98	1,47	4,85	6,88	1,42	4,94	6,80	1,38	1°C
4,65	7,00	1,50	4,73	6,89	1,45	4,81	6,77	1,41	4,89	6,67	1,36	0°C
4,64	6,92	1,49	4,69	6,79	1,45	4,75	6,65	1,40	4,81	6,55	1,36	-1°C
4,61	6,85	1,48	4,64	6,69	1,44	4,66	6,54	1,40	4,69	6,43	1,37	-2°C
4,58	6,77	1,48	4,57	6,59	1,44	4,55	6,42	1,41	4,54	6,31	1,39	-3°C
4,55	6,69	1,47	4,48	6,50	1,45	4,41	6,31	1,43	4,36	6,18	1,42	-4°C
4,50	6,61	1,47	4,37	6,40	1,46	4,25	6,19	1,46	4,14	6,06	1,47	-5°C
4,45	6,53	1,47	4,25	6,30	1,48	4,06	6,08	1,50	3,88	5,94	1,53	-6°C
4,39	6,45	1,47	4,12	6,21	1,51	3,85	5,96	1,55	3,60	5,81	1,62	-7°C
4,56	6,49	1,42	4,38	6,15	1,40	4,20	5,81	1,38	4,08	5,71	1,40	-8°C
4,72	6,53	1,38	4,64	6,10	1,31	4,56	5,66	1,24	4,55	5,60	1,23	-9°C
4,89	6,57	1,34	4,91	6,04	1,23	4,92	5,51	1,12	5,03	5,49	1,09	-10°C
4,86	6,38	1,31	4,87	5,88	1,21	4,89	5,39	1,10	3,00	3,00	1,00	-11°C
4,82	6,18	1,28	4,84	5,72	1,18	4,86	5,26	1,08	3,00	3,00	1,00	-12°C
4,79	5,99	1,25	4,81	5,56	1,16	4,83	5,13	1,06	3,00	3,00	1,00	-13°C
4,75	5,80	1,22	4,78	5,40	1,13	4,80	5,01	1,04	3,00	3,00	1,00	-14°C
4,72	5,60	1,19	4,75	5,24	1,10	4,77	4,88	1,02	3,00	3,00	1,00	-15°C
4,71	5,56	1,18	4,73	5,19	1,10	3,00	3,00	1,00	3,00	3,00	1,00	-16°C
4,70	5,51	1,17	4,72	5,14	1,09	3,00	3,00	1,00	3,00	3,00	1,00	-17°C
4,69	5,46	1,16	4,71	5,09	1,08	3,00	3,00	1,00	3,00	3,00	1,00	-18°C
4,68	5,41	1,16	4,69	5,04	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-19°C
4,67	5,36	1,15	4,68	4,98	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-20°C
4,65	5,31	1,14	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-21°C
4,64	5,26	1,13	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-22°C
4,63	5,21	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-23°C
4,62	5,16	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-24°C
4,61	5,11	1,11	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-25°C

▼ AUREA 2 COMPACT 4 (backup 3kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	0,79	6,57	8,28	0,98	6,57	6,71	1,11	6,43	5,79	1,30	6,39	4,93	1,49	6,39	4,28	1,69	6,39	3,78	1,89	6,39	3,39
34°C	0,79	6,56	8,30	0,98	6,56	6,72	1,11	6,41	5,80	1,30	6,38	4,92	1,49	6,38	4,27	1,69	6,37	3,78	1,88	6,37	3,38
33°C	0,79	6,55	8,31	0,97	6,55	6,73	1,10	6,40	5,81	1,29	6,37	4,92	1,49	6,36	4,27	1,69	6,36	3,77	1,88	6,36	3,38
32°C	0,78	6,54	8,33	0,97	6,54	6,75	1,10	6,39	5,82	1,29	6,35	4,91	1,49	6,35	4,26	1,69	6,35	3,77	1,88	6,35	3,38
31°C	0,78	6,52	8,35	0,96	6,52	6,76	1,09	6,38	5,83	1,29	6,34	4,91	1,49	6,34	4,26	1,68	6,34	3,76	1,88	6,34	3,37
30°C	0,78	6,51	8,36	0,96	6,51	6,78	1,09	6,36	5,85	1,29	6,33	4,90	1,49	6,33	4,26	1,68	6,32	3,76	1,88	6,32	3,37
29°C	0,78	6,50	8,38	0,96	6,50	6,79	1,08	6,35	5,86	1,29	6,32	4,90	1,48	6,31	4,25	1,68	6,31	3,76	1,88	6,31	3,37
28°C	0,77	6,48	8,40	0,95	6,48	6,80	1,08	6,34	5,87	1,29	6,30	4,89	1,48	6,30	4,25	1,68	6,30	3,75	1,87	6,30	3,36
27°C	0,77	6,47	8,41	0,95	6,47	6,82	1,08	6,33	5,88	1,29	6,29	4,89	1,48	6,29	4,24	1,68	6,29	3,75	1,87	6,28	3,36
26°C	0,77	6,46	8,43	0,95	6,46	6,83	1,07	6,31	5,89	1,29	6,28	4,88	1,48	6,27	4,24	1,67	6,27	3,75	1,87	6,27	3,35
25°C	0,76	6,44	8,45	0,94	6,44	6,84	1,07	6,30	5,90	1,28	6,27	4,88	1,48	6,26	4,23	1,67	6,26	3,74	1,87	6,26	3,35
24°C	0,76	6,43	8,46	0,94	6,43	6,86	1,06	6,29	5,92	1,28	6,25	4,87	1,48	6,25	4,23	1,67	6,25	3,74	1,87	6,25	3,35
23°C	0,76	6,42	8,48	0,93	6,42	6,87	1,06	6,27	5,93	1,28	6,24	4,87	1,48	6,24	4,23	1,67	6,24	3,73	1,86	6,23	3,34
22°C	0,75	6,41	8,50	0,93	6,41	6,88	1,05	6,26	5,94	1,28	6,23	4,86	1,47	6,22	4,22	1,67	6,22	3,73	1,86	6,22	3,34
21°C	0,75	6,39	8,51	0,93	6,39	6,90	1,05	6,25	5,95	1,28	6,22	4,86	1,47	6,21	4,22	1,67	6,21	3,73	1,86	6,21	3,34
20°C	0,75	6,38	8,53	0,92	6,38	6,91	1,05	6,24	5,96	1,28	6,20	4,85	1,47	6,20	4,21	1,66	6,20	3,72	1,86	6,20	3,33
19°C	0,74	6,37	8,55	0,92	6,37	6,93	1,04	6,22	5,98	1,28	6,19	4,85	1,47	6,19	4,21	1,66	6,19	3,72	1,86	6,18	3,33
18°C	0,74	6,36	8,56	0,92	6,36	6,94	1,04	6,21	5,99	1,28	6,18	4,84	1,47	6,18	4,20	1,66	6,17	3,72	1,85	6,17	3,33
17°C	0,74	6,34	8,58	0,91	6,34	6,95	1,03	6,20	6,00	1,27	6,17	4,84	1,47	6,16	4,20	1,66	6,16	3,71	1,85	6,16	3,32
16°C	0,74	6,33	8,60	0,91	6,33	6,97	1,03	6,19	6,01	1,27	6,15	4,83	1,47	6,15	4,20	1,66	6,15	3,71	1,85	6,15	3,32
15°C	0,73	6,32	8,62	0,90	6,32	6,98	1,03	6,18	6,02	1,27	6,14	4,83	1,46	6,14	4,19	1,66	6,14	3,70	1,85	6,14	3,32
14°C	0,73	6,30	8,63	0,90	6,30	6,99	1,02	6,16	6,04	1,27	6,13	4,82	1,46	6,13	4,19	1,65	6,12	3,70	1,85	6,12	3,31
13°C	0,73	6,29	8,65	0,90	6,29	7,01	1,02	6,15	6,05	1,27	6,12	4,82	1,46	6,11	4,18	1,65	6,11	3,70	1,85	6,11	3,31
12°C	0,72	6,28	8,67	0,89	6,28	7,02	1,01	6,14	6,06	1,27	6,11	4,82	1,46	6,10	4,18	1,65	6,10	3,69	1,84	6,10	3,31
11°C	0,88	6,33	7,16	1,03	6,32	6,12	1,14	6,22	5,44	1,37	6,18	4,51	1,56	6,18	3,95	1,76	6,18	3,52	1,95	6,18	3,17
10°C	1,03	6,36	6,19	1,16	6,35	5,49	1,26	6,28	5,00	1,46	6,24	4,28	1,65	6,24	3,78	1,84	6,24	3,38	2,03	6,24	3,07
9°C	1,19	6,40	5,40	1,30	6,40	4,93	1,38	6,35	4,59	1,56	6,32	4,04	1,76	6,32	3,60	1,95	6,31	3,24	2,14	6,31	2,95
8°C	1,33	6,43	4,84	1,42	6,43	4,52	1,50	6,42	4,28	1,65	6,38	3,86	1,84	6,38	3,46	2,04	6,38	3,13	2,23	6,38	2,86
7°C	1,53	6,52	4,26	1,61	6,52	4,06	1,66	6,51	3,92	1,80	6,51	3,61	1,99	6,51	3,27	2,18	6,52	2,98	2,37	6,52	2,75
6°C	2,29	7,16	3,12	2,37	7,13	3,01	2,45	7,10	2,90	2,58	7,07	2,74	2,75	7,05	2,56	2,91	7,02	2,41	3,08	7,00	2,27
5°C	2,91	7,68	2,64	2,99	7,63	2,55	3,09	7,58	2,45	3,22	7,53	2,34	3,36	7,48	2,22	3,51	7,43	2,12	3,66	7,39	2,02
4°C	3,41	8,12	2,38	3,50	8,05	2,30	3,61	7,98	2,21	3,73	7,91	2,12	3,87	7,84	2,03	4,00	7,78	1,94	4,13	7,71	1,87
3°C	3,81	8,47	2,22	3,89	8,38	2,15	4,01	8,30	2,07	4,13	8,22	1,99	4,26	8,14	1,91	4,38	8,06	1,84	4,51	7,97	1,77
2°C	4,27	8,90	2,09	4,36	8,80	2,02	4,48	8,70	1,94	4,60	8,60	1,87	4,72	8,50	1,80	4,84	8,40	1,74	4,96	8,30	1,67
1°C	4,27	8,93	2,09	4,36	8,80	2,02	4,48	8,67	1,94	4,60	8,57	1,86	4,72	8,47	1,80	4,84	8,30	1,71	4,96	8,21	1,65
0°C	4,28	8,96	2,09	4,37	8,80	2,02	4,48	8,64	1,93	4,60	8,54	1,86	4,72	8,45	1,79	4,84	8,20	1,70	4,97	8,12	1,63
-1°C	4,30	8,98	2,09	4,38	8,80	2,01	4,49	8,61	1,92	4,60	8,51	1,85	4,72	8,42	1,79	4,83	8,10	1,68	4,98	8,02	1,61
-2°C	4,32	9,01	2,09	4,40	8,80	2,00	4,51	8,58	1,90	4,61	8,48	1,84	4,71	8,39	1,78	4,82	8,00	1,66	4,99	7,93	1,59
-3°C	4,35	9,04	2,08	4,42	8,79	1,99	4,52	8,54	1,89	4,62	8,45	1,83	4,71	8,37	1,78	4,81	7,90	1,64	5,01	7,84	1,56
-4°C	4,38	9,07	2,07	4,45	8,79	1,98	4,54	8,51	1,87	4,62	8,43	1,82	4,71	8,34	1,77	4,80	7,80	1,63	5,03	7,75	1,54
-5°C	4,42	9,09	2,06	4,48	8,79	1,96	4,57	8,48	1,86	4,63	8,40	1,81	4,70	8,31	1,77	4,78	7,70	1,61	5,06	7,65	1,51
-6°C	4,47	9,12	2,04	4,52	8,79	1,94	4,59	8,45	1,84	4,64	8,37	1,80	4,70	8,28	1,76	4,76	7,60	1,60	5,09	7,56	1,49
-7°C	4,52	9,15	2,02	4,56	8,79	1,93	4,62	8,42	1,82	4,66	8,34	1,79	4,69	8,26	1,76	4,74	7,50	1,58	5,12	7,47	1,46
-8°C	4,51	9,03	2,00	4,56	8,66	1,90	4,61	8,28	1,80	4,65	8,12	1,75	4,69	7,95	1,70	4,73	7,34	1,55	5,00	7,21	1,44
-9°C	4,51	8,91	1,98	4,55	8,53	1,87	4,60	8,14	1,77	4,64	7,90	1,70	4,68	7,65	1,63	4,73	7,18	1,52	4,89	6,96	1,42
-10°C	4,50	8,80	1,95	4,55	8,40	1,85	4,59	8,00	1,74	4,64	7,68	1,66	4,68	7,35	1,57	4,73	7,03	1,49	4,77	6,70	1,40
-11°C	4,48	8,52	1,90	4,54	8,19	1,80	4,60	7,85	1,71	4,65	7,57	1,63	4,71	7,29	1,55	4,76	7,00	1,47	4,82	6,66	1,38
-12°C	4,46	8,25	1,85	4,54	7,97	1,76	4,61	7,70	1,67	4,67	7,47	1,60	4,73	7,24	1,53	4,80	6,98	1,46	4,86	6,62	1,36
-13°C	4,44	7,97	1,79	4,53	7,76	1,71	4,62	7,55	1,63	4,69	7,37	1,57	4,76	7,18	1,51	4,83	6,96	1,44	4,91	6,57	1,34
-14°C	4,42	7,70	1,74	4,52	7,55	1,67	4,63	7,40	1,60	4,71	7,26	1,54	4,79	7,13	1,49	4,87	6,94	1,42	4,95	6,53	1,32
-15°C	4,40	7,42	1,69	4,52	7,34	1,62	4,63	7,25	1,56	4,75	7,16	1,51	4,87	7,07	1,45	4,97	6,91	1,39	5,00	6,49	1,30
-16°C	4,37	7,28	1,67	4,49	7,19	1,60	4,61	7,11	1,54	4,70	7,03	1,50	4,80	6,95	1,45	4,89	6,81	1,39	4,99	6,43	1,29

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,98	6,39	3,22	2,30	6,39	2,78	2,66	6,39	2,40	0,00	0,00	0,00	35°C
1,98	6,37	3,22	2,30	6,37	2,78	2,66	6,38	2,40	0,00	0,00	0,00	34°C
1,98	6,36	3,22	2,29	6,36	2,77	2,66	6,36	2,39	0,00	0,00	0,00	33°C
1,98	6,35	3,21	2,29	6,35	2,77	2,66	6,35	2,39	0,00	0,00	0,00	32°C
1,97	6,34	3,21	2,29	6,34	2,77	2,65	6,34	2,39	0,00	0,00	0,00	31°C
1,97	6,32	3,21	2,29	6,32	2,77	2,65	6,32	2,39	0,00	0,00	0,00	30°C
1,97	6,31	3,20	2,28	6,31	2,76	2,65	6,31	2,38	0,00	0,00	0,00	29°C
1,97	6,30	3,20	2,28	6,30	2,76	2,65	6,30	2,38	0,00	0,00	0,00	28°C
1,97	6,28	3,20	2,28	6,29	2,76	2,64	6,29	2,38	0,00	0,00	0,00	27°C
1,96	6,27	3,19	2,28	6,27	2,75	2,64	6,27	2,38	0,00	0,00	0,00	26°C
1,96	6,26	3,19	2,28	6,26	2,75	2,64	6,26	2,37	0,00	0,00	0,00	25°C
1,96	6,25	3,19	2,27	6,25	2,75	2,63	6,25	2,37	0,00	0,00	0,00	24°C
1,96	6,23	3,18	2,27	6,24	2,75	2,63	6,24	2,37	0,00	0,00	0,00	23°C
1,96	6,22	3,18	2,27	6,22	2,74	2,63	6,22	2,37	0,00	0,00	0,00	22°C
1,95	6,21	3,18	2,27	6,21	2,74	2,63	6,21	2,36	0,00	0,00	0,00	21°C
1,95	6,20	3,17	2,26	6,20	2,74	2,62	6,20	2,36	0,00	0,00	0,00	20°C
1,95	6,19	3,17	2,26	6,19	2,74	2,62	6,19	2,36	3,04	6,19	2,04	19°C
1,95	6,17	3,17	2,26	6,17	2,73	2,62	6,17	2,36	3,04	6,18	2,03	18°C
1,95	6,16	3,16	2,26	6,16	2,73	2,62	6,16	2,36	3,03	6,16	2,03	17°C
1,94	6,15	3,16	2,25	6,15	2,73	2,61	6,15	2,35	3,03	6,15	2,03	16°C
1,94	6,14	3,16	2,25	6,14	2,72	2,61	6,14	2,35	3,03	6,14	2,03	15°C
1,94	6,12	3,15	2,25	6,12	2,72	2,61	6,13	2,35	3,02	6,13	2,03	14°C
1,94	6,11	3,15	2,25	6,11	2,72	2,61	6,11	2,35	3,02	6,11	2,02	13°C
1,94	6,10	3,15	2,25	6,10	2,72	2,60	6,10	2,34	3,02	6,10	2,02	12°C
2,04	6,18	3,03	2,35	6,18	2,63	2,71	6,18	2,28	3,12	6,18	1,98	11°C
2,13	6,24	2,93	2,44	6,24	2,56	2,79	6,24	2,23	3,21	6,24	1,95	10°C
2,23	6,31	2,83	2,54	6,31	2,49	2,90	6,32	2,18	3,31	6,32	1,91	9°C
2,32	6,38	2,75	2,63	6,38	2,43	2,98	6,38	2,14	3,40	6,39	1,88	8°C
2,47	6,52	2,64	2,77	6,53	2,35	3,13	6,53	2,09	3,54	6,54	1,84	7°C
3,18	6,98	2,19	3,42	6,95	2,03	3,70	6,93	1,87	4,00	6,91	1,72	6°C
3,77	7,34	1,95	3,96	7,29	1,84	4,16	7,25	1,74	4,39	7,20	1,64	5°C
4,25	7,65	1,80	4,40	7,58	1,72	4,56	7,51	1,65	4,73	7,45	1,58	4°C
4,63	7,89	1,71	4,76	7,81	1,64	4,89	7,73	1,58	5,02	7,65	1,52	3°C
5,08	8,20	1,61	5,21	8,10	1,56	5,33	8,00	1,50	5,45	7,90	1,45	2°C
5,09	8,11	1,59	5,22	8,02	1,54	5,34	7,93	1,48	5,47	7,88	1,44	1°C
5,11	8,03	1,57	5,25	7,94	1,51	5,40	7,86	1,46	5,54	7,86	1,42	0°C
5,15	7,94	1,54	5,32	7,87	1,48	5,48	7,79	1,42	5,65	7,83	1,39	-1°C
5,20	7,86	1,51	5,40	7,79	1,44	5,60	7,72	1,38	5,81	7,81	1,34	-2°C
5,26	7,77	1,48	5,51	7,71	1,40	5,76	7,65	1,33	6,02	7,79	1,29	-3°C
5,34	7,69	1,44	5,64	7,63	1,35	5,95	7,58	1,27	6,27	7,77	1,24	-4°C
5,43	7,60	1,40	5,80	7,56	1,30	6,17	7,51	1,22	6,57	7,75	1,18	-5°C
5,54	7,52	1,36	5,98	7,48	1,25	6,43	7,44	1,16	6,91	7,72	1,12	-6°C
5,66	7,44	1,31	6,19	7,40	1,20	6,73	7,37	1,09	7,30	7,70	1,06	-7°C
5,34	6,97	1,30	5,68	6,73	1,18	6,02	6,48	1,08	6,42	6,64	1,03	-8°C
5,03	6,50	1,29	5,18	6,05	1,17	5,32	5,60	1,05	5,54	5,58	1,01	-9°C
4,72	6,04	1,28	4,67	5,38	1,15	4,62	4,72	1,02	4,66	4,51	0,97	-10°C
4,78	6,04	1,26	4,75	5,43	1,14	4,71	4,82	1,02	3,00	3,00	1,00	-11°C
4,84	6,05	1,25	4,82	5,48	1,14	4,80	4,92	1,02	3,00	3,00	1,00	-12°C
4,90	6,05	1,23	4,90	5,53	1,13	4,90	5,02	1,02	3,00	3,00	1,00	-13°C
4,96	6,06	1,22	4,98	5,59	1,12	4,99	5,11	1,02	3,00	3,00	1,00	-14°C
5,03	6,06	1,21	5,05	5,64	1,12	5,08	5,21	1,03	3,00	3,00	1,00	-15°C
5,01	6,01	1,20	5,04	5,58	1,11	3,00	3,00	1,00	3,00	3,00	1,00	-16°C
5,00	5,95	1,19	5,02	5,52	1,10	3,00	3,00	1,00	3,00	3,00	1,00	-17°C
4,99	5,89	1,18	5,01	5,46	1,09	3,00	3,00	1,00	3,00	3,00	1,00	-18°C
4,97	5,83	1,17	4,99	5,40	1,08	3,00	3,00	1,00	3,00	3,00	1,00	-19°C
4,96	5,77	1,16	4,97	5,34	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-20°C
4,95	5,71	1,16	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-21°C
4,93	5,66	1,15	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-22°C
4,92	5,60	1,14	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-23°C
4,91	5,54	1,13	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-24°C
4,89	5,48	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-25°C

▼ AUREA 2 COMPACT 5 (backup 6kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1,26	8,92	7,08	1,45	8,83	6,09	1,59	8,59	5,39	1,79	8,48	4,75	1,98	8,40	4,24	2,17	8,31	3,83	2,37	8,23	3,48
34°C	1,26	8,90	7,09	1,44	8,81	6,10	1,59	8,58	5,40	1,78	8,46	4,74	1,98	8,38	4,24	2,17	8,30	3,82	2,37	8,21	3,47
33°C	1,25	8,89	7,11	1,44	8,80	6,12	1,58	8,56	5,41	1,78	8,45	4,74	1,98	8,36	4,23	2,17	8,28	3,82	2,36	8,20	3,47
32°C	1,25	8,87	7,12	1,43	8,78	6,13	1,57	8,54	5,43	1,78	8,43	4,73	1,97	8,35	4,23	2,17	8,26	3,81	2,36	8,18	3,47
31°C	1,24	8,85	7,14	1,43	8,76	6,14	1,57	8,52	5,44	1,78	8,41	4,73	1,97	8,33	4,22	2,17	8,25	3,81	2,36	8,16	3,46
30°C	1,24	8,83	7,15	1,42	8,74	6,15	1,56	8,51	5,45	1,78	8,39	4,72	1,97	8,31	4,22	2,16	8,23	3,80	2,36	8,15	3,46
29°C	1,23	8,82	7,16	1,42	8,73	6,16	1,56	8,49	5,46	1,78	8,38	4,72	1,97	8,30	4,21	2,16	8,21	3,80	2,35	8,13	3,45
28°C	1,23	8,80	7,18	1,41	8,71	6,18	1,55	8,47	5,47	1,77	8,36	4,71	1,97	8,28	4,21	2,16	8,20	3,80	2,35	8,11	3,45
27°C	1,22	8,78	7,19	1,40	8,69	6,19	1,54	8,46	5,48	1,77	8,34	4,71	1,96	8,26	4,21	2,16	8,18	3,79	2,35	8,10	3,45
26°C	1,22	8,76	7,21	1,40	8,67	6,20	1,54	8,44	5,49	1,77	8,33	4,70	1,96	8,24	4,20	2,15	8,16	3,79	2,35	8,08	3,44
25°C	1,21	8,75	7,22	1,39	8,66	6,21	1,53	8,42	5,50	1,77	8,31	4,70	1,96	8,23	4,20	2,15	8,15	3,78	2,34	8,06	3,44
24°C	1,21	8,73	7,24	1,39	8,64	6,23	1,52	8,41	5,51	1,77	8,29	4,69	1,96	8,21	4,19	2,15	8,13	3,78	2,34	8,05	3,44
23°C	1,20	8,71	7,25	1,38	8,62	6,24	1,52	8,39	5,52	1,76	8,28	4,69	1,96	8,19	4,19	2,15	8,11	3,78	2,34	8,03	3,43
22°C	1,20	8,69	7,26	1,38	8,60	6,25	1,51	8,37	5,53	1,76	8,26	4,69	1,95	8,18	4,18	2,15	8,10	3,77	2,34	8,01	3,43
21°C	1,19	8,68	7,28	1,37	8,59	6,26	1,51	8,36	5,55	1,76	8,24	4,68	1,95	8,16	4,18	2,14	8,08	3,77	2,33	8,00	3,43
20°C	1,19	8,66	7,29	1,37	8,57	6,28	1,50	8,34	5,56	1,76	8,23	4,68	1,95	8,14	4,18	2,14	8,06	3,77	2,33	7,98	3,42
19°C	1,18	8,64	7,31	1,36	8,55	6,29	1,49	8,32	5,57	1,76	8,21	4,67	1,95	8,13	4,17	2,14	8,05	3,76	2,33	7,96	3,42
18°C	1,18	8,62	7,32	1,35	8,54	6,30	1,49	8,31	5,58	1,76	8,19	4,67	1,95	8,11	4,17	2,14	8,03	3,76	2,33	7,95	3,41
17°C	1,17	8,61	7,34	1,35	8,52	6,31	1,48	8,29	5,59	1,75	8,18	4,66	1,94	8,10	4,16	2,13	8,01	3,75	2,33	7,93	3,41
16°C	1,17	8,59	7,35	1,34	8,50	6,33	1,48	8,27	5,60	1,75	8,16	4,66	1,94	8,08	4,16	2,13	8,00	3,75	2,32	7,91	3,41
15°C	1,16	8,57	7,37	1,34	8,49	6,34	1,47	8,26	5,61	1,75	8,15	4,65	1,94	8,06	4,15	2,13	7,98	3,75	2,32	7,90	3,40
14°C	1,16	8,56	7,38	1,33	8,47	6,35	1,47	8,24	5,62	1,75	8,13	4,65	1,94	8,05	4,15	2,13	7,96	3,74	2,32	7,88	3,40
13°C	1,15	8,54	7,40	1,33	8,45	6,36	1,46	8,22	5,64	1,75	8,11	4,64	1,94	8,03	4,15	2,13	7,95	3,74	2,32	7,86	3,40
12°C	1,15	8,52	7,41	1,32	8,43	6,38	1,45	8,21	5,65	1,75	8,10	4,64	1,93	8,01	4,14	2,12	7,93	3,73	2,31	7,85	3,39
11°C	1,40	8,65	6,20	1,56	8,56	5,49	1,69	8,37	4,95	1,95	8,26	4,23	2,14	8,18	3,82	2,33	8,10	3,47	2,52	8,01	3,18
10°C	1,61	8,75	5,43	1,77	8,66	4,90	1,90	8,51	4,49	2,13	8,40	3,94	2,32	8,31	3,58	2,51	8,23	3,28	2,70	8,15	3,02
9°C	1,86	8,88	4,78	2,00	8,79	4,39	2,13	8,67	4,07	2,34	8,56	3,66	2,53	8,48	3,35	2,72	8,39	3,09	2,91	8,31	2,86
8°C	2,07	8,98	4,33	2,21	8,89	4,02	2,34	8,81	3,77	2,52	8,69	3,45	2,71	8,61	3,18	2,90	8,53	2,95	3,08	8,45	2,74
7°C	2,41	9,20	3,81	2,54	9,11	3,59	2,65	9,03	3,40	2,82	8,95	3,18	3,01	8,87	2,95	3,19	8,78	2,75	3,38	8,70	2,57
6°C	3,88	10,10	2,60	4,00	10,05	2,51	4,13	9,99	2,42	4,29	9,94	2,32	4,47	9,88	2,21	4,64	9,83	2,12	4,82	9,78	2,03
5°C	5,08	10,83	2,13	5,20	10,80	2,08	5,33	10,77	2,02	5,49	10,74	1,96	5,65	10,71	1,89	5,82	10,68	1,84	5,98	10,65	1,78
4°C	6,06	11,44	1,89	6,18	11,43	1,85	6,32	11,42	1,81	6,48	11,41	1,76	6,63	11,40	1,72	6,79	11,39	1,68	6,95	11,38	1,64
3°C	6,83	11,94	1,75	6,94	11,94	1,72	7,09	11,95	1,68	7,25	11,95	1,65	7,40	11,96	1,62	7,55	11,96	1,58	7,70	11,97	1,55
2°C	7,75	12,55	1,62	7,86	12,57	1,60	8,01	12,60	1,57	8,16	12,62	1,55	8,31	12,65	1,52	8,47	12,68	1,50	8,62	12,70	1,47
1°C	7,75	12,57	1,62	7,87	12,58	1,60	8,02	12,59	1,57	8,17	12,60	1,54	8,32	12,61	1,52	8,47	12,64	1,49	8,61	12,57	1,46
0°C	7,77	12,58	1,62	7,88	12,59	1,60	8,03	12,58	1,57	8,18	12,58	1,54	8,33	12,58	1,51	8,48	12,61	1,49	8,61	12,43	1,44
-1°C	7,80	12,60	1,62	7,91	12,60	1,59	8,05	12,57	1,56	8,20	12,56	1,53	8,35	12,54	1,50	8,50	12,58	1,48	8,59	12,30	1,43
-2°C	7,83	12,62	1,61	7,95	12,61	1,59	8,09	12,56	1,55	8,23	12,53	1,52	8,37	12,51	1,49	8,52	12,54	1,47	8,57	12,17	1,42
-3°C	7,88	12,63	1,60	8,00	12,61	1,58	8,13	12,56	1,54	8,27	12,51	1,51	8,41	12,47	1,48	8,56	12,51	1,46	8,55	12,03	1,41
-4°C	7,94	12,65	1,59	8,06	12,62	1,57	8,18	12,55	1,53	8,31	12,49	1,50	8,45	12,43	1,47	8,60	12,48	1,45	8,52	11,90	1,40
-5°C	8,02	12,67	1,58	8,13	12,63	1,55	8,25	12,54	1,52	8,37	12,47	1,49	8,49	12,40	1,46	8,64	12,44	1,44	8,48	11,77	1,39
-6°C	8,10	12,68	1,57	8,21	12,64	1,54	8,32	12,53	1,51	8,43	12,44	1,48	8,55	12,36	1,45	8,70	12,41	1,43	8,44	11,63	1,38
-7°C	8,19	12,70	1,55	8,31	12,64	1,52	8,40	12,52	1,49	8,50	12,42	1,46	8,61	12,32	1,43	8,76	12,38	1,41	8,39	11,50	1,37
-8°C	8,13	12,50	1,54	8,26	12,35	1,50	8,37	12,15	1,45	8,49	12,14	1,43	8,62	12,13	1,41	8,77	12,23	1,39	8,58	11,70	1,36
-9°C	8,07	12,31	1,53	8,21	12,05	1,47	8,34	11,77	1,41	8,48	11,86	1,40	8,62	11,94	1,38	8,78	12,08	1,38	8,76	11,90	1,36
-10°C	8,00	12,11	1,51	8,16	11,76	1,44	8,32	11,40	1,37	8,47	11,58	1,37	8,63	11,75	1,36	8,79	11,93	1,36	8,95	12,10	1,35
-11°C	8,03	12,07	1,50	8,18	11,74	1,44	8,33	11,42	1,37	8,48	11,51	1,36	8,62	11,61	1,35	8,77	11,70	1,33	8,91	11,72	1,31
-12°C	8,05	12,02	1,49	8,20	11,73	1,43	8,35	11,43	1,37	8,48	11,45	1,35	8,62	11,48	1,33	8,75	11,47	1,31	8,88	11,34	1,28
-13°C	8,08	11,98	1,48	8,22	11,71	1,42	8,36	11,45	1,37	8,49	11,39	1,34	8,61	11,34	1,32	8,73	11,24	1,29	8,85	10,96	1,24
-14°C	8,10	11,93	1,47	8,24	11,70	1,42	8,38	11,46	1,37	8,49	11,33	1,33	8,60	11,20	1,30	8,71	11,01	1,26	8,82	10,58	1,20
-15°C	8,13	11,89	1,46	8,26	11,68	1,41	8,39	11,48	1,37	8,53	11,27	1,32	8,66	11,06	1,28	8,77	10,78	1,23	8,79	10,20	1,16
-16°C	8,12	11,63	1,43	8,25	11,																

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,49	8,15	3,28	2,88	8,07	2,80	3,34	7,98	2,39	0,00	0,00	0,00	35°C
2,49	8,13	3,27	2,88	8,05	2,79	3,34	7,97	2,39	0,00	0,00	0,00	34°C
2,48	8,11	3,27	2,88	8,03	2,79	3,34	7,95	2,38	0,00	0,00	0,00	33°C
2,48	8,10	3,27	2,88	8,02	2,79	3,33	7,93	2,38	0,00	0,00	0,00	32°C
2,48	8,08	3,26	2,87	8,00	2,78	3,33	7,92	2,38	0,00	0,00	0,00	31°C
2,48	8,06	3,26	2,87	7,98	2,78	3,33	7,90	2,37	0,00	0,00	0,00	30°C
2,47	8,05	3,25	2,87	7,96	2,78	3,32	7,88	2,37	0,00	0,00	0,00	29°C
2,47	8,03	3,25	2,86	7,95	2,78	3,32	7,86	2,37	0,00	0,00	0,00	28°C
2,47	8,01	3,25	2,86	7,93	2,77	3,32	7,85	2,37	0,00	0,00	0,00	27°C
2,47	8,00	3,24	2,86	7,91	2,77	3,31	7,83	2,36	0,00	0,00	0,00	26°C
2,46	7,98	3,24	2,86	7,90	2,77	3,31	7,81	2,36	0,00	0,00	0,00	25°C
2,46	7,96	3,24	2,85	7,88	2,76	3,31	7,80	2,36	0,00	0,00	0,00	24°C
2,46	7,95	3,23	2,85	7,86	2,76	3,30	7,78	2,36	0,00	0,00	0,00	23°C
2,46	7,93	3,23	2,85	7,85	2,76	3,30	7,76	2,35	0,00	0,00	0,00	22°C
2,45	7,91	3,23	2,84	7,83	2,75	3,30	7,75	2,35	0,00	0,00	0,00	21°C
2,45	7,90	3,22	2,84	7,81	2,75	3,29	7,73	2,35	0,00	0,00	0,00	20°C
2,45	7,88	3,22	2,84	7,80	2,75	3,29	7,71	2,34	3,81	7,63	2,00	19°C
2,45	7,86	3,22	2,84	7,78	2,74	3,29	7,70	2,34	3,81	7,62	2,00	18°C
2,44	7,85	3,21	2,83	7,76	2,74	3,28	7,68	2,34	3,81	7,60	2,00	17°C
2,44	7,83	3,21	2,83	7,75	2,74	3,28	7,67	2,34	3,80	7,58	1,99	16°C
2,44	7,81	3,20	2,83	7,73	2,74	3,28	7,65	2,33	3,80	7,57	1,99	15°C
2,44	7,80	3,20	2,82	7,72	2,73	3,27	7,63	2,33	3,80	7,55	1,99	14°C
2,43	7,78	3,20	2,82	7,70	2,73	3,27	7,62	2,33	3,79	7,53	1,99	13°C
2,43	7,77	3,19	2,82	7,68	2,73	3,27	7,60	2,33	3,79	7,52	1,98	12°C
2,64	7,93	3,01	3,03	7,85	2,59	3,47	7,76	2,24	3,99	7,68	1,92	11°C
2,82	8,06	2,86	3,20	7,98	2,49	3,65	7,90	2,16	4,17	7,82	1,87	10°C
3,02	8,23	2,72	3,41	8,15	2,39	3,86	8,06	2,09	4,38	7,98	1,82	9°C
3,20	8,36	2,61	3,59	8,28	2,31	4,03	8,20	2,03	4,55	8,12	1,78	8°C
3,50	8,62	2,46	3,88	8,53	2,20	4,33	8,45	1,95	4,85	8,37	1,73	7°C
4,94	9,72	1,97	5,25	9,67	1,84	5,59	9,61	1,72	5,97	9,56	1,60	6°C
6,12	10,62	1,73	6,36	10,59	1,67	6,62	10,56	1,60	6,90	10,53	1,53	5°C
7,09	11,37	1,60	7,28	11,36	1,56	7,48	11,35	1,52	7,69	11,34	1,47	4°C
7,85	11,97	1,52	8,02	11,98	1,49	8,18	11,99	1,47	8,34	11,99	1,44	3°C
8,77	12,73	1,45	8,92	12,75	1,43	9,07	12,78	1,41	9,22	12,80	1,39	2°C
8,75	12,41	1,42	8,90	12,26	1,38	9,04	12,11	1,34	9,18	12,00	1,31	1°C
8,71	12,10	1,39	8,82	11,77	1,33	8,93	11,44	1,28	9,04	11,21	1,24	0°C
8,65	11,79	1,36	8,70	11,28	1,30	8,76	10,77	1,23	8,82	10,41	1,18	-1°C
8,55	11,48	1,34	8,53	10,79	1,26	8,51	10,10	1,19	8,50	9,61	1,13	-2°C
8,43	11,16	1,32	8,31	10,30	1,24	8,20	9,43	1,15	8,09	8,81	1,09	-3°C
8,28	10,85	1,31	8,05	9,81	1,22	7,81	8,76	1,12	7,59	8,02	1,06	-4°C
8,11	10,54	1,30	7,73	9,31	1,20	7,36	8,09	1,10	7,01	7,22	1,03	-5°C
7,90	10,23	1,29	7,37	8,82	1,20	6,83	7,42	1,09	6,33	6,42	1,01	-6°C
7,67	9,92	1,29	6,96	8,33	1,20	6,24	6,75	1,08	5,56	5,63	1,01	-7°C
8,09	10,43	1,29	7,61	9,16	1,20	7,13	7,89	1,11	6,72	7,18	1,07	-8°C
8,51	10,94	1,29	8,27	9,99	1,21	8,02	9,03	1,13	7,88	8,73	1,11	-9°C
8,93	11,46	1,28	8,92	10,82	1,21	8,91	10,17	1,14	9,04	10,28	1,14	-10°C
8,91	11,09	1,25	8,90	10,46	1,18	8,89	9,83	1,11	6,00	6,00	1,00	-11°C
8,88	10,72	1,21	8,88	10,11	1,14	8,88	9,49	1,07	6,00	6,00	1,00	-12°C
8,85	10,36	1,17	8,86	9,75	1,10	8,86	9,15	1,03	6,00	6,00	1,00	-13°C
8,83	9,99	1,13	8,84	9,40	1,06	8,85	8,80	1,00	6,00	6,00	1,00	-14°C
8,80	9,62	1,09	8,82	9,04	1,03	8,83	8,46	0,96	6,00	6,00	1,00	-15°C
8,79	9,53	1,08	8,80	8,96	1,02	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
8,78	9,44	1,07	8,78	8,87	1,01	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
8,77	9,34	1,07	8,76	8,79	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
8,76	9,25	1,06	8,75	8,70	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
8,75	9,16	1,05	8,73	8,62	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
8,75	9,07	1,04	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
8,74	8,97	1,03	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
8,73	8,88	1,02	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
8,72	8,79	1,01	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
8,71	8,70	1,00	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 COMPACT 7 / 7TRI (backup 6kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	1,12	9,21	8,20	1,46	9,21	6,33	1,68	9,15	5,44	2,04	9,14	4,49	2,39	9,21	3,86	2,73	9,33	3,42	3,08	9,58	3,11
	34°C	1,12	9,19	8,22	1,45	9,19	6,34	1,67	9,13	5,45	2,04	9,13	4,48	2,38	9,19	3,86	2,73	9,31	3,41	3,08	9,58	3,11
	33°C	1,11	9,18	8,23	1,44	9,18	6,35	1,67	9,11	5,46	2,03	9,11	4,48	2,38	9,18	3,85	2,73	9,31	3,42	3,07	9,58	3,12
	32°C	1,11	9,16	8,25	1,44	9,16	6,37	1,66	9,10	5,48	2,03	9,09	4,47	2,38	9,16	3,85	2,72	9,31	3,42	3,07	9,58	3,12
	31°C	1,11	9,14	8,27	1,43	9,14	6,38	1,65	9,08	5,49	2,03	9,07	4,47	2,38	9,14	3,85	2,72	9,31	3,42	3,07	9,58	3,12
	30°C	1,10	9,12	8,28	1,43	9,12	6,39	1,65	9,06	5,50	2,03	9,05	4,46	2,37	9,12	3,84	2,72	9,31	3,43	3,06	9,58	3,13
	29°C	1,10	9,10	8,30	1,42	9,10	6,40	1,64	9,04	5,51	2,03	9,03	4,46	2,37	9,10	3,84	2,72	9,31	3,43	3,06	9,58	3,13
	28°C	1,09	9,09	8,32	1,42	9,09	6,42	1,64	9,02	5,52	2,02	9,02	4,45	2,37	9,09	3,84	2,71	9,31	3,43	3,06	9,58	3,13
	27°C	1,09	9,07	8,33	1,41	9,07	6,43	1,63	9,01	5,53	2,02	9,00	4,45	2,37	9,07	3,83	2,71	9,31	3,44	3,05	9,58	3,14
	26°C	1,08	9,05	8,35	1,40	9,05	6,44	1,62	8,99	5,54	2,02	8,98	4,45	2,36	9,05	3,83	2,71	9,31	3,44	3,05	9,58	3,14
	25°C	1,08	9,03	8,37	1,40	9,03	6,46	1,62	8,97	5,55	2,02	8,96	4,44	2,36	9,04	3,83	2,70	9,31	3,44	3,05	9,58	3,14
	24°C	1,08	9,01	8,38	1,39	9,01	6,47	1,61	8,95	5,56	2,02	8,94	4,44	2,36	9,04	3,83	2,70	9,31	3,45	3,05	9,58	3,15
	23°C	1,07	9,00	8,40	1,39	9,00	6,48	1,60	8,93	5,57	2,01	8,93	4,43	2,36	9,04	3,84	2,70	9,31	3,45	3,04	9,58	3,15
	22°C	1,07	8,98	8,42	1,38	8,98	6,49	1,60	8,92	5,59	2,01	8,91	4,43	2,35	9,04	3,84	2,70	9,31	3,45	3,04	9,58	3,15
	21°C	1,06	8,96	8,43	1,38	8,96	6,51	1,59	8,90	5,60	2,01	8,89	4,42	2,35	9,04	3,85	2,69	9,31	3,46	3,04	9,58	3,16
	20°C	1,06	8,94	8,45	1,37	8,94	6,52	1,58	8,88	5,61	2,01	8,87	4,42	2,35	9,04	3,85	2,69	9,31	3,46	3,03	9,58	3,16
	19°C	1,05	8,92	8,47	1,37	8,92	6,53	1,58	8,86	5,62	2,01	8,86	4,41	2,35	9,04	3,85	2,69	9,31	3,46	3,03	9,58	3,16
	18°C	1,05	8,91	8,48	1,36	8,91	6,55	1,57	8,85	5,63	2,00	8,84	4,41	2,35	9,04	3,86	2,69	9,31	3,47	3,03	9,58	3,17
	17°C	1,05	8,89	8,50	1,35	8,89	6,56	1,56	8,83	5,64	2,00	8,82	4,41	2,34	9,04	3,86	2,68	9,31	3,47	3,02	9,58	3,17
	16°C	1,04	8,87	8,52	1,35	8,87	6,57	1,56	8,81	5,65	2,00	8,80	4,40	2,34	9,04	3,86	2,68	9,31	3,47	3,02	9,58	3,17
	15°C	1,04	8,85	8,53	1,34	8,85	6,59	1,55	8,79	5,66	2,00	8,79	4,40	2,34	9,04	3,87	2,68	9,31	3,48	3,02	9,58	3,17
	14°C	1,03	8,83	8,55	1,34	8,83	6,60	1,55	8,78	5,68	2,00	8,78	4,40	2,34	9,04	3,87	2,68	9,31	3,48	3,01	9,58	3,18
	13°C	1,03	8,82	8,57	1,33	8,82	6,61	1,54	8,76	5,69	1,99	8,78	4,40	2,33	9,04	3,88	2,67	9,31	3,48	3,01	9,58	3,18
	12°C	1,02	8,80	8,59	1,33	8,80	6,63	1,53	8,74	5,70	1,99	8,78	4,41	2,33	9,04	3,88	2,67	9,31	3,49	3,01	9,58	3,18
	11°C	1,31	8,98	6,84	1,59	8,98	5,65	1,79	8,94	5,01	2,20	8,99	4,08	2,54	9,25	3,65	2,88	9,52	3,31	3,22	9,79	3,04
	10°C	1,57	9,14	5,82	1,82	9,14	5,02	2,01	9,11	4,54	2,38	9,17	3,85	2,72	9,43	3,47	3,05	9,70	3,18	3,39	9,97	2,94
	9°C	1,86	9,32	5,01	2,08	9,32	4,48	2,26	9,30	4,12	2,59	9,38	3,63	2,92	9,64	3,30	3,26	9,91	3,04	3,60	10,18	2,83
	8°C	2,12	9,48	4,48	2,31	9,48	4,10	2,48	9,47	3,82	2,76	9,56	3,46	3,10	9,82	3,17	3,44	10,09	2,93	3,78	10,36	2,74
	7°C	2,50	9,75	3,91	2,66	9,75	3,66	2,80	9,75	3,49	3,06	9,86	3,22	3,40	10,12	2,98	3,74	10,39	2,78	4,07	10,66	2,62
	6°C	3,96	10,51	2,65	4,08	10,51	2,58	4,22	10,52	2,49	4,45	10,61	2,38	4,72	10,81	2,29	4,99	11,01	2,21	5,26	11,22	2,13
	5°C	5,15	11,11	2,16	5,24	11,12	2,12	5,39	11,14	2,07	5,58	11,20	2,01	5,80	11,35	1,96	6,01	11,50	1,91	6,23	11,65	1,87
	4°C	6,13	11,62	1,90	6,20	11,64	1,88	6,34	11,65	1,84	6,51	11,71	1,80	6,70	11,81	1,76	6,88	11,92	1,73	7,06	12,02	1,70
	3°C	6,90	12,04	1,74	6,95	12,06	1,73	7,10	12,08	1,70	7,26	12,12	1,67	7,41	12,19	1,64	7,57	12,26	1,62	7,73	12,33	1,59
	2°C	7,82	12,55	1,61	7,86	12,57	1,60	8,01	12,60	1,57	8,16	12,62	1,55	8,31	12,65	1,52	8,47	12,68	1,50	8,62	12,70	1,47
	1°C	7,82	12,80	1,64	7,87	12,77	1,62	8,02	12,75	1,59	8,17	12,76	1,56	8,32	12,77	1,53	8,47	12,69	1,50	8,62	12,68	1,47
0°C	7,85	13,05	1,66	7,89	12,97	1,64	8,04	12,90	1,60	8,19	12,89	1,57	8,33	12,88	1,55	8,48	12,70	1,50	8,63	12,66	1,47	
-1°C	7,88	13,30	1,69	7,93	13,17	1,66	8,08	13,05	1,62	8,22	13,02	1,58	8,36	13,00	1,56	8,50	12,71	1,49	8,65	12,64	1,46	
-2°C	7,94	13,55	1,71	7,99	13,36	1,67	8,13	13,19	1,62	8,26	13,16	1,59	8,39	13,12	1,56	8,53	12,72	1,49	8,68	12,61	1,45	
-3°C	8,00	13,80	1,72	8,06	13,56	1,68	8,19	13,34	1,63	8,31	13,29	1,60	8,44	13,23	1,57	8,57	12,73	1,49	8,72	12,59	1,44	
-4°C	8,09	14,05	1,74	8,14	13,76	1,69	8,27	13,49	1,63	8,38	13,42	1,60	8,49	13,35	1,57	8,61	12,74	1,48	8,77	12,57	1,43	
-5°C	8,18	14,30	1,75	8,25	13,96	1,69	8,36	13,64	1,63	8,46	13,56	1,60	8,55	13,47	1,57	8,66	12,75	1,47	8,82	12,55	1,42	
-6°C	8,30	14,55	1,75	8,36	14,16	1,69	8,47	13,79	1,63	8,55	13,69	1,60	8,62	13,58	1,58	8,72	12,76	1,46	8,88	12,52	1,41	
-7°C	8,42	14,80	1,76	8,50	14,36	1,69	8,59	13,94	1,62	8,65	13,82	1,60	8,71	13,70	1,57	8,79	12,77	1,45	8,95	12,50	1,40	
-8°C	8,42	14,64	1,74	8,50	14,17	1,67	8,59	13,73	1,60	8,66	13,55	1,56	8,73	13,37	1,53	8,81	12,65	1,44	8,95	12,37	1,38	
-9°C	8,41	14,48	1,72	8,50	13,99	1,65	8,59	13,51	1,57	8,67	13,27	1,53	8,75	13,03	1,49	8,83	12,52	1,42	8,95	12,23	1,37	
-10°C	8,41	14,32	1,70	8,50	13,81	1,63	8,59	13,30	1,55	8,68	13,00	1,50	8,77	12,70	1,45	8,86	12,40	1,40	8,95	12,10	1,35	
-11°C	8,35	13,84	1,66	8,45	13,39	1,58	8,55	12,94	1,51	8,64	12,65	1,46	8,73	12,37	1,42	8,82	12,08	1,37	8,91	11,72	1,31	
-12°C	8,30	13,35	1,61	8,40	12,96	1,54	8,51	12,57	1,48	8,60	12,31	1,43	8,70	12,05	1,39	8,79	11,75	1,34	8,88	11,34	1,28	
-13°C	8,24	12,86	1,56	8,36	12,53	1,50	8,47	12,21	1,44	8,57	11,96	1,40	8,66	11,72	1,35	8,76	11,43	1,31	8,85	10,96	1,2,	

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
3,23	9,85	3,04	3,75	10,12	2,70	4,35	10,38	2,39	0,00	0,00	0,00	35°C
3,23	9,85	3,05	3,75	10,12	2,70	4,34	10,38	2,39	0,00	0,00	0,00	34°C
3,23	9,85	3,05	3,74	10,12	2,70	4,34	10,38	2,39	0,00	0,00	0,00	33°C
3,23	9,85	3,05	3,74	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	32°C
3,22	9,85	3,06	3,74	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	31°C
3,22	9,85	3,06	3,73	10,12	2,71	4,33	10,38	2,40	0,00	0,00	0,00	30°C
3,22	9,85	3,06	3,73	10,12	2,71	4,32	10,38	2,40	0,00	0,00	0,00	29°C
3,21	9,85	3,07	3,72	10,12	2,72	4,32	10,38	2,41	0,00	0,00	0,00	28°C
3,21	9,85	3,07	3,72	10,12	2,72	4,31	10,38	2,41	0,00	0,00	0,00	27°C
3,21	9,85	3,07	3,72	10,12	2,72	4,31	10,38	2,41	0,00	0,00	0,00	26°C
3,20	9,85	3,07	3,71	10,12	2,72	4,30	10,38	2,41	0,00	0,00	0,00	25°C
3,20	9,85	3,08	3,71	10,12	2,73	4,30	10,38	2,41	0,00	0,00	0,00	24°C
3,20	9,85	3,08	3,71	10,12	2,73	4,30	10,38	2,42	0,00	0,00	0,00	23°C
3,19	9,85	3,08	3,70	10,12	2,73	4,29	10,38	2,42	0,00	0,00	0,00	22°C
3,19	9,85	3,09	3,70	10,12	2,74	4,29	10,38	2,42	0,00	0,00	0,00	21°C
3,19	9,85	3,09	3,69	10,12	2,74	4,28	10,38	2,42	0,00	0,00	0,00	20°C
3,18	9,85	3,09	3,69	10,12	2,74	4,28	10,38	2,43	4,96	10,65	2,15	19°C
3,18	9,85	3,10	3,69	10,12	2,74	4,27	10,38	2,43	4,96	10,65	2,15	18°C
3,18	9,85	3,10	3,68	10,12	2,75	4,27	10,38	2,43	4,95	10,65	2,15	17°C
3,17	9,85	3,10	3,68	10,12	2,75	4,27	10,38	2,43	4,95	10,65	2,15	16°C
3,17	9,85	3,11	3,68	10,12	2,75	4,26	10,38	2,44	4,94	10,65	2,16	15°C
3,17	9,85	3,11	3,67	10,12	2,75	4,26	10,38	2,44	4,94	10,65	2,16	14°C
3,16	9,85	3,11	3,67	10,12	2,76	4,25	10,38	2,44	4,93	10,65	2,16	13°C
3,16	9,85	3,11	3,66	10,12	2,76	4,25	10,38	2,44	4,93	10,65	2,16	12°C
3,37	10,06	2,99	3,87	10,33	2,67	4,45	10,59	2,38	5,13	10,86	2,12	11°C
3,55	10,24	2,89	4,05	10,51	2,60	4,63	10,77	2,33	5,31	11,04	2,08	10°C
3,75	10,45	2,78	4,25	10,72	2,52	4,84	10,98	2,27	5,51	11,25	2,04	9°C
3,93	10,63	2,71	4,43	10,90	2,46	5,01	11,16	2,23	5,69	11,43	2,01	8°C
4,23	10,93	2,59	4,73	11,20	2,37	5,31	11,46	2,16	5,98	11,73	1,96	7°C
5,41	11,42	2,11	5,78	11,62	2,01	6,21	11,83	1,90	6,70	12,03	1,80	6°C
6,38	11,80	1,85	6,66	11,95	1,79	6,97	12,10	1,74	7,31	12,25	1,68	5°C
7,21	12,13	1,68	7,42	12,23	1,65	7,64	12,34	1,62	7,87	12,44	1,58	4°C
7,88	12,40	1,57	8,05	12,47	1,55	8,22	12,54	1,53	8,39	12,61	1,50	3°C
8,77	12,73	1,45	8,92	12,75	1,43	9,07	12,78	1,41	9,22	12,81	1,39	2°C
8,77	12,66	1,44	8,92	12,63	1,42	9,08	12,61	1,39	9,23	12,65	1,37	1°C
8,79	12,59	1,43	8,94	12,51	1,40	9,09	12,44	1,37	9,24	12,49	1,35	0°C
8,81	12,51	1,42	8,96	12,39	1,38	9,11	12,27	1,35	9,27	12,33	1,33	-1°C
8,84	12,44	1,41	8,99	12,27	1,36	9,15	12,10	1,32	9,31	12,17	1,31	-2°C
8,88	12,37	1,39	9,03	12,15	1,35	9,19	11,93	1,30	9,36	12,01	1,28	-3°C
8,92	12,30	1,38	9,08	12,03	1,32	9,24	11,76	1,27	9,42	11,85	1,26	-4°C
8,98	12,23	1,36	9,14	11,91	1,30	9,30	11,59	1,25	9,49	11,69	1,23	-5°C
9,05	12,16	1,34	9,21	11,79	1,28	9,37	11,42	1,22	9,57	11,53	1,21	-6°C
9,12	12,08	1,33	9,28	11,67	1,26	9,45	11,25	1,19	9,66	11,38	1,18	-7°C
9,04	11,78	1,30	9,12	11,18	1,23	9,21	10,59	1,15	9,38	10,61	1,13	-8°C
8,96	11,47	1,28	8,96	10,70	1,19	8,97	9,93	1,11	9,09	9,85	1,08	-9°C
8,88	11,16	1,26	8,80	10,22	1,16	8,73	9,28	1,06	8,81	9,09	1,03	-10°C
8,86	10,85	1,22	8,81	9,98	1,13	8,75	9,11	1,04	6,00	6,00	1,00	-11°C
8,85	10,54	1,19	8,81	9,75	1,11	8,77	8,95	1,02	6,00	6,00	1,00	-12°C
8,83	10,24	1,16	8,81	9,51	1,08	8,79	8,79	1,00	6,00	6,00	1,00	-13°C
8,82	9,93	1,13	8,81	9,28	1,05	8,81	8,62	0,98	6,00	6,00	1,00	-14°C
8,80	9,62	1,09	8,82	9,04	1,03	8,83	8,46	0,96	6,00	6,00	1,00	-15°C
8,79	9,53	1,08	8,80	8,96	1,02	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
8,78	9,44	1,07	8,78	8,87	1,01	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
8,77	9,34	1,07	8,76	8,79	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
8,76	9,25	1,06	8,75	8,70	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
8,75	9,16	1,05	8,73	8,62	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
8,75	9,07	1,04	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
8,74	8,97	1,03	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
8,73	8,88	1,02	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
8,72	8,79	1,01	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
8,71	8,70	1,00	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 COMPACT 9 (backup 6kW)

	Starting temperature																					
	25°C			30°C			35°C			40°C			45°C			50°C			55°C			
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
Outdoor temperature	35°C	1.82	13.38	7.36	2.29	13.38	5.85	2.61	13.20	5.06	3.15	13.17	4.19	3.62	13.22	3.65	4.10	13.32	3.25	4.57	13.44	2.94
	34°C	1.81	13.35	7.37	2.28	13.35	5.86	2.60	13.17	5.07	3.14	13.14	4.18	3.62	13.20	3.65	4.09	13.29	3.25	4.57	13.41	2.93
	33°C	1.80	13.33	7.39	2.27	13.33	5.87	2.59	13.15	5.08	3.14	13.11	4.18	3.61	13.17	3.64	4.09	13.26	3.24	4.56	13.38	2.93
	32°C	1.80	13.30	7.40	2.26	13.30	5.88	2.58	13.12	5.09	3.14	13.09	4.17	3.61	13.14	3.64	4.09	13.24	3.24	4.56	13.36	2.93
	31°C	1.79	13.27	7.42	2.25	13.27	5.90	2.57	13.09	5.10	3.13	13.06	4.17	3.61	13.12	3.64	4.08	13.21	3.24	4.56	13.33	2.93
	30°C	1.78	13.25	7.43	2.24	13.25	5.91	2.56	13.07	5.11	3.13	13.04	4.16	3.60	13.09	3.63	4.08	13.19	3.23	4.55	13.30	2.92
	29°C	1.78	13.22	7.45	2.23	13.22	5.92	2.55	13.04	5.12	3.13	13.01	4.16	3.60	13.07	3.63	4.07	13.16	3.23	4.55	13.28	2.92
	28°C	1.77	13.19	7.46	2.22	13.19	5.93	2.54	13.02	5.13	3.12	12.98	4.16	3.60	13.04	3.63	4.07	13.13	3.23	4.54	13.25	2.92
	27°C	1.76	13.17	7.48	2.22	13.17	5.94	2.53	12.99	5.14	3.12	12.96	4.15	3.59	13.01	3.62	4.07	13.11	3.22	4.54	13.23	2.92
	26°C	1.75	13.14	7.49	2.21	13.14	5.96	2.52	12.96	5.15	3.12	12.93	4.15	3.59	12.99	3.62	4.06	13.08	3.22	4.53	13.20	2.91
	25°C	1.75	13.12	7.51	2.20	13.12	5.97	2.51	12.94	5.16	3.11	12.91	4.14	3.59	12.96	3.61	4.06	13.06	3.22	4.53	13.17	2.91
	24°C	1.74	13.09	7.52	2.19	13.09	5.98	2.50	12.91	5.17	3.11	12.88	4.14	3.58	12.94	3.61	4.05	13.03	3.22	4.52	13.15	2.91
	23°C	1.73	13.06	7.54	2.18	13.06	5.99	2.49	12.89	5.18	3.11	12.86	4.14	3.58	12.91	3.61	4.05	13.01	3.21	4.52	13.12	2.90
	22°C	1.73	13.04	7.55	2.17	13.04	6.00	2.48	12.86	5.19	3.11	12.83	4.13	3.57	12.88	3.60	4.04	12.98	3.21	4.51	13.12	2.91
	21°C	1.72	13.01	7.57	2.16	13.01	6.02	2.47	12.84	5.20	3.10	12.80	4.13	3.57	12.86	3.60	4.04	12.95	3.21	4.51	13.12	2.91
	20°C	1.71	12.99	7.58	2.15	12.99	6.03	2.46	12.81	5.21	3.10	12.78	4.12	3.57	12.83	3.60	4.04	12.93	3.20	4.51	13.12	2.91
	19°C	1.71	12.96	7.60	2.15	12.96	6.04	2.45	12.78	5.22	3.10	12.75	4.12	3.56	12.81	3.59	4.03	12.91	3.20	4.50	13.12	2.91
	18°C	1.70	12.93	7.61	2.14	12.93	6.05	2.44	12.76	5.23	3.09	12.73	4.12	3.56	12.78	3.59	4.03	12.91	3.20	4.50	13.12	2.92
	17°C	1.69	12.91	7.63	2.13	12.91	6.06	2.43	12.73	5.24	3.09	12.70	4.11	3.56	12.76	3.59	4.02	12.91	3.21	4.49	13.12	2.92
	16°C	1.69	12.88	7.64	2.12	12.88	6.08	2.42	12.71	5.25	3.09	12.68	4.11	3.55	12.73	3.58	4.02	12.91	3.21	4.49	13.12	2.92
	15°C	1.68	12.86	7.66	2.11	12.86	6.09	2.41	12.68	5.26	3.08	12.65	4.10	3.55	12.71	3.58	4.02	12.91	3.21	4.48	13.12	2.93
	14°C	1.67	12.83	7.67	2.10	12.83	6.10	2.40	12.66	5.27	3.08	12.63	4.10	3.55	12.70	3.58	4.01	12.91	3.22	4.48	13.12	2.93
	13°C	1.67	12.80	7.69	2.10	12.80	6.11	2.39	12.63	5.28	3.08	12.60	4.09	3.54	12.70	3.58	4.01	12.91	3.22	4.47	13.12	2.93
	12°C	1.66	12.78	7.70	2.09	12.78	6.12	2.38	12.61	5.29	3.07	12.58	4.09	3.54	12.70	3.59	4.00	12.91	3.22	4.47	13.12	2.94
	11°C	1.93	12.91	6.68	2.34	12.91	5.51	2.65	12.78	4.82	3.28	12.75	3.89	3.75	12.91	3.45	4.21	13.12	3.12	4.68	13.33	2.85
	10°C	2.18	13.02	5.98	2.57	13.02	5.06	2.89	12.93	4.47	3.46	12.90	3.73	3.92	13.09	3.34	4.39	13.30	3.03	4.85	13.51	2.79
	9°C	2.45	13.15	5.36	2.83	13.15	4.65	3.16	13.10	4.15	3.67	13.08	3.57	4.13	13.30	3.22	4.59	13.51	2.94	5.06	13.72	2.71
	8°C	2.70	13.26	4.91	3.06	13.26	4.34	3.40	13.25	3.90	3.84	13.26	3.45	4.31	13.48	3.13	4.77	13.69	2.87	5.23	13.90	2.66
	7°C	3.06	13.48	4.40	3.41	13.48	3.96	3.73	13.48	3.62	4.14	13.56	3.28	4.60	13.78	2.99	5.06	13.99	2.76	5.53	14.20	2.57
	6°C	4.69	14.60	3.11	5.00	14.55	2.91	5.30	14.51	2.74	5.66	14.52	2.56	6.06	14.63	2.42	6.45	14.74	2.29	6.84	14.85	2.17
	5°C	6.01	15.51	2.58	6.30	15.43	2.45	6.59	15.34	2.33	6.91	15.30	2.22	7.24	15.32	2.12	7.58	15.34	2.02	7.92	15.37	1.94
	4°C	7.08	16.27	2.30	7.35	16.16	2.20	7.63	16.04	2.10	7.92	15.95	2.01	8.22	15.90	1.93	8.52	15.85	1.86	8.82	15.80	1.79
3°C	7.90	16.89	2.14	8.16	16.74	2.05	8.43	16.60	1.97	8.71	16.47	1.89	8.98	16.37	1.82	9.26	16.27	1.76	9.54	16.16	1.69	
2°C	8.83	17.65	2.00	9.10	17.47	1.92	9.36	17.30	1.85	9.63	17.12	1.78	9.90	16.95	1.71	10.17	16.78	1.65	10.44	16.60	1.59	
1°C	8.84	17.61	1.99	9.10	17.41	1.91	9.37	17.22	1.84	9.64	17.05	1.77	9.90	16.87	1.70	10.17	16.63	1.64	10.44	16.39	1.57	
0°C	8.87	17.57	1.98	9.13	17.35	1.90	9.39	17.14	1.82	9.65	16.97	1.76	9.91	16.80	1.69	10.17	16.49	1.62	10.45	16.19	1.55	
-1°C	8.93	17.53	1.96	9.17	17.29	1.88	9.43	17.06	1.81	9.68	16.89	1.75	9.92	16.72	1.68	10.17	16.35	1.61	10.48	15.98	1.53	
-2°C	9.00	17.49	1.94	9.23	17.22	1.87	9.48	16.98	1.79	9.71	16.81	1.73	9.94	16.64	1.67	10.18	16.21	1.59	10.51	15.78	1.50	
-3°C	9.09	17.46	1.92	9.31	17.16	1.84	9.55	16.90	1.77	9.76	16.73	1.71	9.97	16.57	1.66	10.18	16.07	1.58	10.55	15.57	1.48	
-4°C	9.21	17.42	1.89	9.40	17.10	1.82	9.64	16.82	1.75	9.82	16.66	1.70	10.00	16.49	1.65	10.19	15.93	1.56	10.60	15.37	1.45	
-5°C	9.34	17.38	1.86	9.51	17.04	1.79	9.73	16.74	1.72	9.88	16.58	1.68	10.03	16.42	1.64	10.20	15.79	1.55	10.66	15.16	1.42	
-6°C	9.50	17.34	1.83	9.64	16.97	1.76	9.85	16.66	1.69	9.96	16.50	1.66	10.07	16.34	1.62	10.21	15.64	1.53	10.73	14.96	1.39	
-7°C	9.67	17.30	1.79	9.78	16.91	1.73	9.98	16.58	1.66	10.05	16.42	1.63	10.12	16.26	1.61	10.22	15.50	1.52	10.81	14.75	1.36	
-8°C	9.87	17.15	1.74	9.94	16.73	1.68	10.08	16.35	1.62	10.13	16.10	1.59	10.19	15.84	1.56	10.26	15.19	1.48	10.66	14.53	1.36	
-9°C	10.06	16.99	1.69	10.11	16.55	1.64	10.18	16.13	1.58	10.22	15.77	1.54	10.25	15.42	1.50	10.30	14.87	1.44	10.51	14.32	1.36	
-10°C	10.25	16.84	1.64	10.27	16.37	1.59	10.29	15.90	1.55	10.30	15.45	1.50	10.32	15.00	1.45	10.34	14.55	1.41	10.35	14.10	1.36	
-11°C	10.09	16.42	1.63	10.15	16.02	1.58	10.20	15.63	1.53	10.25	15.25	1.49	10.29	14.87	1.45	10.34	14.47	1.40	10.38	13.94	1.34	
-12°C	9.93	15.99	1.61	10.02	15.68	1.56	10.12	15.36	1.52	10.19	15.05	1.48	10.26	14.75	1.44	10.34	14.38	1.39	10.41	13.78	1.32	
-13°C	9.77	15.57	1.59	9.90	15.33	1.55	10.03	15.09	1.50	10.13	14.86	1.47	10.23	14.62	1.43	10.33	14.30	1.38	10.43	13.63	1.31	
-14°C	9.60	15.15	1.58	9.78	14.98	1.53	9.95	14.82	1.49	10.08	14.66	1.45	10.21	14.50	1.42	10.33	14.22	1.38	10.46	13		

60°C			65°C			70°C			75°C			
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,81	13,57	2,82	5,57	13,71	2,46	6,46	13,87	2,15	0,00	0,00	0,00	35°C
4,80	13,54	2,82	5,57	13,69	2,46	6,45	13,84	2,15	0,00	0,00	0,00	34°C
4,80	13,52	2,82	5,56	13,66	2,46	6,45	13,82	2,14	0,00	0,00	0,00	33°C
4,79	13,49	2,82	5,55	13,64	2,45	6,44	13,79	2,14	0,00	0,00	0,00	32°C
4,79	13,46	2,81	5,55	13,61	2,45	6,43	13,76	2,14	0,00	0,00	0,00	31°C
4,78	13,44	2,81	5,54	13,58	2,45	6,43	13,76	2,14	0,00	0,00	0,00	30°C
4,78	13,41	2,81	5,54	13,56	2,45	6,42	13,76	2,14	0,00	0,00	0,00	29°C
4,77	13,39	2,80	5,53	13,54	2,45	6,41	13,76	2,14	0,00	0,00	0,00	28°C
4,77	13,36	2,80	5,53	13,54	2,45	6,41	13,76	2,15	0,00	0,00	0,00	27°C
4,76	13,33	2,80	5,52	13,54	2,45	6,40	13,76	2,15	0,00	0,00	0,00	26°C
4,76	13,33	2,80	5,52	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	25°C
4,75	13,33	2,80	5,51	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	24°C
4,75	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	23°C
4,74	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	22°C
4,74	13,33	2,81	5,49	13,54	2,47	6,37	13,76	2,16	0,00	0,00	0,00	21°C
4,73	13,33	2,82	5,49	13,54	2,47	6,36	13,76	2,16	0,00	0,00	0,00	20°C
4,73	13,33	2,82	5,48	13,54	2,47	6,36	13,76	2,16	7,37	13,97	1,90	19°C
4,72	13,33	2,82	5,48	13,54	2,47	6,35	13,76	2,17	7,36	13,97	1,90	18°C
4,72	13,33	2,82	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	17°C
4,72	13,33	2,83	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	16°C
4,71	13,33	2,83	5,46	13,54	2,48	6,33	13,76	2,17	7,34	13,97	1,90	15°C
4,71	13,33	2,83	5,46	13,54	2,48	6,32	13,76	2,17	7,33	13,97	1,90	14°C
4,70	13,33	2,84	5,45	13,54	2,48	6,32	13,76	2,18	7,32	13,97	1,91	13°C
4,70	13,33	2,84	5,44	13,54	2,49	6,31	13,76	2,18	7,32	13,97	1,91	12°C
4,90	13,54	2,76	5,65	13,75	2,43	6,52	13,97	2,14	7,52	14,18	1,89	11°C
5,08	13,72	2,70	5,82	13,93	2,39	6,69	14,15	2,11	7,69	14,36	1,87	10°C
5,28	13,93	2,64	6,03	14,14	2,35	6,89	14,36	2,08	7,90	14,57	1,85	9°C
5,46	14,11	2,59	6,20	14,32	2,31	7,07	14,54	2,06	8,07	14,75	1,83	8°C
5,75	14,41	2,50	6,50	14,62	2,25	7,36	14,84	2,02	8,36	15,05	1,80	7°C
7,08	14,96	2,11	7,66	15,07	1,97	8,31	15,18	1,83	9,04	15,29	1,69	6°C
8,17	15,39	1,88	8,61	15,41	1,79	9,09	15,43	1,70	9,63	15,45	1,61	5°C
9,08	15,75	1,74	9,42	15,71	1,67	9,79	15,66	1,60	10,17	15,61	1,53	4°C
9,80	16,06	1,64	10,09	15,95	1,58	10,38	15,85	1,53	10,68	15,75	1,47	3°C
10,70	16,43	1,53	10,97	16,25	1,48	11,24	16,08	1,43	11,51	15,90	1,38	2°C
10,71	16,10	1,50	10,99	15,80	1,44	11,26	15,50	1,38	11,54	15,28	1,32	1°C
10,75	15,77	1,47	11,04	15,34	1,39	11,33	14,92	1,32	11,63	14,66	1,26	0°C
10,80	15,44	1,43	11,13	14,89	1,34	11,45	14,34	1,25	11,79	14,04	1,19	-1°C
10,88	15,11	1,39	11,25	14,44	1,28	11,62	13,76	1,18	12,01	13,42	1,12	-2°C
10,98	14,78	1,35	11,41	13,98	1,23	11,84	13,19	1,11	12,29	12,80	1,04	-3°C
11,10	14,45	1,30	11,60	13,53	1,17	12,10	12,61	1,04	12,63	12,18	0,96	-4°C
11,24	14,12	1,26	11,83	13,07	1,11	12,41	12,03	0,97	13,04	11,55	0,89	-5°C
11,41	13,79	1,21	12,09	12,62	1,04	12,77	11,45	0,90	13,51	10,93	0,81	-6°C
11,60	13,46	1,16	12,38	12,17	0,98	13,17	10,88	0,83	14,04	10,31	0,73	-7°C
11,11	13,24	1,19	11,57	11,96	1,03	12,03	10,67	0,89	12,61	10,20	0,81	-8°C
10,63	13,03	1,23	10,76	11,75	1,09	10,89	10,46	0,96	11,19	10,08	0,90	-9°C
10,15	12,82	1,26	9,95	11,54	1,16	9,75	10,25	1,05	9,76	9,97	1,02	-10°C
10,22	12,75	1,25	10,07	11,56	1,15	9,91	10,37	1,05	6,00	6,00	1,00	-11°C
10,29	12,68	1,23	10,18	11,59	1,14	10,07	10,49	1,04	6,00	6,00	1,00	-12°C
10,37	12,62	1,22	10,30	11,61	1,13	10,23	10,60	1,04	6,00	6,00	1,00	-13°C
10,44	12,55	1,20	10,41	11,64	1,12	10,39	10,72	1,03	6,00	6,00	1,00	-14°C
10,51	12,49	1,19	10,53	11,66	1,11	10,55	10,84	1,03	6,00	6,00	1,00	-15°C
10,52	12,39	1,18	10,54	11,55	1,10	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
10,54	12,30	1,17	10,55	11,43	1,08	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
10,55	12,21	1,16	10,56	11,32	1,07	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
10,57	12,11	1,15	10,57	11,21	1,06	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
10,58	12,02	1,14	10,57	11,09	1,05	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
10,59	11,93	1,13	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
10,61	11,83	1,12	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
10,62	11,74	1,11	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
10,64	11,65	1,09	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
10,65	11,55	1,08	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

Outdoor temperature

▼ AUREA 2 COMPACT 12 (backup 6kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	2,04	15,54	7,63	2,54	15,54	6,11	2,89	15,39	5,32	3,44	15,36	4,46	3,96	15,46	3,90	4,49	15,63	3,48	5,01	15,83	3,16
34°C	2,03	15,50	7,64	2,53	15,50	6,12	2,88	15,36	5,33	3,44	15,33	4,46	3,96	15,43	3,90	4,48	15,59	3,48	5,00	15,80	3,16
33°C	2,02	15,47	7,66	2,52	15,47	6,14	2,87	15,33	5,34	3,44	15,30	4,45	3,96	15,40	3,89	4,48	15,56	3,48	5,00	15,78	3,16
32°C	2,01	15,44	7,67	2,51	15,44	6,15	2,86	15,30	5,35	3,43	15,27	4,45	3,95	15,37	3,89	4,47	15,53	3,47	4,99	15,78	3,16
31°C	2,00	15,41	7,69	2,50	15,41	6,16	2,85	15,27	5,36	3,43	15,24	4,45	3,95	15,34	3,88	4,47	15,50	3,47	4,99	15,78	3,16
30°C	2,00	15,38	7,71	2,49	15,38	6,17	2,84	15,24	5,37	3,43	15,21	4,44	3,94	15,31	3,88	4,46	15,47	3,47	4,98	15,78	3,17
29°C	1,99	15,35	7,72	2,48	15,35	6,18	2,83	15,20	5,38	3,42	15,18	4,44	3,94	15,28	3,88	4,46	15,44	3,46	4,98	15,78	3,17
28°C	1,98	15,32	7,74	2,47	15,32	6,20	2,81	15,17	5,39	3,42	15,15	4,43	3,94	15,25	3,87	4,46	15,41	3,46	4,97	15,78	3,17
27°C	1,97	15,29	7,75	2,46	15,29	6,21	2,80	15,14	5,40	3,42	15,12	4,43	3,93	15,22	3,87	4,45	15,41	3,46	4,97	15,78	3,18
26°C	1,96	15,26	7,77	2,45	15,26	6,22	2,79	15,11	5,41	3,41	15,09	4,42	3,93	15,19	3,87	4,45	15,41	3,47	4,96	15,78	3,18
25°C	1,96	15,23	7,78	2,44	15,23	6,23	2,78	15,08	5,43	3,41	15,06	4,42	3,93	15,16	3,86	4,44	15,41	3,47	4,96	15,78	3,18
24°C	1,95	15,20	7,80	2,43	15,20	6,25	2,77	15,05	5,44	3,40	15,03	4,41	3,92	15,13	3,86	4,44	15,41	3,47	4,95	15,78	3,19
23°C	1,94	15,17	7,81	2,42	15,17	6,26	2,76	15,02	5,45	3,40	15,00	4,41	3,92	15,10	3,85	4,43	15,41	3,48	4,95	15,78	3,19
22°C	1,93	15,14	7,83	2,41	15,14	6,27	2,75	14,99	5,46	3,40	14,97	4,41	3,91	15,07	3,85	4,43	15,41	3,48	4,94	15,78	3,19
21°C	1,93	15,11	7,84	2,40	15,11	6,28	2,74	14,96	5,47	3,39	14,94	4,40	3,91	15,04	3,85	4,42	15,41	3,48	4,94	15,78	3,19
20°C	1,92	15,08	7,86	2,39	15,08	6,30	2,73	14,93	5,48	3,39	14,91	4,40	3,91	15,04	3,85	4,42	15,41	3,49	4,93	15,78	3,20
19°C	1,91	15,05	7,88	2,38	15,05	6,31	2,71	14,90	5,49	3,39	14,88	4,39	3,90	15,04	3,86	4,42	15,41	3,49	4,93	15,78	3,20
18°C	1,90	15,02	7,89	2,38	15,02	6,32	2,70	14,87	5,50	3,38	14,85	4,39	3,90	15,04	3,86	4,41	15,41	3,49	4,92	15,78	3,20
17°C	1,90	14,99	7,91	2,37	14,99	6,33	2,69	14,84	5,51	3,38	14,82	4,38	3,89	15,04	3,86	4,41	15,41	3,50	4,92	15,78	3,21
16°C	1,89	14,96	7,92	2,36	14,96	6,35	2,68	14,81	5,52	3,38	14,79	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
15°C	1,88	14,93	7,94	2,35	14,93	6,36	2,67	14,79	5,53	3,37	14,76	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
14°C	1,87	14,90	7,96	2,34	14,90	6,37	2,66	14,76	5,55	3,37	14,73	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
13°C	1,87	14,87	7,97	2,33	14,87	6,38	2,65	14,73	5,56	3,37	14,70	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
12°C	1,86	14,84	7,99	2,32	14,84	6,40	2,64	14,70	5,57	3,36	14,68	4,36	3,87	15,04	3,88	4,38	15,41	3,52	4,89	15,78	3,22
11°C	2,17	14,99	6,91	2,60	14,99	5,77	2,91	14,88	5,11	3,57	14,89	4,17	4,08	15,25	3,74	4,59	15,62	3,40	5,10	15,99	3,14
10°C	2,45	15,10	6,16	2,85	15,10	5,31	3,16	15,03	4,76	3,75	15,07	4,02	4,26	15,43	3,63	4,77	15,80	3,32	5,27	16,17	3,07
9°C	2,76	15,25	5,52	3,13	15,25	4,88	3,43	15,21	4,43	3,95	15,28	3,86	4,46	15,64	3,51	4,97	16,01	3,22	5,48	16,38	2,99
8°C	3,04	15,37	5,05	3,37	15,37	4,55	3,68	15,36	4,18	4,13	15,46	3,74	4,64	15,82	3,41	5,15	16,19	3,15	5,66	16,56	2,93
7°C	3,44	15,61	4,53	3,74	15,61	4,17	4,01	15,61	3,90	4,43	15,76	3,56	4,94	16,12	3,27	5,44	16,49	3,03	5,95	16,86	2,83
6°C	5,11	16,89	3,31	5,57	16,88	3,03	5,86	16,87	2,88	6,24	16,96	2,72	6,68	17,22	2,58	7,12	17,48	2,45	7,56	17,73	2,34
5°C	6,46	17,95	2,78	7,05	17,92	2,54	7,35	17,90	2,43	7,71	17,95	2,33	8,10	18,11	2,24	8,48	18,27	2,15	8,87	18,44	2,08
4°C	7,55	18,82	2,49	8,23	18,79	2,28	8,54	18,75	2,19	8,88	18,77	2,11	9,23	18,86	2,04	9,58	18,94	1,98	9,94	19,03	1,92
3°C	8,39	19,52	2,33	9,12	19,48	2,14	9,44	19,44	2,06	9,77	19,43	1,99	10,10	19,46	1,93	10,42	19,48	1,87	10,75	19,51	1,81
2°C	9,33	20,40	2,19	10,08	20,35	2,02	10,40	20,30	1,95	10,72	20,25	1,89	11,04	20,20	1,83	11,36	20,15	1,77	11,69	20,10	1,72
1°C	9,32	20,19	2,17	10,07	20,15	2,00	10,39	20,09	1,93	10,72	20,02	1,87	11,04	19,96	1,81	11,36	19,97	1,76	11,68	19,87	1,70
0°C	9,31	19,99	2,15	10,05	19,96	1,99	10,37	19,88	1,92	10,70	19,80	1,85	11,03	19,72	1,79	11,37	19,79	1,74	11,67	19,63	1,68
-1°C	9,28	19,78	2,13	10,01	19,76	1,97	10,34	19,67	1,90	10,68	19,57	1,83	11,01	19,48	1,77	11,37	19,60	1,72	11,64	19,40	1,67
-2°C	9,24	19,58	2,12	9,95	19,56	1,97	10,30	19,46	1,89	10,64	19,35	1,82	10,99	19,23	1,75	11,38	19,42	1,71	11,61	19,17	1,65
-3°C	9,20	19,37	2,11	9,88	19,37	1,96	10,24	19,24	1,88	10,60	19,12	1,80	10,96	18,99	1,73	11,39	19,24	1,69	11,57	18,93	1,64
-4°C	9,14	19,17	2,10	9,79	19,17	1,96	10,17	19,03	1,87	10,55	18,89	1,79	10,93	18,75	1,72	11,40	19,06	1,67	11,52	18,70	1,62
-5°C	9,08	18,96	2,09	9,69	18,97	1,96	10,08	18,82	1,87	10,48	18,67	1,78	10,89	18,51	1,70	11,41	18,87	1,65	11,46	18,47	1,61
-6°C	9,00	18,76	2,08	9,57	18,77	1,96	9,99	18,61	1,86	10,41	18,44	1,77	10,84	18,27	1,69	11,42	18,69	1,64	11,39	18,23	1,60
-7°C	8,91	18,55	2,08	9,43	18,58	1,97	9,88	18,40	1,86	10,33	18,21	1,76	10,79	18,03	1,67	11,44	18,51	1,62	11,31	18,00	1,59
-8°C	9,08	18,49	2,04	9,56	18,48	1,93	9,99	18,33	1,84	10,43	18,16	1,74	10,87	17,99	1,65	11,44	18,26	1,60	11,49	17,87	1,55
-9°C	9,24	18,43	1,99	9,68	18,38	1,90	10,11	18,27	1,81	10,53	18,10	1,72	10,96	17,94	1,64	11,44	18,00	1,57	11,68	17,73	1,52
-10°C	9,40	18,37	1,95	9,81	18,28	1,86	10,22	18,20	1,78	10,63	18,05	1,70	11,04	17,90	1,62	11,45	17,75	1,55	11,86	17,60	1,48
-11°C	9,41	17,64	1,87	9,78	17,55	1,79	10,15	17,47	1,72	10,51	17,33	1,65	10,87	17,19	1,58	11,23	17,03	1,52	11,58	16,74	1,45
-12°C	9,42	16,91	1,80	9,75	16,82	1,73	10,08	16,74	1,66	10,39	16,61	1,60	10,69	16,49	1,54	11,00	16,30	1,48	11,31	15,88	1,40
-13°C	9,43	16,18	1,72	9,72	16,10	1,66	10,01	16,01	1,60	10,27	15,90	1,55	10,52	15,78	1,50	10,78	15,58	1,45	11,04	15,03	1,36
-14°C	9,43	15,45	1,64	9,69	15,37	1,59	9,94	15,28	1,54	10,14	15,18	1,50	10,35	15,08	1,46	10,56	14,86	1,41	10,76	14,17	

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
5,26	16,15	3,07	6,10	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	35°C
5,26	16,15	3,07	6,09	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	34°C
5,25	16,15	3,07	6,09	16,52	2,71	7,06	16,88	2,39	0,00	0,00	0,00	33°C
5,25	16,15	3,08	6,08	16,52	2,72	7,05	16,88	2,39	0,00	0,00	0,00	32°C
5,24	16,15	3,08	6,08	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	31°C
5,24	16,15	3,08	6,07	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	30°C
5,23	16,15	3,09	6,06	16,52	2,72	7,03	16,88	2,40	0,00	0,00	0,00	29°C
5,23	16,15	3,09	6,06	16,52	2,73	7,02	16,88	2,40	0,00	0,00	0,00	28°C
5,22	16,15	3,09	6,05	16,52	2,73	7,02	16,88	2,41	0,00	0,00	0,00	27°C
5,22	16,15	3,10	6,05	16,52	2,73	7,01	16,88	2,41	0,00	0,00	0,00	26°C
5,21	16,15	3,10	6,04	16,52	2,73	7,00	16,88	2,41	0,00	0,00	0,00	25°C
5,21	16,15	3,10	6,03	16,52	2,74	7,00	16,88	2,41	0,00	0,00	0,00	24°C
5,20	16,15	3,11	6,03	16,52	2,74	6,99	16,88	2,42	0,00	0,00	0,00	23°C
5,19	16,15	3,11	6,02	16,52	2,74	6,98	16,88	2,42	0,00	0,00	0,00	22°C
5,19	16,15	3,11	6,02	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	21°C
5,18	16,15	3,11	6,01	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	20°C
5,18	16,15	3,12	6,00	16,52	2,75	6,96	16,88	2,43	8,07	17,25	2,14	19°C
5,17	16,15	3,12	6,00	16,52	2,75	6,95	16,88	2,43	8,06	17,25	2,14	18°C
5,17	16,15	3,12	5,99	16,52	2,76	6,95	16,88	2,43	8,05	17,25	2,14	17°C
5,16	16,15	3,13	5,99	16,52	2,76	6,94	16,88	2,43	8,05	17,25	2,14	16°C
5,16	16,15	3,13	5,98	16,52	2,76	6,93	16,88	2,44	8,04	17,25	2,15	15°C
5,15	16,15	3,13	5,97	16,52	2,76	6,93	16,88	2,44	8,03	17,25	2,15	14°C
5,15	16,15	3,14	5,97	16,52	2,77	6,92	16,88	2,44	8,02	17,25	2,15	13°C
5,14	16,15	3,14	5,96	16,52	2,77	6,91	16,88	2,44	8,01	17,25	2,15	12°C
5,35	16,36	3,06	6,17	16,73	2,71	7,12	17,09	2,40	8,21	17,46	2,13	11°C
5,52	16,54	2,99	6,34	16,91	2,67	7,29	17,27	2,37	8,39	17,64	2,10	10°C
5,73	16,75	2,92	6,54	17,12	2,62	7,49	17,48	2,33	8,59	17,85	2,08	9°C
5,90	16,93	2,87	6,72	17,30	2,57	7,66	17,66	2,30	8,76	18,03	2,06	8°C
6,20	17,23	2,78	7,01	17,60	2,51	7,96	17,96	2,26	9,05	18,33	2,02	7°C
7,84	17,99	2,30	8,48	18,25	2,15	9,20	18,51	2,01	10,01	18,76	1,87	6°C
9,17	18,60	2,03	9,67	18,76	1,94	10,21	18,93	1,85	10,81	19,09	1,77	5°C
10,24	19,12	1,87	10,64	19,20	1,80	11,07	19,29	1,74	11,51	19,37	1,68	4°C
11,07	19,54	1,76	11,41	19,56	1,71	11,76	19,59	1,67	12,11	19,62	1,62	3°C
12,01	20,05	1,67	12,33	20,00	1,62	12,65	19,95	1,58	12,97	19,90	1,53	2°C
11,99	19,61	1,64	12,30	19,36	1,57	12,61	19,11	1,52	12,92	18,97	1,47	1°C
11,94	19,18	1,61	12,21	18,72	1,53	12,48	18,27	1,46	12,76	18,03	1,41	0°C
11,85	18,74	1,58	12,06	18,08	1,50	12,27	17,43	1,42	12,49	17,10	1,37	-1°C
11,73	18,31	1,56	11,85	17,44	1,47	11,97	16,58	1,39	12,11	16,17	1,34	-2°C
11,58	17,87	1,54	11,58	16,81	1,45	11,59	15,74	1,36	11,62	15,23	1,31	-3°C
11,39	17,43	1,53	11,25	16,17	1,44	11,12	14,90	1,34	11,03	14,30	1,30	-4°C
11,16	17,00	1,52	10,87	15,53	1,43	10,57	14,06	1,33	10,33	13,37	1,29	-5°C
10,90	16,56	1,52	10,42	14,89	1,43	9,93	13,22	1,33	9,52	12,43	1,31	-6°C
10,61	16,13	1,52	9,91	14,25	1,44	9,21	12,38	1,34	8,60	11,50	1,34	-7°C
11,05	16,11	1,46	10,60	14,35	1,35	10,15	12,59	1,24	9,86	11,98	1,21	-8°C
11,48	16,09	1,40	11,28	14,45	1,28	11,09	12,81	1,16	11,12	12,45	1,12	-9°C
11,91	16,07	1,35	11,97	14,55	1,22	12,02	13,02	1,08	12,37	12,93	1,05	-10°C
11,63	15,36	1,32	11,68	13,97	1,20	11,73	12,59	1,07	6,00	6,00	1,00	-11°C
11,35	14,64	1,29	11,39	13,39	1,18	11,44	12,15	1,06	6,00	6,00	1,00	-12°C
11,07	13,92	1,26	11,11	12,82	1,15	11,14	11,71	1,05	6,00	6,00	1,00	-13°C
10,79	13,20	1,22	10,82	12,24	1,13	10,85	11,27	1,04	6,00	6,00	1,00	-14°C
10,51	12,49	1,19	10,53	11,66	1,11	10,55	10,84	1,03	6,00	6,00	1,00	-15°C
10,52	12,39	1,18	10,54	11,55	1,10	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
10,54	12,30	1,17	10,55	11,43	1,08	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
10,55	12,21	1,16	10,56	11,32	1,07	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
10,57	12,11	1,15	10,57	11,21	1,06	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
10,58	12,02	1,14	10,57	11,09	1,05	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
10,59	11,93	1,13	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
10,61	11,83	1,12	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
10,62	11,74	1,11	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
10,64	11,65	1,09	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
10,65	11,55	1,08	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 3 (backup 3kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	0.67	5.57	8.37	0.82	5.55	6.79	0.92	5.43	5.87	1.07	5.39	5.02	1.24	5.38	4.35	1.40	5.37	3.84	1.56	5.35	3.43
	34°C	0.66	5.56	8.38	0.81	5.54	6.81	0.92	5.42	5.88	1.07	5.38	5.01	1.24	5.37	4.35	1.40	5.36	3.83	1.56	5.34	3.43
	33°C	0.66	5.55	8.40	0.81	5.53	6.82	0.92	5.41	5.89	1.07	5.37	5.01	1.23	5.36	4.34	1.40	5.35	3.83	1.56	5.33	3.43
	32°C	0.66	5.54	8.42	0.81	5.52	6.83	0.91	5.40	5.90	1.07	5.36	5.00	1.23	5.35	4.34	1.39	5.33	3.83	1.56	5.32	3.42
	31°C	0.65	5.52	8.43	0.80	5.51	6.85	0.91	5.38	5.92	1.07	5.35	5.00	1.23	5.34	4.33	1.39	5.32	3.82	1.55	5.31	3.42
	30°C	0.65	5.51	8.45	0.80	5.50	6.86	0.91	5.37	5.93	1.07	5.34	4.99	1.23	5.33	4.33	1.39	5.31	3.82	1.55	5.30	3.42
	29°C	0.65	5.50	8.47	0.80	5.49	6.87	0.90	5.36	5.94	1.07	5.33	4.99	1.23	5.32	4.32	1.39	5.30	3.82	1.55	5.29	3.41
	28°C	0.65	5.49	8.49	0.80	5.48	6.89	0.90	5.35	5.95	1.07	5.32	4.98	1.23	5.30	4.32	1.39	5.29	3.81	1.55	5.28	3.41
	27°C	0.64	5.48	8.50	0.79	5.47	6.90	0.90	5.34	5.96	1.07	5.31	4.98	1.23	5.29	4.32	1.39	5.28	3.81	1.55	5.27	3.40
	26°C	0.64	5.47	8.52	0.79	5.46	6.92	0.89	5.33	5.98	1.07	5.30	4.97	1.23	5.28	4.31	1.39	5.27	3.80	1.55	5.26	3.40
	25°C	0.64	5.46	8.54	0.79	5.45	6.93	0.89	5.32	5.99	1.06	5.29	4.97	1.22	5.27	4.31	1.38	5.26	3.80	1.54	5.25	3.40
	24°C	0.64	5.45	8.55	0.78	5.43	6.94	0.89	5.31	6.00	1.06	5.27	4.96	1.22	5.26	4.30	1.38	5.25	3.80	1.54	5.24	3.39
	23°C	0.63	5.44	8.57	0.78	5.42	6.96	0.88	5.30	6.01	1.06	5.26	4.96	1.22	5.25	4.30	1.38	5.24	3.79	1.54	5.23	3.39
	22°C	0.63	5.43	8.59	0.78	5.41	6.97	0.88	5.29	6.02	1.06	5.25	4.95	1.22	5.24	4.29	1.38	5.23	3.79	1.54	5.22	3.39
	21°C	0.63	5.42	8.60	0.77	5.40	6.98	0.87	5.28	6.04	1.06	5.24	4.95	1.22	5.23	4.29	1.38	5.22	3.78	1.54	5.21	3.38
	20°C	0.63	5.40	8.62	0.77	5.39	7.00	0.87	5.27	6.05	1.06	5.23	4.94	1.22	5.22	4.29	1.38	5.21	3.78	1.54	5.19	3.38
	19°C	0.62	5.39	8.64	0.77	5.38	7.01	0.87	5.26	6.06	1.06	5.22	4.94	1.22	5.21	4.28	1.38	5.20	3.78	1.54	5.18	3.38
	18°C	0.62	5.38	8.66	0.76	5.37	7.03	0.86	5.25	6.07	1.06	5.21	4.93	1.22	5.20	4.28	1.37	5.19	3.77	1.53	5.17	3.37
	17°C	0.62	5.37	8.67	0.76	5.36	7.04	0.86	5.24	6.08	1.06	5.20	4.93	1.21	5.19	4.27	1.37	5.18	3.77	1.53	5.16	3.37
	16°C	0.62	5.36	8.69	0.76	5.35	7.05	0.86	5.23	6.10	1.05	5.19	4.92	1.21	5.18	4.27	1.37	5.17	3.77	1.53	5.15	3.37
	15°C	0.61	5.35	8.71	0.76	5.34	7.07	0.85	5.22	6.11	1.05	5.18	4.92	1.21	5.17	4.26	1.37	5.16	3.76	1.53	5.14	3.36
	14°C	0.61	5.34	8.73	0.75	5.33	7.08	0.85	5.20	6.12	1.05	5.17	4.91	1.21	5.16	4.26	1.37	5.14	3.76	1.53	5.13	3.36
	13°C	0.61	5.33	8.74	0.75	5.32	7.10	0.85	5.19	6.13	1.05	5.16	4.91	1.21	5.15	4.26	1.37	5.13	3.75	1.53	5.12	3.36
	12°C	0.61	5.32	8.76	0.75	5.31	7.11	0.84	5.18	6.14	1.05	5.15	4.90	1.21	5.14	4.25	1.37	5.12	3.75	1.52	5.11	3.35
	11°C	0.76	5.37	7.07	0.88	5.36	6.08	0.97	5.26	5.44	1.15	5.23	4.53	1.31	5.22	3.98	1.47	5.20	3.54	1.63	5.19	3.19
	10°C	0.90	5.41	6.04	1.00	5.40	5.39	1.08	5.33	4.95	1.24	5.30	4.26	1.40	5.28	3.77	1.56	5.27	3.38	1.72	5.26	3.06
9°C	1.05	5.47	5.21	1.14	5.45	4.80	1.20	5.41	4.50	1.35	5.38	3.99	1.50	5.36	3.56	1.66	5.35	3.22	1.82	5.34	2.93	
8°C	1.19	5.51	4.64	1.26	5.49	4.37	1.31	5.48	4.17	1.44	5.44	3.79	1.59	5.43	3.41	1.75	5.42	3.09	1.91	5.40	2.83	
7°C	1.38	5.61	4.05	1.44	5.59	3.89	1.47	5.58	3.79	1.59	5.57	3.51	1.74	5.56	3.19	1.90	5.54	2.92	2.06	5.53	2.69	
6°C	2.11	6.15	2.92	2.17	6.12	2.82	2.23	6.09	2.74	2.34	6.06	2.60	2.47	6.03	2.44	2.61	6.00	2.30	2.75	5.97	2.17	
5°C	2.70	6.60	2.44	2.76	6.55	2.37	2.84	6.51	2.29	2.95	6.46	2.19	3.07	6.41	2.09	3.19	6.37	2.00	3.31	6.32	1.91	
4°C	3.19	6.97	2.19	3.25	6.91	2.13	3.34	6.85	2.05	3.45	6.80	1.97	3.56	6.74	1.89	3.67	6.68	1.82	3.78	6.62	1.75	
3°C	3.57	7.27	2.04	3.64	7.20	1.98	3.73	7.13	1.91	3.84	7.07	1.84	3.94	7.00	1.78	4.04	6.93	1.71	4.15	6.86	1.65	
2°C	4.02	7.64	1.90	4.09	7.56	1.85	4.19	7.48	1.78	4.30	7.40	1.72	4.40	7.32	1.66	4.50	7.24	1.61	4.60	7.16	1.56	
1°C	4.03	7.67	1.91	4.10	7.58	1.85	4.20	7.46	1.78	4.30	7.38	1.72	4.40	7.30	1.66	4.50	7.21	1.60	4.60	7.11	1.54	
0°C	4.03	7.70	1.91	4.10	7.60	1.85	4.20	7.43	1.77	4.30	7.35	1.71	4.40	7.28	1.65	4.51	7.18	1.59	4.61	7.06	1.53	
-1°C	4.04	7.73	1.92	4.11	7.62	1.85	4.20	7.41	1.76	4.31	7.33	1.70	4.41	7.26	1.64	4.53	7.16	1.58	4.62	7.01	1.52	
-2°C	4.05	7.76	1.92	4.13	7.64	1.85	4.20	7.38	1.76	4.31	7.31	1.69	4.42	7.24	1.64	4.55	7.13	1.57	4.63	6.96	1.50	
-3°C	4.06	7.80	1.92	4.15	7.66	1.85	4.21	7.36	1.75	4.32	7.29	1.69	4.44	7.22	1.63	4.58	7.10	1.55	4.64	6.90	1.49	
-4°C	4.08	7.83	1.92	4.17	7.68	1.84	4.21	7.33	1.74	4.34	7.26	1.68	4.46	7.19	1.61	4.61	7.07	1.53	4.66	6.85	1.47	
-5°C	4.10	7.86	1.92	4.20	7.70	1.83	4.22	7.31	1.73	4.35	7.24	1.66	4.48	7.17	1.60	4.65	7.04	1.51	4.68	6.80	1.45	
-6°C	4.12	7.89	1.91	4.24	7.72	1.82	4.23	7.28	1.72	4.37	7.22	1.65	4.51	7.15	1.59	4.70	7.02	1.49	4.71	6.75	1.43	
-7°C	4.15	7.92	1.91	4.28	7.74	1.81	4.23	7.26	1.71	4.39	7.20	1.64	4.54	7.13	1.57	4.75	6.99	1.47	4.74	6.70	1.41	
-8°C	4.16	7.83	1.88	4.28	7.63	1.78	4.29	7.23	1.68	4.43	7.14	1.61	4.56	7.05	1.55	4.74	6.91	1.46	4.77	6.67	1.40	
-9°C	4.18	7.75	1.85	4.29	7.52	1.75	4.35	7.20	1.66	4.47	7.08	1.59	4.59	6.97	1.52	4.73	6.82	1.44	4.80	6.63	1.38	
-10°C	4.19	7.66	1.83	4.30	7.41	1.73	4.40	7.17	1.63	4.51	7.02	1.56	4.61	6.88	1.49	4.72	6.74	1.43	4.83	6.60	1.37	
-11°C	4.19	7.48	1.79	4.29	7.27	1.69	4.40	7.05	1.60	4.50	6.93	1.54	4.60	6.80	1.48	4.70	6.66	1.42	4.80	6.47	1.35	
-12°C	4.19	7.30	1.74	4.29	7.12	1.66	4.40	6.94	1.58	4.49	6.83	1.52	4.59	6.71	1.46	4.68	6.58	1.40	4.78	6.35	1.33	
-13°C	4.19	7.12	1.70	4.29	6.98	1.63	4.39	6.83	1.55	4.48	6.73	1.50	4.57	6.63	1.45	4.66	6.49	1.39	4.75	6.22	1.31	
-14°C	4.19	6.94	1.66	4.29	6.83	1.59	4.39	6.72	1.53	4.47	6.63	1.48	4.56	6.54	1.44	4.64	6.41	1.38	4.72	6.09	1.29	
-15°C	4.19	6.76	1.61	4.29	6.69	1.56	4.39	6.61	1.51	4.49	6.54	1.46	4.59	6.46	1.41	4.67	6.33	1.35	4.70	5.97	1.27	
-16°C	4.16	6.64	1.59	4.26	6.57	1.54	4.36	6.50	1.49	4.45	6.42	1.45	4.53	6.35	1.40	4.61	6.23	1.35	4.69	5.92	</	

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
1,64	5,34	3,26	1,90	5,33	2,80	2,20	5,32	2,41	0,00	0,00	0,00	35°C
1,64	5,33	3,26	1,90	5,32	2,80	2,20	5,31	2,41	0,00	0,00	0,00	34°C
1,64	5,32	3,25	1,90	5,31	2,80	2,20	5,29	2,41	0,00	0,00	0,00	33°C
1,63	5,31	3,25	1,89	5,30	2,80	2,20	5,28	2,41	0,00	0,00	0,00	32°C
1,63	5,30	3,25	1,89	5,29	2,79	2,19	5,27	2,40	0,00	0,00	0,00	31°C
1,63	5,29	3,24	1,89	5,28	2,79	2,19	5,26	2,40	0,00	0,00	0,00	30°C
1,63	5,28	3,24	1,89	5,26	2,79	2,19	5,25	2,40	0,00	0,00	0,00	29°C
1,63	5,27	3,24	1,89	5,25	2,78	2,19	5,24	2,40	0,00	0,00	0,00	28°C
1,63	5,26	3,23	1,88	5,24	2,78	2,19	5,23	2,39	0,00	0,00	0,00	27°C
1,62	5,25	3,23	1,88	5,23	2,78	2,18	5,22	2,39	0,00	0,00	0,00	26°C
1,62	5,23	3,23	1,88	5,22	2,78	2,18	5,21	2,39	0,00	0,00	0,00	25°C
1,62	5,22	3,22	1,88	5,21	2,77	2,18	5,20	2,39	0,00	0,00	0,00	24°C
1,62	5,21	3,22	1,88	5,20	2,77	2,18	5,19	2,38	0,00	0,00	0,00	23°C
1,62	5,20	3,22	1,88	5,19	2,77	2,17	5,18	2,38	0,00	0,00	0,00	22°C
1,62	5,19	3,21	1,87	5,18	2,76	2,17	5,17	2,38	0,00	0,00	0,00	21°C
1,61	5,18	3,21	1,87	5,17	2,76	2,17	5,16	2,38	0,00	0,00	0,00	20°C
1,61	5,17	3,21	1,87	5,16	2,76	2,17	5,15	2,37	2,51	5,13	2,04	19°C
1,61	5,16	3,20	1,87	5,15	2,76	2,17	5,14	2,37	2,51	5,12	2,04	18°C
1,61	5,15	3,20	1,87	5,14	2,75	2,16	5,13	2,37	2,51	5,11	2,04	17°C
1,61	5,14	3,20	1,86	5,13	2,75	2,16	5,12	2,37	2,51	5,10	2,04	16°C
1,61	5,13	3,19	1,86	5,12	2,75	2,16	5,10	2,36	2,50	5,09	2,03	15°C
1,60	5,12	3,19	1,86	5,11	2,74	2,16	5,09	2,36	2,50	5,08	2,03	14°C
1,60	5,11	3,19	1,86	5,10	2,74	2,15	5,08	2,36	2,50	5,07	2,03	13°C
1,60	5,10	3,18	1,86	5,09	2,74	2,15	5,07	2,36	2,50	5,06	2,03	12°C
1,71	5,18	3,04	1,96	5,17	2,64	2,26	5,15	2,29	2,60	5,14	1,98	11°C
1,79	5,25	2,92	2,05	5,23	2,55	2,34	5,22	2,23	2,69	5,21	1,94	10°C
1,90	5,33	2,81	2,15	5,31	2,47	2,45	5,30	2,17	2,79	5,29	1,90	9°C
1,99	5,39	2,72	2,24	5,38	2,40	2,53	5,37	2,12	2,88	5,35	1,86	8°C
2,13	5,52	2,59	2,39	5,50	2,31	2,68	5,49	2,05	3,02	5,48	1,81	7°C
2,83	5,94	2,10	3,03	5,91	1,95	3,26	5,88	1,81	3,51	5,85	1,67	6°C
3,40	6,28	1,85	3,56	6,23	1,75	3,73	6,19	1,66	3,92	6,14	1,57	5°C
3,87	6,56	1,69	4,00	6,50	1,63	4,13	6,45	1,56	4,27	6,39	1,50	4°C
4,25	6,79	1,60	4,35	6,73	1,54	4,46	6,66	1,49	4,57	6,59	1,44	3°C
4,70	7,08	1,51	4,80	7,00	1,46	4,90	6,92	1,41	5,01	6,84	1,37	2°C
4,70	7,01	1,49	4,80	6,91	1,44	4,90	6,81	1,39	4,99	6,73	1,35	1°C
4,69	6,94	1,48	4,78	6,82	1,43	4,87	6,71	1,38	4,96	6,61	1,33	0°C
4,68	6,87	1,47	4,75	6,74	1,42	4,82	6,60	1,37	4,90	6,50	1,33	-1°C
4,67	6,80	1,46	4,72	6,65	1,41	4,76	6,49	1,36	4,81	6,38	1,33	-2°C
4,65	6,73	1,45	4,67	6,56	1,41	4,68	6,39	1,36	4,70	6,27	1,33	-3°C
4,63	6,66	1,44	4,61	6,47	1,40	4,58	6,28	1,37	4,57	6,16	1,35	-4°C
4,61	6,59	1,43	4,54	6,38	1,41	4,46	6,17	1,38	4,41	6,04	1,37	-5°C
4,58	6,52	1,42	4,46	6,29	1,41	4,33	6,07	1,40	4,23	5,93	1,40	-6°C
4,55	6,45	1,42	4,36	6,21	1,42	4,18	5,96	1,43	4,02	5,81	1,45	-7°C
4,64	6,32	1,36	4,52	5,98	1,32	4,39	5,64	1,28	4,32	5,51	1,28	-8°C
4,73	6,20	1,31	4,67	5,76	1,23	4,61	5,32	1,15	4,62	5,21	1,13	-9°C
4,83	6,07	1,26	4,83	5,53	1,15	4,82	5,00	1,04	4,91	4,91	1,00	-10°C
4,81	5,97	1,24	4,81	5,48	1,14	4,81	4,98	1,03	3,00	3,00	1,00	-11°C
4,78	5,88	1,23	4,79	5,42	1,13	4,80	4,95	1,03	3,00	3,00	1,00	-12°C
4,76	5,79	1,22	4,78	5,36	1,12	4,79	4,93	1,03	3,00	3,00	1,00	-13°C
4,74	5,70	1,20	4,76	5,30	1,11	4,78	4,91	1,03	3,00	3,00	1,00	-14°C
4,72	5,60	1,19	4,75	5,24	1,10	4,77	4,88	1,02	3,00	3,00	1,00	-15°C
4,71	5,56	1,18	4,73	5,19	1,10	3,00	3,00	1,00	3,00	3,00	1,00	-16°C
4,70	5,51	1,17	4,72	5,14	1,09	3,00	3,00	1,00	3,00	3,00	1,00	-17°C
4,69	5,46	1,16	4,71	5,09	1,08	3,00	3,00	1,00	3,00	3,00	1,00	-18°C
4,68	5,41	1,16	4,69	5,04	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-19°C
4,67	5,36	1,15	4,68	4,98	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-20°C
4,65	5,31	1,14	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-21°C
4,64	5,26	1,13	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-22°C
4,63	5,21	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-23°C
4,62	5,16	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-24°C
4,61	5,11	1,11	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 4 (backup 3kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	0,82	6,52	7,95	1,00	6,50	6,47	1,13	6,33	5,59	1,32	6,27	4,73	1,52	6,24	4,12	1,71	6,22	3,64	1,90	6,20	3,26
	34°C	0,82	6,51	7,96	1,00	6,49	6,49	1,13	6,32	5,60	1,32	6,26	4,73	1,51	6,23	4,11	1,71	6,21	3,64	1,90	6,19	3,26
	33°C	0,81	6,49	7,98	1,00	6,48	6,50	1,13	6,31	5,61	1,32	6,24	4,72	1,51	6,22	4,11	1,71	6,19	3,63	1,90	6,18	3,26
	32°C	0,81	6,48	8,00	0,99	6,46	6,51	1,12	6,30	5,62	1,32	6,23	4,72	1,51	6,20	4,10	1,70	6,18	3,63	1,89	6,16	3,25
	31°C	0,81	6,47	8,01	0,99	6,45	6,53	1,12	6,28	5,63	1,32	6,22	4,72	1,51	6,19	4,10	1,70	6,17	3,63	1,89	6,15	3,25
	30°C	0,80	6,45	8,03	0,98	6,44	6,54	1,11	6,27	5,64	1,32	6,21	4,71	1,51	6,18	4,09	1,70	6,16	3,62	1,89	6,14	3,25
	29°C	0,80	6,44	8,04	0,98	6,43	6,55	1,11	6,26	5,65	1,32	6,19	4,71	1,51	6,17	4,09	1,70	6,14	3,62	1,89	6,13	3,24
	28°C	0,80	6,43	8,06	0,98	6,41	6,57	1,10	6,25	5,66	1,31	6,18	4,70	1,51	6,15	4,09	1,70	6,13	3,61	1,89	6,11	3,24
	27°C	0,79	6,42	8,08	0,97	6,40	6,58	1,10	6,23	5,67	1,31	6,17	4,70	1,50	6,14	4,08	1,69	6,12	3,61	1,89	6,10	3,24
	26°C	0,79	6,40	8,09	0,97	6,39	6,59	1,09	6,22	5,69	1,31	6,16	4,69	1,50	6,13	4,08	1,69	6,11	3,61	1,88	6,09	3,23
	25°C	0,79	6,39	8,11	0,97	6,37	6,61	1,09	6,21	5,70	1,31	6,14	4,69	1,50	6,12	4,07	1,69	6,09	3,60	1,88	6,08	3,23
	24°C	0,79	6,38	8,12	0,96	6,36	6,62	1,09	6,20	5,71	1,31	6,13	4,68	1,50	6,10	4,07	1,69	6,08	3,60	1,88	6,07	3,23
	23°C	0,78	6,37	8,14	0,96	6,35	6,63	1,08	6,18	5,72	1,31	6,12	4,68	1,50	6,09	4,07	1,69	6,07	3,60	1,88	6,05	3,22
	22°C	0,78	6,35	8,16	0,95	6,34	6,65	1,08	6,17	5,73	1,31	6,11	4,67	1,50	6,08	4,06	1,69	6,06	3,59	1,88	6,04	3,22
	21°C	0,78	6,34	8,17	0,95	6,32	6,66	1,07	6,16	5,74	1,31	6,10	4,67	1,50	6,07	4,06	1,68	6,05	3,59	1,87	6,03	3,22
	20°C	0,77	6,33	8,19	0,95	6,31	6,67	1,07	6,15	5,75	1,30	6,08	4,66	1,49	6,05	4,05	1,68	6,03	3,58	1,87	6,02	3,21
	19°C	0,77	6,31	8,21	0,94	6,30	6,68	1,06	6,13	5,77	1,30	6,07	4,66	1,49	6,04	4,05	1,68	6,02	3,58	1,87	6,00	3,21
	18°C	0,77	6,30	8,22	0,94	6,29	6,70	1,06	6,12	5,78	1,30	6,06	4,65	1,49	6,03	4,05	1,68	6,01	3,58	1,87	5,99	3,21
	17°C	0,76	6,29	8,24	0,93	6,27	6,71	1,06	6,11	5,79	1,30	6,05	4,65	1,49	6,02	4,04	1,68	6,00	3,57	1,87	5,98	3,20
	16°C	0,76	6,28	8,25	0,93	6,26	6,73	1,05	6,10	5,80	1,30	6,03	4,64	1,49	6,01	4,04	1,68	5,98	3,57	1,86	5,97	3,20
	15°C	0,76	6,26	8,27	0,93	6,25	6,74	1,05	6,09	5,81	1,30	6,02	4,64	1,49	5,99	4,03	1,67	5,97	3,57	1,86	5,96	3,20
	14°C	0,75	6,25	8,29	0,92	6,24	6,75	1,04	6,07	5,82	1,30	6,01	4,64	1,48	5,98	4,03	1,67	5,96	3,56	1,86	5,94	3,19
	13°C	0,75	6,24	8,30	0,92	6,22	6,77	1,04	6,06	5,84	1,30	6,00	4,63	1,48	5,97	4,02	1,67	5,95	3,56	1,86	5,93	3,19
	12°C	0,75	6,23	8,32	0,92	6,21	6,78	1,03	6,05	5,85	1,29	5,99	4,63	1,48	5,96	4,02	1,67	5,94	3,56	1,86	5,92	3,19
	11°C	0,90	6,27	6,98	1,05	6,25	5,95	1,16	6,12	5,26	1,40	6,06	4,33	1,59	6,03	3,80	1,77	6,01	3,39	1,96	5,99	3,06
	10°C	1,03	6,31	6,10	1,17	6,28	5,36	1,28	6,18	4,84	1,49	6,12	4,11	1,67	6,09	3,64	1,86	6,07	3,26	2,05	6,05	2,95
	9°C	1,19	6,36	5,36	1,31	6,33	4,84	1,41	6,25	4,45	1,59	6,19	3,89	1,78	6,16	3,47	1,96	6,14	3,13	2,15	6,14	2,85
	8°C	1,32	6,39	4,84	1,43	6,35	4,45	1,52	6,31	4,15	1,68	6,25	3,72	1,87	6,23	3,34	2,05	6,23	3,03	2,24	6,23	2,78
7°C	1,52	6,48	4,27	1,61	6,44	4,01	1,68	6,40	3,81	1,83	6,38	3,49	2,01	6,38	3,17	2,20	6,38	2,90	2,39	6,38	2,67	
6°C	2,28	7,10	3,11	2,38	7,05	2,97	2,47	6,99	2,83	2,61	6,95	2,67	2,77	6,92	2,50	2,94	6,90	2,35	3,10	6,87	2,21	
5°C	2,90	7,61	2,62	3,00	7,54	2,52	3,11	7,47	2,41	3,24	7,41	2,29	3,39	7,36	2,17	3,54	7,32	2,07	3,69	7,27	1,97	
4°C	3,41	8,04	2,35	3,51	7,96	2,27	3,63	7,88	2,17	3,76	7,80	2,08	3,89	7,73	1,99	4,03	7,67	1,90	4,17	7,60	1,82	
3°C	3,81	8,38	2,20	3,90	8,29	2,12	4,03	8,20	2,03	4,16	8,11	1,95	4,29	8,03	1,87	4,41	7,95	1,80	4,54	7,87	1,73	
2°C	4,27	8,80	2,06	4,37	8,70	1,99	4,49	8,60	1,91	4,62	8,50	1,84	4,75	8,40	1,77	4,87	8,30	1,70	5,00	8,20	1,64	
1°C	4,27	8,83	2,07	4,37	8,70	1,99	4,50	8,57	1,91	4,62	8,47	1,83	4,75	8,37	1,76	4,87	8,20	1,68	5,00	8,11	1,62	
0°C	4,28	8,86	2,07	4,38	8,70	1,99	4,50	8,54	1,90	4,62	8,44	1,83	4,75	8,35	1,76	4,87	8,10	1,66	5,01	8,02	1,60	
-1°C	4,30	8,88	2,07	4,39	8,70	1,98	4,51	8,51	1,89	4,63	8,41	1,82	4,74	8,32	1,75	4,86	8,00	1,65	5,02	7,93	1,58	
-2°C	4,32	8,91	2,06	4,41	8,70	1,97	4,52	8,48	1,87	4,63	8,38	1,81	4,74	8,29	1,75	4,86	7,90	1,63	5,04	7,84	1,56	
-3°C	4,35	8,94	2,06	4,43	8,69	1,96	4,54	8,44	1,86	4,64	8,36	1,80	4,74	8,27	1,74	4,85	7,80	1,61	5,06	7,76	1,53	
-4°C	4,39	8,97	2,04	4,46	8,69	1,95	4,56	8,41	1,84	4,65	8,33	1,79	4,74	8,24	1,74	4,83	7,70	1,59	5,08	7,67	1,51	
-5°C	4,43	8,99	2,03	4,50	8,69	1,93	4,59	8,38	1,83	4,66	8,30	1,78	4,73	8,21	1,73	4,82	7,60	1,58	5,11	7,58	1,48	
-6°C	4,47	9,02	2,02	4,54	8,69	1,92	4,61	8,35	1,81	4,67	8,27	1,77	4,73	8,19	1,73	4,80	7,50	1,56	5,15	7,49	1,45	
-7°C	4,53	9,05	2,00	4,58	8,69	1,90	4,65	8,32	1,79	4,69	8,24	1,76	4,73	8,16	1,73	4,78	7,40	1,55	5,19	7,40	1,43	
-8°C	4,54	8,93	1,97	4,59	8,56	1,87	4,65	8,18	1,76	4,69	8,02	1,71	4,73	7,86	1,66	4,78	7,24	1,51	5,07	7,13	1,41	
-9°C	4,55	8,81	1,94	4,60	8,43	1,83	4,65	8,04	1,73	4,69	7,80	1,66	4,73	7,55	1,60	4,78	7,08	1,48	4,95	6,87	1,39	
-10°C	4,56	8,70	1,91	4,61	8,30	1,80	4,65	7,90	1,70	4,69	7,58	1,61	4,74	7,25	1,53	4,78	6,93	1,45	4,83	6,60	1,37	
-11°C	4,53	8,44	1,86	4,59	8,11	1,77	4,65	7,77	1,67	4,70	7,49	1,59	4,75	7,21	1,52	4,81	6,92	1,44	4,86	6,58	1,35	
-12°C	4,50	8,19	1,82	4,57	7,91	1,73	4,64	7,64	1,65	4,71	7,41	1,57	4,77	7,18	1,51	4,83	6,92	1,43	4,89	6,56	1,34	
-13°C	4,46	7,93	1,78	4,55	7,72	1,70	4,64	7,51	1,62	4,71	7,33	1,55	4,78	7,14	1,49	4,86	6,92	1,42	4,93	6,53	1,33	
-14°C	4,43	7,68	1,73	4,53	7,53	1,66	4,64	7,38	1,59	4,72	7,24	1,53	4,80	7,11	1,48	4,88	6,92	1,42	4,96	6,51	1,31	
-15°C	4,40	7,42	1,69	4,52	7,34	1,62	4,63	7,25	1,56	4,75	7,16	1,51	4,87	7,07	1,45	4,97	6,91	1,39	5,00	6,49	1,30	
-16°C	4,37	7,28	1,67	4,49	7,19	1,60	4,61	7,11	1,54	4,70	7,03	1,50	4,80	6,95	1,45	4,89	6,81	1,39	4,99	6,43		

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,00	6,19	3,10	2,32	6,18	2,67	2,68	6,17	2,30	0,00	0,00	0,00	35°C
2,00	6,18	3,10	2,31	6,16	2,66	2,68	6,15	2,29	0,00	0,00	0,00	34°C
1,99	6,16	3,09	2,31	6,15	2,66	2,68	6,14	2,29	0,00	0,00	0,00	33°C
1,99	6,15	3,09	2,31	6,14	2,66	2,68	6,13	2,29	0,00	0,00	0,00	32°C
1,99	6,14	3,09	2,31	6,13	2,66	2,67	6,12	2,29	0,00	0,00	0,00	31°C
1,99	6,13	3,08	2,30	6,11	2,65	2,67	6,10	2,29	0,00	0,00	0,00	30°C
1,99	6,11	3,08	2,30	6,10	2,65	2,67	6,09	2,28	0,00	0,00	0,00	29°C
1,98	6,10	3,08	2,30	6,09	2,65	2,67	6,08	2,28	0,00	0,00	0,00	28°C
1,98	6,09	3,07	2,30	6,08	2,65	2,66	6,07	2,28	0,00	0,00	0,00	27°C
1,98	6,08	3,07	2,29	6,06	2,64	2,66	6,05	2,28	0,00	0,00	0,00	26°C
1,98	6,06	3,07	2,29	6,05	2,64	2,66	6,04	2,27	0,00	0,00	0,00	25°C
1,98	6,05	3,06	2,29	6,04	2,64	2,65	6,03	2,27	0,00	0,00	0,00	24°C
1,97	6,04	3,06	2,29	6,03	2,63	2,65	6,02	2,27	0,00	0,00	0,00	23°C
1,97	6,03	3,06	2,29	6,01	2,63	2,65	6,00	2,27	0,00	0,00	0,00	22°C
1,97	6,01	3,05	2,28	6,00	2,63	2,65	5,99	2,26	0,00	0,00	0,00	21°C
1,97	6,00	3,05	2,28	5,99	2,63	2,64	5,98	2,26	0,00	0,00	0,00	20°C
1,97	5,99	3,05	2,28	5,98	2,62	2,64	5,97	2,26	3,06	5,96	1,95	19°C
1,96	5,98	3,04	2,28	5,97	2,62	2,64	5,95	2,26	3,06	5,95	1,94	18°C
1,96	5,97	3,04	2,27	5,95	2,62	2,64	5,94	2,25	3,06	5,93	1,94	17°C
1,96	5,95	3,04	2,27	5,94	2,62	2,63	5,93	2,25	3,05	5,92	1,94	16°C
1,96	5,94	3,04	2,27	5,93	2,61	2,63	5,92	2,25	3,05	5,91	1,94	15°C
1,96	5,93	3,03	2,27	5,92	2,61	2,63	5,91	2,25	3,05	5,90	1,94	14°C
1,95	5,92	3,03	2,26	5,90	2,61	2,63	5,89	2,25	3,04	5,88	1,93	13°C
1,95	5,91	3,03	2,26	5,89	2,60	2,62	5,88	2,24	3,04	5,87	1,93	12°C
2,05	5,98	2,91	2,37	5,97	2,52	2,73	5,95	2,19	3,14	5,95	1,89	11°C
2,14	6,04	2,82	2,45	6,04	2,46	2,81	6,04	2,15	3,23	6,04	1,87	10°C
2,25	6,14	2,73	2,56	6,14	2,40	2,91	6,14	2,11	3,33	6,14	1,84	9°C
2,33	6,23	2,67	2,64	6,23	2,36	3,00	6,23	2,08	3,42	6,23	1,82	8°C
2,48	6,38	2,57	2,79	6,38	2,29	3,15	6,38	2,03	3,57	6,38	1,79	7°C
3,21	6,84	2,13	3,45	6,82	1,97	3,73	6,79	1,82	4,04	6,76	1,67	6°C
3,80	7,22	1,90	3,99	7,17	1,80	4,20	7,12	1,69	4,43	7,07	1,59	5°C
4,29	7,53	1,76	4,44	7,46	1,68	4,61	7,40	1,61	4,78	7,33	1,53	4°C
4,67	7,79	1,67	4,80	7,70	1,60	4,94	7,62	1,54	5,08	7,54	1,49	3°C
5,13	8,10	1,58	5,25	8,00	1,52	5,38	7,90	1,47	5,51	7,80	1,42	2°C
5,13	8,02	1,56	5,27	7,94	1,51	5,40	7,85	1,45	5,53	7,80	1,41	1°C
5,16	7,95	1,54	5,31	7,87	1,48	5,45	7,79	1,43	5,61	7,80	1,39	0°C
5,20	7,87	1,51	5,37	7,81	1,45	5,55	7,74	1,40	5,73	7,80	1,36	-1°C
5,25	7,79	1,48	5,47	7,74	1,42	5,68	7,69	1,35	5,90	7,80	1,32	-2°C
5,32	7,72	1,45	5,59	7,68	1,37	5,85	7,64	1,31	6,12	7,80	1,27	-3°C
5,41	7,64	1,41	5,73	7,61	1,33	6,05	7,58	1,25	6,39	7,80	1,22	-4°C
5,51	7,56	1,37	5,90	7,55	1,28	6,30	7,53	1,20	6,72	7,80	1,16	-5°C
5,63	7,49	1,33	6,10	7,48	1,23	6,58	7,48	1,14	7,09	7,80	1,10	-6°C
5,76	7,41	1,29	6,33	7,42	1,17	6,90	7,43	1,08	7,50	7,80	1,04	-7°C
5,43	6,92	1,27	5,79	6,71	1,16	6,15	6,50	1,06	6,57	6,68	1,02	-8°C
5,10	6,44	1,26	5,26	6,01	1,14	5,41	5,58	1,03	5,64	5,57	0,99	-9°C
4,77	5,95	1,25	4,72	5,30	1,12	4,67	4,65	1,00	4,70	4,45	0,95	-10°C
4,82	5,97	1,24	4,79	5,37	1,12	4,75	4,77	1,00	3,00	3,00	1,00	-11°C
4,87	6,00	1,23	4,85	5,44	1,12	4,83	4,88	1,01	3,00	3,00	1,00	-12°C
4,92	6,02	1,22	4,92	5,50	1,12	4,92	4,99	1,01	3,00	3,00	1,00	-13°C
4,97	6,04	1,21	4,99	5,57	1,12	5,00	5,10	1,02	3,00	3,00	1,00	-14°C
5,03	6,06	1,21	5,05	5,64	1,12	5,08	5,21	1,03	3,00	3,00	1,00	-15°C
5,01	6,01	1,20	5,04	5,58	1,11	3,00	3,00	1,00	3,00	3,00	1,00	-16°C
5,00	5,95	1,19	5,02	5,52	1,10	3,00	3,00	1,00	3,00	3,00	1,00	-17°C
4,99	5,89	1,18	5,01	5,46	1,09	3,00	3,00	1,00	3,00	3,00	1,00	-18°C
4,97	5,83	1,17	4,99	5,40	1,08	3,00	3,00	1,00	3,00	3,00	1,00	-19°C
4,96	5,77	1,16	4,97	5,34	1,07	3,00	3,00	1,00	3,00	3,00	1,00	-20°C
4,95	5,71	1,16	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-21°C
4,93	5,66	1,15	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-22°C
4,92	5,60	1,14	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-23°C
4,91	5,54	1,13	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-24°C
4,89	5,48	1,12	3,00	3,00	1,00	3,00	3,00	1,00	3,00	3,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 5 (backup 6kW)

Outdoor temperature		Starting temperature																	
		25°C			30°C			35°C			40°C			45°C		50°C		55°C	
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	Pabs	Pcal	Pabs	Pcal
35°C		1,30	8,87	6,85	1,48	8,76	5,91	1,63	8,52	5,24	1,82	8,39	4,61	2,01	8,29	4,12	2,20	8,19	3,73
34°C		1,29	8,85	6,86	1,48	8,74	5,92	1,62	8,50	5,25	1,82	8,37	4,60	2,01	8,27	4,12	2,20	8,17	3,72
33°C		1,29	8,84	6,87	1,47	8,73	5,93	1,61	8,48	5,26	1,82	8,35	4,60	2,01	8,25	4,12	2,19	8,15	3,72
32°C		1,28	8,82	6,89	1,46	8,71	5,95	1,61	8,47	5,27	1,82	8,34	4,59	2,00	8,24	4,11	2,19	8,14	3,71
31°C		1,28	8,80	6,90	1,46	8,69	5,96	1,60	8,45	5,28	1,81	8,32	4,59	2,00	8,22	4,11	2,19	8,12	3,71
30°C		1,27	8,78	6,92	1,45	8,68	5,97	1,59	8,43	5,29	1,81	8,30	4,58	2,00	8,20	4,10	2,19	8,10	3,71
29°C		1,27	8,77	6,93	1,45	8,66	5,98	1,59	8,41	5,30	1,81	8,29	4,58	2,00	8,19	4,10	2,18	8,09	3,70
28°C		1,26	8,75	6,94	1,44	8,64	5,99	1,58	8,40	5,31	1,81	8,27	4,57	2,00	8,17	4,09	2,18	8,07	3,70
27°C		1,26	8,73	6,96	1,44	8,62	6,01	1,57	8,38	5,32	1,81	8,25	4,57	1,99	8,15	4,09	2,18	8,05	3,69
26°C		1,25	8,71	6,97	1,43	8,61	6,02	1,57	8,36	5,34	1,80	8,24	4,56	1,99	8,14	4,09	2,18	8,04	3,69
25°C		1,25	8,70	6,99	1,42	8,59	6,03	1,56	8,35	5,35	1,80	8,22	4,56	1,99	8,12	4,08	2,18	8,02	3,69
24°C		1,24	8,68	7,00	1,42	8,57	6,04	1,56	8,33	5,36	1,80	8,20	4,55	1,99	8,10	4,08	2,17	8,00	3,68
23°C		1,24	8,66	7,01	1,41	8,55	6,05	1,55	8,31	5,37	1,80	8,19	4,55	1,99	8,09	4,07	2,17	7,99	3,68
22°C		1,23	8,65	7,03	1,41	8,54	6,07	1,54	8,30	5,38	1,80	8,17	4,54	1,98	8,07	4,07	2,17	7,97	3,67
21°C		1,23	8,63	7,04	1,40	8,52	6,08	1,54	8,28	5,39	1,80	8,15	4,54	1,98	8,05	4,06	2,17	7,95	3,67
20°C		1,22	8,61	7,06	1,40	8,50	6,09	1,53	8,26	5,40	1,79	8,14	4,54	1,98	8,04	4,06	2,16	7,94	3,67
19°C		1,22	8,59	7,07	1,39	8,49	6,10	1,52	8,25	5,41	1,79	8,12	4,53	1,98	8,02	4,06	2,16	7,92	3,66
18°C		1,21	8,58	7,08	1,39	8,47	6,11	1,52	8,23	5,42	1,79	8,10	4,53	1,98	8,00	4,05	2,16	7,90	3,66
17°C		1,21	8,56	7,10	1,38	8,45	6,13	1,51	8,22	5,43	1,79	8,09	4,52	1,97	7,99	4,05	2,16	7,89	3,65
16°C		1,20	8,54	7,11	1,37	8,44	6,14	1,51	8,20	5,44	1,79	8,07	4,52	1,97	7,97	4,04	2,16	7,87	3,65
15°C		1,20	8,52	7,13	1,37	8,42	6,15	1,50	8,18	5,45	1,79	8,06	4,51	1,97	7,96	4,04	2,15	7,85	3,65
14°C		1,19	8,51	7,14	1,36	8,40	6,16	1,49	8,17	5,46	1,78	8,04	4,51	1,97	7,94	4,03	2,15	7,84	3,64
13°C		1,19	8,49	7,15	1,36	8,39	6,18	1,49	8,15	5,48	1,78	8,02	4,50	1,97	7,92	4,03	2,15	7,82	3,64
12°C		1,18	8,47	7,17	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
11°C		1,18	8,46	7,18	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
10°C		1,18	8,45	7,19	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
9°C		1,18	8,44	7,20	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
8°C		1,18	8,43	7,21	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
7°C		1,18	8,42	7,22	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
6°C		1,18	8,41	7,23	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
5°C		1,18	8,40	7,24	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
4°C		1,18	8,39	7,25	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
3°C		1,18	8,38	7,26	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
2°C		1,18	8,37	7,27	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
1°C		1,18	8,36	7,28	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
0°C		1,18	8,35	7,29	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-1°C		1,18	8,34	7,30	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-2°C		1,18	8,33	7,31	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-3°C		1,18	8,32	7,32	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-4°C		1,18	8,31	7,33	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-5°C		1,18	8,30	7,34	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-6°C		1,18	8,29	7,35	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-7°C		1,18	8,28	7,36	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-8°C		1,18	8,27	7,37	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-9°C		1,18	8,26	7,38	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-10°C		1,18	8,25	7,39	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-11°C		1,18	8,24	7,40	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-12°C		1,18	8,23	7,41	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-13°C		1,18	8,22	7,42	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-14°C		1,18	8,21	7,43	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-15°C		1,18	8,20	7,44	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-16°C		1,18	8,19	7,45	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-17°C		1,18	8,18	7,46	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-18°C		1,18	8,17	7,47	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-19°C		1,18	8,16	7,48	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-20°C		1,18	8,15	7,49	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-21°C		1,18	8,14	7,50	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-22°C		1,18	8,13	7,51	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-23°C		1,18	8,12	7,52	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-24°C		1,18	8,11	7,53	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63
-25°C		1,18	8,10	7,54	1,35	8,37	6,19	1,48	8,13	5,49	1,78	8,01	4,50	1,96	7,91	4,03	2,15	7,81	3,63

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
2,51	7,99	3,19	2,91	7,89	2,71	3,37	7,79	2,31	0,00	0,00	0,00	35°C
2,50	7,97	3,18	2,90	7,87	2,71	3,37	7,77	2,31	0,00	0,00	0,00	34°C
2,50	7,95	3,18	2,90	7,85	2,71	3,36	7,75	2,31	0,00	0,00	0,00	33°C
2,50	7,94	3,18	2,90	7,84	2,70	3,36	7,73	2,30	0,00	0,00	0,00	32°C
2,50	7,92	3,17	2,89	7,82	2,70	3,36	7,72	2,30	0,00	0,00	0,00	31°C
2,49	7,90	3,17	2,89	7,80	2,70	3,35	7,70	2,30	0,00	0,00	0,00	30°C
2,49	7,89	3,16	2,89	7,78	2,69	3,35	7,68	2,29	0,00	0,00	0,00	29°C
2,49	7,87	3,16	2,89	7,77	2,69	3,35	7,67	2,29	0,00	0,00	0,00	28°C
2,49	7,85	3,16	2,88	7,75	2,69	3,34	7,65	2,29	0,00	0,00	0,00	27°C
2,48	7,84	3,15	2,88	7,73	2,69	3,34	7,63	2,29	0,00	0,00	0,00	26°C
2,48	7,82	3,15	2,88	7,72	2,68	3,34	7,62	2,28	0,00	0,00	0,00	25°C
2,48	7,80	3,15	2,87	7,70	2,68	3,33	7,60	2,28	0,00	0,00	0,00	24°C
2,48	7,79	3,14	2,87	7,69	2,68	3,33	7,58	2,28	0,00	0,00	0,00	23°C
2,47	7,77	3,14	2,87	7,67	2,67	3,33	7,57	2,28	0,00	0,00	0,00	22°C
2,47	7,75	3,14	2,87	7,65	2,67	3,32	7,55	2,27	0,00	0,00	0,00	21°C
2,47	7,74	3,13	2,86	7,64	2,67	3,32	7,54	2,27	0,00	0,00	0,00	20°C
2,47	7,72	3,13	2,86	7,62	2,66	3,32	7,52	2,27	3,84	7,42	1,93	19°C
2,46	7,70	3,13	2,86	7,60	2,66	3,31	7,50	2,27	3,84	7,40	1,93	18°C
2,46	7,69	3,12	2,85	7,59	2,66	3,31	7,49	2,26	3,84	7,39	1,93	17°C
2,46	7,67	3,12	2,85	7,57	2,65	3,31	7,47	2,26	3,83	7,37	1,92	16°C
2,46	7,65	3,12	2,85	7,55	2,65	3,30	7,45	2,26	3,83	7,35	1,92	15°C
2,45	7,64	3,11	2,85	7,54	2,65	3,30	7,44	2,25	3,82	7,34	1,92	14°C
2,45	7,62	3,11	2,84	7,52	2,65	3,30	7,42	2,25	3,82	7,32	1,92	13°C
2,45	7,61	3,10	2,84	7,51	2,64	3,29	7,41	2,25	3,82	7,30	1,91	12°C
2,66	7,77	2,92	3,05	7,67	2,52	3,50	7,57	2,16	4,02	7,47	1,86	11°C
2,83	7,90	2,79	3,22	7,80	2,42	3,68	7,70	2,10	4,20	7,60	1,81	10°C
3,04	8,06	2,65	3,43	7,96	2,32	3,88	7,86	2,03	4,41	7,76	1,76	9°C
3,22	8,20	2,55	3,61	8,10	2,24	4,06	8,00	1,97	4,58	7,90	1,72	8°C
3,52	8,45	2,40	3,91	8,35	2,14	4,36	8,25	1,89	4,88	8,15	1,67	7°C
4,97	9,57	1,92	5,28	9,51	1,80	5,62	9,44	1,68	6,02	9,37	1,56	6°C
6,16	10,49	1,70	6,40	10,45	1,63	6,66	10,41	1,56	6,95	10,37	1,49	5°C
7,14	11,25	1,58	7,33	11,23	1,53	7,54	11,22	1,49	7,75	11,20	1,44	4°C
7,90	11,86	1,50	8,07	11,86	1,47	8,24	11,87	1,44	8,41	11,87	1,41	3°C
8,82	12,63	1,43	8,98	12,65	1,41	9,13	12,68	1,39	9,29	12,70	1,37	2°C
8,81	12,35	1,40	8,96	12,23	1,37	9,11	12,10	1,33	9,26	12,03	1,30	1°C
8,78	12,08	1,38	8,90	11,80	1,33	9,02	11,53	1,28	9,15	11,35	1,24	0°C
8,72	11,81	1,35	8,80	11,38	1,29	8,88	10,95	1,23	8,97	10,68	1,19	-1°C
8,65	11,53	1,33	8,67	10,95	1,26	8,68	10,38	1,19	8,71	10,00	1,15	-2°C
8,55	11,26	1,32	8,49	10,53	1,24	8,43	9,80	1,16	8,39	9,33	1,11	-3°C
8,43	10,99	1,30	8,28	10,11	1,22	8,12	9,23	1,14	7,99	8,65	1,08	-4°C
8,29	10,71	1,29	8,02	9,68	1,21	7,76	8,65	1,12	7,52	7,98	1,06	-5°C
8,13	10,44	1,28	7,73	9,26	1,20	7,34	8,08	1,10	6,97	7,30	1,05	-6°C
7,95	10,17	1,28	7,40	8,83	1,19	6,86	7,50	1,09	6,36	6,63	1,04	-7°C
8,31	10,53	1,27	7,95	9,43	1,19	7,58	8,33	1,10	7,29	7,78	1,07	-8°C
8,68	10,90	1,26	8,49	10,03	1,18	8,30	9,17	1,10	8,23	8,94	1,09	-9°C
9,05	11,27	1,25	9,04	10,63	1,18	9,03	10,00	1,11	9,17	10,10	1,10	-10°C
9,00	10,94	1,22	8,99	10,32	1,15	8,99	9,69	1,08	6,00	6,00	1,00	-11°C
8,95	10,61	1,19	8,95	10,00	1,12	8,95	9,38	1,05	6,00	6,00	1,00	-12°C
8,90	10,28	1,16	8,90	9,68	1,09	8,91	9,08	1,02	6,00	6,00	1,00	-13°C
8,85	9,95	1,12	8,86	9,36	1,06	8,87	8,77	0,99	6,00	6,00	1,00	-14°C
8,80	9,62	1,09	8,82	9,04	1,03	8,83	8,46	0,96	6,00	6,00	1,00	-15°C
8,79	9,53	1,08	8,80	8,96	1,02	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
8,78	9,44	1,07	8,78	8,87	1,01	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
8,77	9,34	1,07	8,76	8,79	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
8,76	9,25	1,06	8,75	8,70	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
8,75	9,16	1,05	8,73	8,62	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
8,75	9,07	1,04	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
8,74	8,97	1,03	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
8,73	8,88	1,02	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
8,72	8,79	1,01	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
8,71	8,70	1,00	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 7 / 7TRI (backup 6kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	1,17	9,16	7,82	1,50	9,16	6,11	1,72	9,08	5,28	2,08	9,07	4,36	2,42	9,14	3,78	2,75	9,25	3,36	3,09	9,44	3,05
	34°C	1,17	9,14	7,83	1,49	9,14	6,12	1,71	9,07	5,29	2,08	9,06	4,36	2,41	9,12	3,78	2,75	9,23	3,36	3,09	9,44	3,06
	33°C	1,16	9,12	7,85	1,49	9,12	6,14	1,71	9,05	5,30	2,08	9,04	4,35	2,41	9,10	3,77	2,75	9,21	3,35	3,09	9,44	3,06
	32°C	1,16	9,10	7,86	1,48	9,10	6,15	1,70	9,03	5,31	2,07	9,02	4,35	2,41	9,09	3,77	2,75	9,20	3,35	3,08	9,44	3,06
	31°C	1,15	9,08	7,88	1,47	9,08	6,16	1,69	9,01	5,32	2,07	9,00	4,35	2,41	9,07	3,77	2,74	9,19	3,35	3,08	9,44	3,07
	30°C	1,15	9,06	7,89	1,47	9,06	6,17	1,69	8,99	5,33	2,07	8,98	4,34	2,41	9,05	3,76	2,74	9,19	3,35	3,08	9,44	3,07
	29°C	1,14	9,05	7,91	1,46	9,05	6,19	1,68	8,98	5,34	2,07	8,97	4,34	2,40	9,03	3,76	2,74	9,19	3,36	3,07	9,44	3,07
	28°C	1,14	9,03	7,93	1,46	9,03	6,20	1,67	8,96	5,35	2,07	8,95	4,33	2,40	9,01	3,75	2,74	9,19	3,36	3,07	9,44	3,07
	27°C	1,13	9,01	7,94	1,45	9,01	6,21	1,67	8,94	5,36	2,06	8,93	4,33	2,40	9,00	3,75	2,73	9,19	3,36	3,07	9,44	3,08
	26°C	1,13	8,99	7,96	1,45	8,99	6,22	1,66	8,92	5,37	2,06	8,91	4,32	2,40	8,98	3,75	2,73	9,19	3,37	3,06	9,44	3,08
	25°C	1,13	8,97	7,97	1,44	8,97	6,24	1,65	8,91	5,38	2,06	8,90	4,32	2,39	8,96	3,74	2,73	9,19	3,37	3,06	9,44	3,08
	24°C	1,12	8,96	7,99	1,43	8,96	6,25	1,65	8,89	5,40	2,06	8,88	4,32	2,39	8,94	3,74	2,72	9,19	3,37	3,06	9,44	3,09
	23°C	1,12	8,94	8,01	1,43	8,94	6,26	1,64	8,87	5,41	2,06	8,86	4,31	2,39	8,94	3,74	2,72	9,19	3,38	3,05	9,44	3,09
	22°C	1,11	8,92	8,02	1,42	8,92	6,27	1,63	8,85	5,42	2,05	8,84	4,31	2,39	8,94	3,75	2,72	9,19	3,38	3,05	9,44	3,09
	21°C	1,11	8,90	8,04	1,42	8,90	6,29	1,63	8,83	5,43	2,05	8,82	4,30	2,38	8,94	3,75	2,72	9,19	3,38	3,05	9,44	3,10
	20°C	1,10	8,89	8,05	1,41	8,89	6,30	1,62	8,82	5,44	2,05	8,81	4,30	2,38	8,94	3,76	2,71	9,19	3,39	3,05	9,44	3,10
	19°C	1,10	8,87	8,07	1,41	8,87	6,31	1,61	8,80	5,45	2,05	8,79	4,29	2,38	8,94	3,76	2,71	9,19	3,39	3,04	9,44	3,10
	18°C	1,09	8,85	8,09	1,40	8,85	6,32	1,61	8,78	5,46	2,05	8,77	4,29	2,38	8,94	3,76	2,71	9,19	3,39	3,04	9,44	3,11
	17°C	1,09	8,83	8,10	1,39	8,83	6,34	1,60	8,76	5,47	2,04	8,75	4,29	2,37	8,94	3,77	2,71	9,19	3,40	3,04	9,44	3,11
	16°C	1,09	8,81	8,12	1,39	8,81	6,35	1,60	8,75	5,48	2,04	8,74	4,28	2,37	8,94	3,77	2,70	9,19	3,40	3,03	9,44	3,11
	15°C	1,08	8,80	8,13	1,38	8,80	6,36	1,59	8,73	5,49	2,04	8,72	4,28	2,37	8,94	3,77	2,70	9,19	3,40	3,03	9,44	3,11
	14°C	1,08	8,78	8,15	1,38	8,78	6,37	1,58	8,71	5,50	2,04	8,70	4,27	2,37	8,94	3,78	2,70	9,19	3,41	3,03	9,44	3,12
	13°C	1,07	8,76	8,17	1,37	8,76	6,39	1,58	8,69	5,51	2,03	8,70	4,27	2,36	8,94	3,78	2,69	9,19	3,41	3,02	9,44	3,12
	12°C	1,07	8,74	8,18	1,37	8,74	6,40	1,57	8,68	5,53	2,03	8,70	4,28	2,36	8,94	3,79	2,69	9,19	3,41	3,02	9,44	3,12
	11°C	1,34	8,92	6,64	1,62	8,92	5,51	1,82	8,87	4,87	2,24	8,91	3,97	2,57	9,15	3,56	2,90	9,40	3,24	3,23	9,65	2,99
10°C	1,59	9,07	5,71	1,84	9,07	4,92	2,04	9,04	4,43	2,42	9,09	3,76	2,75	9,33	3,40	3,08	9,58	3,11	3,41	9,83	2,89	
9°C	1,86	9,26	4,97	2,10	9,26	4,41	2,29	9,24	4,03	2,63	9,30	3,54	2,96	9,54	3,23	3,28	9,79	2,98	3,61	10,04	2,78	
8°C	2,11	9,41	4,46	2,32	9,41	4,05	2,51	9,40	3,74	2,80	9,48	3,38	3,13	9,72	3,10	3,46	9,97	2,88	3,79	10,22	2,70	
7°C	2,47	9,68	3,91	2,66	9,68	3,63	2,83	9,68	3,42	3,10	9,78	3,15	3,43	10,02	2,92	3,76	10,27	2,73	4,09	10,52	2,57	
6°C	3,95	10,43	2,64	4,09	10,43	2,55	4,25	10,44	2,45	4,48	10,52	2,35	4,75	10,71	2,25	5,02	10,90	2,17	5,28	11,09	2,10	
5°C	5,15	11,02	2,14	5,25	11,04	2,10	5,41	11,05	2,04	5,61	11,11	1,98	5,83	11,25	1,93	6,05	11,39	1,88	6,27	11,53	1,84	
4°C	6,13	11,53	1,88	6,21	11,55	1,86	6,37	11,56	1,82	6,54	11,61	1,78	6,73	11,71	1,74	6,91	11,81	1,71	7,10	11,91	1,68	
3°C	6,91	11,94	1,73	6,96	11,96	1,72	7,12	11,98	1,68	7,28	12,02	1,65	7,45	12,09	1,62	7,61	12,16	1,60	7,78	12,22	1,57	
2°C	7,82	12,45	1,59	7,87	12,47	1,58	8,03	12,50	1,56	8,19	12,52	1,53	8,35	12,55	1,50	8,50	12,58	1,48	8,66	12,60	1,46	
1°C	7,83	12,70	1,62	7,88	12,67	1,61	8,04	12,65	1,57	8,19	12,66	1,54	8,35	12,67	1,52	8,51	12,58	1,48	8,67	12,59	1,45	
0°C	7,86	12,96	1,65	7,91	12,87	1,63	8,06	12,80	1,59	8,21	12,79	1,56	8,36	12,78	1,53	8,52	12,58	1,48	8,68	12,58	1,45	
-1°C	7,90	13,21	1,67	7,95	13,07	1,64	8,10	12,95	1,60	8,24	12,92	1,57	8,39	12,90	1,54	8,53	12,58	1,47	8,70	12,57	1,44	
-2°C	7,95	13,47	1,69	8,01	13,28	1,66	8,15	13,09	1,61	8,28	13,06	1,58	8,42	13,02	1,55	8,56	12,59	1,47	8,74	12,56	1,44	
-3°C	8,03	13,73	1,71	8,08	13,48	1,67	8,21	13,24	1,61	8,34	13,19	1,58	8,46	13,14	1,55	8,59	12,59	1,47	8,78	12,55	1,43	
-4°C	8,12	13,98	1,72	8,17	13,68	1,67	8,29	13,39	1,61	8,40	13,32	1,59	8,51	13,25	1,56	8,63	12,59	1,46	8,83	12,53	1,42	
-5°C	8,22	14,24	1,73	8,28	13,88	1,68	8,39	13,54	1,61	8,48	13,46	1,59	8,57	13,37	1,56	8,67	12,60	1,45	8,89	12,52	1,41	
-6°C	8,34	14,49	1,74	8,40	14,08	1,68	8,50	13,69	1,61	8,57	13,59	1,59	8,64	13,49	1,56	8,72	12,60	1,44	8,96	12,51	1,40	
-7°C	8,48	14,75	1,74	8,54	14,28	1,67	8,62	13,84	1,61	8,67	13,72	1,58	8,71	13,60	1,56	8,78	12,60	1,44	9,04	12,50	1,38	
-8°C	8,45	14,59	1,73	8,53	14,10	1,65	8,62	13,63	1,58	8,69	13,44	1,55	8,76	13,25	1,51	8,84	12,48	1,41	9,04	12,30	1,36	
-9°C	8,43	14,43	1,71	8,52	13,91	1,63	8,62	13,41	1,56	8,71	13,16	1,51	8,80	12,90	1,47	8,89	12,35	1,39	9,05	12,10	1,34	
-10°C	8,40	14,26	1,70	8,51	13,73	1,61	8,62	13,20	1,53	8,73	12,88	1,48	8,84	12,55	1,42	8,95	12,23	1,37	9,06	11,90	1,31	
-11°C	8,34	13,79	1,65	8,46	13,32	1,57	8,57	12,86	1,50	8,68	12,55	1,45	8,79	12,25	1,39	8,90	11,94	1,34	9,00	11,56	1,28	
-12°C	8,29	13,31	1,61	8,41	12,91	1,54	8,53	12,51	1,47	8,63	12,23	1,42	8,74	11,96	1,37	8,84	11,65	1,32	8,95	11,22	1,25	
-13°C	8,24	12,84	1,56	8,36	12,50	1,50	8,48	12,17	1,43	8,59	11,91	1,39	8,69	11,66	1,34	8,79	11,36	1,29	8,89	10,88	1,22	

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
3,25	9,69	2,98	3,77	9,94	2,64	4,37	10,18	2,33	0,00	0,00	0,00	35°C
3,25	9,69	2,99	3,76	9,94	2,64	4,36	10,18	2,34	0,00	0,00	0,00	34°C
3,24	9,69	2,99	3,76	9,94	2,64	4,36	10,18	2,34	0,00	0,00	0,00	33°C
3,24	9,69	2,99	3,75	9,94	2,65	4,35	10,18	2,34	0,00	0,00	0,00	32°C
3,24	9,69	2,99	3,75	9,94	2,65	4,35	10,18	2,34	0,00	0,00	0,00	31°C
3,23	9,69	3,00	3,75	9,94	2,65	4,34	10,18	2,34	0,00	0,00	0,00	30°C
3,23	9,69	3,00	3,74	9,94	2,65	4,34	10,18	2,35	0,00	0,00	0,00	29°C
3,23	9,69	3,00	3,74	9,94	2,66	4,34	10,18	2,35	0,00	0,00	0,00	28°C
3,22	9,69	3,01	3,74	9,94	2,66	4,33	10,18	2,35	0,00	0,00	0,00	27°C
3,22	9,69	3,01	3,73	9,94	2,66	4,33	10,18	2,35	0,00	0,00	0,00	26°C
3,22	9,69	3,01	3,73	9,94	2,66	4,32	10,18	2,36	0,00	0,00	0,00	25°C
3,21	9,69	3,02	3,72	9,94	2,67	4,32	10,18	2,36	0,00	0,00	0,00	24°C
3,21	9,69	3,02	3,72	9,94	2,67	4,31	10,18	2,36	0,00	0,00	0,00	23°C
3,21	9,69	3,02	3,72	9,94	2,67	4,31	10,18	2,36	0,00	0,00	0,00	22°C
3,20	9,69	3,02	3,71	9,94	2,68	4,31	10,18	2,37	0,00	0,00	0,00	21°C
3,20	9,69	3,03	3,71	9,94	2,68	4,30	10,18	2,37	0,00	0,00	0,00	20°C
3,20	9,69	3,03	3,71	9,94	2,68	4,30	10,18	2,37	4,98	10,43	2,09	19°C
3,19	9,69	3,03	3,70	9,94	2,68	4,29	10,18	2,37	4,98	10,43	2,10	18°C
3,19	9,69	3,04	3,70	9,94	2,69	4,29	10,18	2,38	4,97	10,43	2,10	17°C
3,19	9,69	3,04	3,70	9,94	2,69	4,28	10,18	2,38	4,97	10,43	2,10	16°C
3,18	9,69	3,04	3,69	9,94	2,69	4,28	10,18	2,38	4,96	10,43	2,10	15°C
3,18	9,69	3,05	3,69	9,94	2,69	4,28	10,18	2,38	4,96	10,43	2,11	14°C
3,18	9,69	3,05	3,68	9,94	2,70	4,27	10,18	2,38	4,95	10,43	2,11	13°C
3,17	9,69	3,05	3,68	9,94	2,70	4,27	10,18	2,39	4,95	10,43	2,11	12°C
3,38	9,90	2,93	3,89	10,15	2,61	4,47	10,39	2,32	5,15	10,64	2,07	11°C
3,56	10,08	2,83	4,06	10,33	2,54	4,65	10,57	2,28	5,33	10,82	2,03	10°C
3,77	10,29	2,73	4,27	10,54	2,47	4,85	10,78	2,22	5,53	11,03	1,99	9°C
3,94	10,47	2,66	4,45	10,72	2,41	5,03	10,96	2,18	5,71	11,21	1,96	8°C
4,24	10,77	2,54	4,74	11,02	2,32	5,33	11,26	2,12	6,00	11,51	1,92	7°C
5,44	11,28	2,07	5,82	11,47	1,97	6,25	11,65	1,87	6,73	11,84	1,76	6°C
6,42	11,67	1,82	6,70	11,81	1,76	7,01	11,95	1,70	7,36	12,09	1,64	5°C
7,25	12,01	1,66	7,47	12,11	1,62	7,69	12,20	1,59	7,93	12,30	1,55	4°C
7,93	12,29	1,55	8,10	12,36	1,52	8,28	12,42	1,50	8,46	12,49	1,48	3°C
8,82	12,63	1,43	8,98	12,65	1,41	9,13	12,68	1,39	9,29	12,71	1,37	2°C
8,83	12,60	1,43	8,98	12,60	1,40	9,14	12,60	1,38	9,30	12,67	1,36	1°C
8,85	12,56	1,42	9,01	12,55	1,39	9,18	12,53	1,37	9,34	12,63	1,35	0°C
8,88	12,53	1,41	9,05	12,49	1,38	9,23	12,45	1,35	9,41	12,60	1,34	-1°C
8,92	12,50	1,40	9,11	12,44	1,36	9,30	12,38	1,33	9,50	12,56	1,32	-2°C
8,98	12,46	1,39	9,19	12,38	1,35	9,40	12,30	1,31	9,62	12,52	1,30	-3°C
9,06	12,43	1,37	9,28	12,33	1,33	9,51	12,23	1,29	9,76	12,49	1,28	-4°C
9,14	12,40	1,36	9,40	12,27	1,31	9,65	12,15	1,26	9,93	12,45	1,25	-5°C
9,24	12,37	1,34	9,52	12,22	1,28	9,81	12,08	1,23	10,13	12,41	1,23	-6°C
9,35	12,33	1,32	9,67	12,17	1,26	9,99	12,00	1,20	10,35	12,38	1,20	-7°C
9,24	11,88	1,29	9,43	11,46	1,22	9,62	11,03	1,15	9,89	11,22	1,13	-8°C
9,12	11,42	1,25	9,18	10,75	1,17	9,25	10,07	1,09	9,43	10,06	1,07	-9°C
9,00	10,97	1,22	8,94	10,04	1,12	8,88	9,10	1,03	8,97	8,90	0,99	-10°C
8,96	10,70	1,19	8,91	9,84	1,10	8,87	8,97	1,01	6,00	6,00	1,00	-11°C
8,92	10,43	1,17	8,89	9,64	1,08	8,86	8,85	1,00	6,00	6,00	1,00	-12°C
8,88	10,16	1,14	8,86	9,44	1,06	8,85	8,72	0,99	6,00	6,00	1,00	-13°C
8,84	9,89	1,12	8,84	9,24	1,05	8,84	8,59	0,97	6,00	6,00	1,00	-14°C
8,80	9,62	1,09	8,82	9,04	1,03	8,83	8,46	0,96	6,00	6,00	1,00	-15°C
8,79	9,53	1,08	8,80	8,96	1,02	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
8,78	9,44	1,07	8,78	8,87	1,01	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
8,77	9,34	1,07	8,76	8,79	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
8,76	9,25	1,06	8,75	8,70	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
8,75	9,16	1,05	8,73	8,62	0,99	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
8,75	9,07	1,04	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
8,74	8,97	1,03	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
8,73	8,88	1,02	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
8,72	8,79	1,01	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
8,71	8,70	1,00	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 9 (backup 6kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1,91	13,33	6,98	2,37	13,33	5,63	2,69	13,13	4,89	3,22	13,10	4,06	3,68	13,15	3,57	4,14	13,23	3,20	4,60	13,34	2,90
34°C	1,90	13,30	6,99	2,36	13,30	5,64	2,68	13,11	4,90	3,22	13,07	4,06	3,68	13,12	3,57	4,14	13,21	3,19	4,59	13,31	2,90
33°C	1,89	13,27	7,01	2,35	13,27	5,65	2,67	13,08	4,91	3,22	13,05	4,06	3,67	13,10	3,56	4,13	13,18	3,19	4,59	13,29	2,89
32°C	1,89	13,25	7,02	2,34	13,25	5,66	2,65	13,06	4,92	3,21	13,02	4,05	3,67	13,07	3,56	4,13	13,16	3,19	4,59	13,26	2,89
31°C	1,88	13,22	7,04	2,33	13,22	5,67	2,64	13,03	4,93	3,21	13,00	4,05	3,67	13,04	3,56	4,12	13,13	3,18	4,58	13,24	2,89
30°C	1,87	13,19	7,05	2,32	13,19	5,69	2,63	13,00	4,94	3,21	12,97	4,04	3,66	13,02	3,55	4,12	13,10	3,18	4,58	13,21	2,89
29°C	1,86	13,17	7,06	2,31	13,17	5,70	2,62	12,98	4,95	3,20	12,94	4,04	3,66	12,99	3,55	4,12	13,08	3,18	4,57	13,18	2,88
28°C	1,86	13,14	7,08	2,30	13,14	5,71	2,61	12,95	4,96	3,20	12,92	4,04	3,66	12,97	3,55	4,11	13,05	3,17	4,57	13,16	2,88
27°C	1,85	13,11	7,09	2,29	13,11	5,72	2,60	12,93	4,97	3,20	12,89	4,03	3,65	12,94	3,54	4,11	13,03	3,17	4,56	13,13	2,88
26°C	1,84	13,09	7,11	2,28	13,09	5,73	2,59	12,90	4,98	3,19	12,87	4,03	3,65	12,92	3,54	4,10	13,00	3,17	4,56	13,11	2,88
25°C	1,83	13,06	7,12	2,27	13,06	5,74	2,58	12,87	4,99	3,19	12,84	4,02	3,64	12,89	3,54	4,10	12,97	3,17	4,55	13,08	2,87
24°C	1,83	13,04	7,13	2,27	13,04	5,75	2,57	12,85	5,00	3,19	12,81	4,02	3,64	12,86	3,53	4,10	12,95	3,16	4,55	13,05	2,87
23°C	1,82	13,01	7,15	2,26	13,01	5,77	2,56	12,82	5,01	3,18	12,79	4,02	3,64	12,84	3,53	4,09	12,92	3,16	4,54	13,03	2,87
22°C	1,81	12,98	7,16	2,25	12,98	5,78	2,55	12,80	5,02	3,18	12,76	4,01	3,63	12,81	3,53	4,09	12,90	3,16	4,54	13,00	2,86
21°C	1,81	12,96	7,18	2,24	12,96	5,79	2,54	12,77	5,03	3,18	12,74	4,01	3,63	12,79	3,52	4,08	12,87	3,15	4,54	12,98	2,86
20°C	1,80	12,93	7,19	2,23	12,93	5,80	2,53	12,75	5,04	3,17	12,71	4,00	3,63	12,76	3,52	4,08	12,85	3,15	4,53	12,97	2,86
19°C	1,79	12,91	7,21	2,22	12,91	5,81	2,52	12,72	5,05	3,17	12,69	4,00	3,62	12,74	3,52	4,07	12,82	3,15	4,53	12,97	2,87
18°C	1,78	12,88	7,22	2,21	12,88	5,82	2,51	12,70	5,06	3,17	12,66	4,00	3,62	12,71	3,51	4,07	12,80	3,14	4,52	12,97	2,87
17°C	1,78	12,85	7,23	2,20	12,85	5,83	2,50	12,67	5,07	3,17	12,64	3,99	3,62	12,69	3,51	4,07	12,78	3,14	4,52	12,97	2,87
16°C	1,77	12,83	7,25	2,19	12,83	5,85	2,49	12,65	5,08	3,16	12,61	3,99	3,61	12,66	3,50	4,06	12,78	3,15	4,51	12,97	2,87
15°C	1,76	12,80	7,26	2,19	12,80	5,86	2,48	12,62	5,09	3,16	12,59	3,98	3,61	12,64	3,50	4,06	12,78	3,15	4,51	12,97	2,88
14°C	1,76	12,78	7,28	2,18	12,78	5,87	2,47	12,59	5,10	3,16	12,56	3,98	3,61	12,61	3,50	4,05	12,78	3,15	4,50	12,97	2,88
13°C	1,75	12,75	7,29	2,17	12,75	5,88	2,46	12,57	5,11	3,15	12,54	3,98	3,60	12,59	3,50	4,05	12,78	3,16	4,50	12,97	2,88
12°C	1,74	12,73	7,31	2,16	12,73	5,89	2,45	12,54	5,12	3,15	12,51	3,97	3,60	12,59	3,50	4,05	12,78	3,16	4,49	12,97	2,89
11°C	1,99	12,86	6,45	2,41	12,86	5,35	2,72	12,72	4,68	3,36	12,68	3,78	3,80	12,80	3,36	4,25	12,99	3,05	4,70	13,18	2,80
10°C	2,22	12,96	5,85	2,62	12,96	4,94	2,96	12,86	4,35	3,53	12,83	3,63	3,98	12,98	3,26	4,43	13,17	2,97	4,88	13,36	2,74
9°C	2,47	13,09	5,30	2,87	13,09	4,56	3,23	13,04	4,04	3,74	13,00	3,48	4,19	13,19	3,15	4,63	13,38	2,89	5,08	13,57	2,67
8°C	2,69	13,19	4,90	3,08	13,19	4,28	3,46	13,18	3,80	3,92	13,18	3,37	4,36	13,37	3,06	4,81	13,56	2,82	5,26	13,75	2,62
7°C	3,03	13,41	4,42	3,42	13,41	3,92	3,79	13,41	3,53	4,21	13,48	3,20	4,66	13,67	2,93	5,11	13,86	2,71	5,55	14,05	2,53
6°C	4,69	14,57	3,11	5,05	14,51	2,88	5,38	14,45	2,69	5,74	14,45	2,52	6,11	14,53	2,38	6,49	14,61	2,25	6,86	14,69	2,14
5°C	6,03	15,52	2,57	6,37	15,41	2,42	6,66	15,30	2,30	6,97	15,23	2,18	7,29	15,22	2,09	7,61	15,20	2,00	7,93	15,19	1,91
4°C	7,12	16,32	2,29	7,44	16,17	2,17	7,71	16,02	2,08	7,99	15,89	1,99	8,27	15,80	1,91	8,55	15,71	1,84	8,83	15,62	1,77
3°C	7,95	16,96	2,13	8,26	16,77	2,03	8,52	16,59	1,95	8,77	16,42	1,87	9,03	16,27	1,80	9,29	16,12	1,74	9,55	15,97	1,67
2°C	8,89	17,75	2,00	9,20	17,52	1,91	9,45	17,30	1,83	9,69	17,07	1,76	9,94	16,85	1,69	10,19	16,63	1,63	10,44	16,40	1,57
1°C	8,90	17,70	1,99	9,20	17,45	1,90	9,45	17,21	1,82	9,70	16,99	1,75	9,95	16,77	1,69	10,19	16,47	1,62	10,45	16,22	1,55
0°C	8,93	17,65	1,98	9,23	17,38	1,88	9,47	17,12	1,81	9,71	16,91	1,74	9,95	16,70	1,68	10,19	16,32	1,60	10,47	16,03	1,53
-1°C	8,98	17,60	1,96	9,27	17,30	1,87	9,51	17,03	1,79	9,74	16,82	1,73	9,96	16,62	1,67	10,19	16,17	1,59	10,50	15,85	1,51
-2°C	9,06	17,55	1,94	9,32	17,23	1,85	9,56	16,94	1,77	9,77	16,74	1,71	9,98	16,55	1,66	10,19	16,02	1,57	10,54	15,67	1,49
-3°C	9,15	17,50	1,91	9,39	17,15	1,83	9,63	16,84	1,75	9,81	16,66	1,70	10,00	16,47	1,65	10,19	15,87	1,56	10,60	15,48	1,46
-4°C	9,27	17,45	1,88	9,48	17,08	1,80	9,71	16,75	1,73	9,87	16,57	1,68	10,02	16,39	1,64	10,19	15,72	1,54	10,67	15,30	1,43
-5°C	9,41	17,40	1,85	9,58	17,00	1,77	9,80	16,66	1,70	9,93	16,49	1,66	10,05	16,32	1,62	10,19	15,56	1,53	10,75	15,12	1,41
-6°C	9,57	17,35	1,81	9,70	16,93	1,75	9,91	16,57	1,67	10,00	16,41	1,64	10,09	16,24	1,61	10,19	15,41	1,51	10,84	14,93	1,38
-7°C	9,75	17,30	1,78	9,83	16,86	1,71	10,03	16,48	1,64	10,08	16,32	1,62	10,12	16,17	1,60	10,19	15,26	1,50	10,94	14,75	1,35
-8°C	9,95	17,14	1,72	10,01	16,67	1,67	10,14	16,25	1,60	10,17	15,99	1,57	10,20	15,73	1,54	10,25	14,97	1,46	10,75	14,47	1,35
-9°C	10,15	16,98	1,67	10,18	16,49	1,62	10,25	16,03	1,56	10,26	15,66	1,53	10,28	15,29	1,49	10,31	14,67	1,42	10,56	14,18	1,34
-10°C	10,35	16,82	1,63	10,35	16,31	1,58	10,36	15,80	1,53	10,36	15,33	1,48	10,36	14,85	1,43	10,36	14,38	1,39	10,36	13,90	1,34
-11°C	10,17	16,40	1,61	10,21	15,98	1,56	10,26	15,55	1,52	10,29	15,15	1,47	10,32	14,75	1,43	10,36	14,33	1,38	10,39	13,78	1,33
-12°C	9,99	15,98	1,60	10,07	15,64	1,55	10,16	15,30	1,51	10,22	14,98	1,47	10,29	14,66	1,42	10,35	14,28	1,38	10,41	13,66	1,31
-13°C	9,81	15,56	1,59	9,93	15,31	1,54	10,06	15,05	1,50	10,16	14,81	1,46	10,25	14,56	1,42	10,34	14,23	1,38	10,44	13,55	1,30
-14°C	9,62	15,14	1,57	9,79	14,97	1,53	9,96	14,80	1,49	10,09	14,63	1,45	10,21	14,47	1,42	10,34	14,18	1,37	10,46	13,43	1,28

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,83	13,46	2,78	5,60	13,59	2,43	6,49	13,73	2,11	#DIV/0!	0,00	#DIV/0!	35°C
4,83	13,43	2,78	5,60	13,56	2,42	6,49	13,70	2,11	#DIV/0!	0,00	#DIV/0!	34°C
4,82	13,41	2,78	5,59	13,54	2,42	6,48	13,67	2,11	#DIV/0!	0,00	#DIV/0!	33°C
4,82	13,38	2,78	5,59	13,51	2,42	6,48	13,65	2,11	#DIV/0!	0,00	#DIV/0!	32°C
4,81	13,35	2,77	5,58	13,48	2,42	6,47	13,62	2,11	#DIV/0!	0,00	#DIV/0!	31°C
4,81	13,33	2,77	5,57	13,46	2,41	6,46	13,60	2,10	#DIV/0!	0,00	#DIV/0!	30°C
4,80	13,30	2,77	5,57	13,43	2,41	6,46	13,57	2,10	#DIV/0!	0,00	#DIV/0!	29°C
4,80	13,28	2,77	5,56	13,41	2,41	6,45	13,54	2,10	#DIV/0!	0,00	#DIV/0!	28°C
4,79	13,25	2,76	5,56	13,38	2,41	6,44	13,54	2,10	#DIV/0!	0,00	#DIV/0!	27°C
4,79	13,23	2,76	5,55	13,36	2,41	6,44	13,54	2,10	#DIV/0!	0,00	#DIV/0!	26°C
4,78	13,20	2,76	5,55	13,35	2,41	6,43	13,54	2,11	#DIV/0!	0,00	#DIV/0!	25°C
4,78	13,17	2,76	5,54	13,35	2,41	6,42	13,54	2,11	#DIV/0!	0,00	#DIV/0!	24°C
4,78	13,16	2,76	5,54	13,35	2,41	6,42	13,54	2,11	#DIV/0!	0,00	#DIV/0!	23°C
4,77	13,16	2,76	5,53	13,35	2,41	6,41	13,54	2,11	#DIV/0!	0,00	#DIV/0!	22°C
4,77	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,11	#DIV/0!	0,00	#DIV/0!	21°C
4,76	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,12	#DIV/0!	0,00	#DIV/0!	20°C
4,76	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,41	13,73	1,85	19°C
4,75	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,40	13,73	1,85	18°C
4,75	13,16	2,77	5,50	13,35	2,43	6,38	13,54	2,12	7,40	13,73	1,86	17°C
4,74	13,16	2,78	5,50	13,35	2,43	6,37	13,54	2,12	7,39	13,73	1,86	16°C
4,74	13,16	2,78	5,49	13,35	2,43	6,37	13,54	2,13	7,38	13,73	1,86	15°C
4,73	13,16	2,78	5,49	13,35	2,43	6,36	13,54	2,13	7,37	13,73	1,86	14°C
4,73	13,16	2,78	5,48	13,35	2,44	6,35	13,54	2,13	7,37	13,73	1,86	13°C
4,72	13,16	2,79	5,48	13,35	2,44	6,35	13,54	2,13	7,36	13,73	1,87	12°C
4,93	13,37	2,71	5,68	13,56	2,39	6,55	13,75	2,10	7,56	13,94	1,84	11°C
5,10	13,55	2,65	5,85	13,74	2,35	6,72	13,93	2,07	7,73	14,12	1,83	10°C
5,31	13,76	2,59	6,06	13,95	2,30	6,93	14,14	2,04	7,94	14,33	1,81	9°C
5,48	13,94	2,54	6,23	14,13	2,27	7,10	14,32	2,02	8,11	14,51	1,79	8°C
5,78	14,24	2,46	6,53	14,43	2,21	7,40	14,62	1,98	8,40	14,81	1,76	7°C
7,10	14,77	2,08	7,67	14,85	1,94	8,31	14,93	1,80	9,05	15,01	1,66	6°C
8,18	15,18	1,86	8,61	15,16	1,76	9,08	15,15	1,67	9,60	15,14	1,58	5°C
9,08	15,53	1,71	9,40	15,44	1,64	9,75	15,35	1,57	10,12	15,26	1,51	4°C
9,79	15,82	1,62	10,06	15,67	1,56	10,34	15,53	1,50	10,62	15,38	1,45	3°C
10,69	16,18	1,51	10,94	15,95	1,46	11,19	15,73	1,40	11,44	15,50	1,35	2°C
10,71	15,91	1,49	10,97	15,61	1,42	11,23	15,31	1,36	11,49	15,09	1,31	1°C
10,76	15,65	1,45	11,05	15,28	1,38	11,34	14,90	1,31	11,63	14,68	1,26	0°C
10,84	15,39	1,42	11,18	14,94	1,34	11,52	14,48	1,26	11,87	14,27	1,20	-1°C
10,95	15,13	1,38	11,37	14,60	1,28	11,78	14,07	1,19	12,20	13,86	1,14	-2°C
11,10	14,87	1,34	11,60	14,26	1,23	12,10	13,66	1,13	12,63	13,45	1,06	-3°C
11,28	14,61	1,30	11,89	13,93	1,17	12,50	13,24	1,06	13,15	13,04	0,99	-4°C
11,49	14,35	1,25	12,23	13,59	1,11	12,98	12,83	0,99	13,77	12,63	0,92	-5°C
11,73	14,09	1,20	12,63	13,25	1,05	13,52	12,41	0,92	14,48	12,22	0,84	-6°C
12,01	13,83	1,15	13,08	12,92	0,99	14,14	12,00	0,85	15,29	11,81	0,77	-7°C
11,39	13,43	1,18	12,03	12,40	1,03	12,67	11,36	0,90	13,43	11,14	0,83	-8°C
10,77	13,03	1,21	10,98	11,87	1,08	11,19	10,72	0,96	11,58	10,46	0,90	-9°C
10,15	12,63	1,24	9,93	11,35	1,14	9,72	10,08	1,04	9,72	9,78	1,01	-10°C
10,22	12,60	1,23	10,05	11,41	1,14	9,88	10,23	1,04	6,00	6,00	1,00	-11°C
10,29	12,57	1,22	10,17	11,48	1,13	10,05	10,38	1,03	6,00	6,00	1,00	-12°C
10,37	12,54	1,21	10,29	11,54	1,12	10,22	10,53	1,03	6,00	6,00	1,00	-13°C
10,44	12,51	1,20	10,41	11,60	1,11	10,39	10,69	1,03	6,00	6,00	1,00	-14°C
10,51	12,49	1,19	10,53	11,66	1,11	10,55	10,84	1,03	6,00	6,00	1,00	-15°C
10,52	12,39	1,18	10,54	11,55	1,10	6,00	6,00	1,00	6,00	6,00	1,00	-16°C
10,54	12,30	1,17	10,55	11,43	1,08	6,00	6,00	1,00	6,00	6,00	1,00	-17°C
10,55	12,21	1,16	10,56	11,32	1,07	6,00	6,00	1,00	6,00	6,00	1,00	-18°C
10,57	12,11	1,15	10,57	11,21	1,06	6,00	6,00	1,00	6,00	6,00	1,00	-19°C
10,58	12,02	1,14	10,57	11,09	1,05	6,00	6,00	1,00	6,00	6,00	1,00	-20°C
10,59	11,93	1,13	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C
10,61	11,83	1,12	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C
10,62	11,74	1,11	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C
10,64	11,65	1,09	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C
10,65	11,55	1,08	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 12 (backup 6kW)

		Starting temperature																				
		25°C			30°C			35°C			40°C			45°C			50°C			55°C		
		Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
Outdoor temperature	35°C	2,16	15,48	7,16	2,65	15,48	5,84	3,00	15,32	5,11	3,54	15,30	4,32	4,04	15,39	3,81	4,54	15,54	3,42	5,04	15,73	3,12
	34°C	2,15	15,45	7,18	2,64	15,45	5,85	2,98	15,29	5,12	3,54	15,27	4,31	4,04	15,36	3,80	4,54	15,51	3,42	5,03	15,70	3,12
	33°C	2,14	15,42	7,19	2,63	15,42	5,86	2,97	15,26	5,13	3,54	15,24	4,31	4,03	15,33	3,80	4,53	15,48	3,42	5,03	15,67	3,12
	32°C	2,14	15,39	7,21	2,62	15,39	5,87	2,96	15,23	5,14	3,53	15,21	4,30	4,03	15,30	3,79	4,53	15,45	3,41	5,02	15,64	3,11
	31°C	2,13	15,36	7,22	2,61	15,36	5,89	2,95	15,20	5,16	3,53	15,18	4,30	4,03	15,27	3,79	4,52	15,42	3,41	5,02	15,63	3,11
	30°C	2,12	15,33	7,23	2,60	15,33	5,90	2,94	15,17	5,17	3,53	15,15	4,29	4,02	15,24	3,79	4,52	15,39	3,41	5,01	15,63	3,12
	29°C	2,11	15,30	7,25	2,59	15,30	5,91	2,93	15,14	5,18	3,52	15,12	4,29	4,02	15,20	3,78	4,51	15,36	3,40	5,01	15,63	3,12
	28°C	2,10	15,27	7,26	2,58	15,27	5,92	2,91	15,11	5,19	3,52	15,08	4,29	4,01	15,17	3,78	4,51	15,33	3,40	5,00	15,63	3,12
	27°C	2,09	15,23	7,28	2,57	15,23	5,93	2,90	15,08	5,20	3,52	15,05	4,28	4,01	15,14	3,78	4,50	15,30	3,40	5,00	15,63	3,13
	26°C	2,08	15,20	7,29	2,56	15,20	5,94	2,89	15,05	5,21	3,51	15,02	4,28	4,01	15,11	3,77	4,50	15,28	3,40	4,99	15,63	3,13
	25°C	2,08	15,17	7,31	2,55	15,17	5,96	2,88	15,02	5,22	3,51	14,99	4,27	4,00	15,08	3,77	4,50	15,28	3,40	4,99	15,63	3,13
	24°C	2,07	15,14	7,32	2,54	15,14	5,97	2,87	14,99	5,23	3,51	14,96	4,27	4,00	15,05	3,77	4,49	15,28	3,40	4,98	15,63	3,14
	23°C	2,06	15,11	7,34	2,53	15,11	5,98	2,86	14,96	5,24	3,50	14,94	4,26	3,99	15,02	3,76	4,49	15,28	3,41	4,98	15,63	3,14
	22°C	2,05	15,08	7,35	2,52	15,08	5,99	2,84	14,93	5,25	3,50	14,91	4,26	3,99	15,00	3,76	4,48	15,28	3,41	4,97	15,63	3,14
	21°C	2,04	15,05	7,37	2,51	15,05	6,00	2,83	14,90	5,26	3,50	14,88	4,26	3,99	14,97	3,75	4,48	15,28	3,41	4,97	15,63	3,15
	20°C	2,04	15,02	7,38	2,50	15,02	6,02	2,82	14,87	5,27	3,49	14,85	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
	19°C	2,03	14,99	7,40	2,49	14,99	6,03	2,81	14,84	5,28	3,49	14,82	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
	18°C	2,02	14,96	7,41	2,48	14,96	6,04	2,80	14,81	5,29	3,48	14,79	4,24	3,97	14,94	3,76	4,46	15,28	3,42	4,95	15,63	3,16
	17°C	2,01	14,93	7,42	2,47	14,93	6,05	2,79	14,78	5,30	3,48	14,76	4,24	3,97	14,94	3,76	4,46	15,28	3,43	4,95	15,63	3,16
	16°C	2,00	14,90	7,44	2,46	14,90	6,06	2,78	14,75	5,31	3,48	14,73	4,23	3,97	14,94	3,77	4,46	15,28	3,43	4,94	15,63	3,16
	15°C	2,00	14,87	7,45	2,45	14,87	6,08	2,77	14,72	5,32	3,47	14,70	4,23	3,96	14,94	3,77	4,45	15,28	3,43	4,94	15,63	3,16
	14°C	1,99	14,84	7,47	2,44	14,84	6,09	2,76	14,69	5,33	3,47	14,67	4,23	3,96	14,94	3,77	4,45	15,28	3,44	4,93	15,63	3,17
	13°C	1,98	14,81	7,48	2,43	14,81	6,10	2,74	14,66	5,34	3,47	14,64	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,93	15,63	3,17
	12°C	1,97	14,78	7,50	2,42	14,78	6,11	2,73	14,63	5,35	3,46	14,61	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,92	15,63	3,17
	11°C	2,25	14,93	6,63	2,68	14,93	5,57	3,01	14,81	4,93	3,67	14,80	4,03	4,16	15,15	3,64	4,64	15,49	3,34	5,13	15,84	3,09
	10°C	2,50	15,04	6,01	2,91	15,04	5,16	3,25	14,96	4,61	3,85	14,98	3,89	4,33	15,33	3,54	4,82	15,67	3,25	5,30	16,02	3,02
	9°C	2,79	15,19	5,45	3,18	15,19	4,78	3,52	15,14	4,30	4,05	15,19	3,75	4,54	15,54	3,42	5,02	15,88	3,16	5,51	16,23	2,95
	8°C	3,04	15,30	5,04	3,41	15,30	4,49	3,77	15,29	4,06	4,23	15,37	3,63	4,72	15,72	3,33	5,20	16,06	3,09	5,68	16,41	2,89
	7°C	3,41	15,53	4,56	3,76	15,53	4,13	4,10	15,53	3,79	4,53	15,67	3,46	5,01	16,02	3,20	5,50	16,36	2,98	5,98	16,71	2,79
	6°C	5,12	16,85	3,29	5,64	16,83	2,99	5,95	16,81	2,82	6,34	16,90	2,67	6,75	17,13	2,54	7,17	17,36	2,42	7,58	17,60	2,32
	5°C	6,50	17,93	2,76	7,14	17,90	2,50	7,45	17,86	2,40	7,80	17,89	2,29	8,16	18,03	2,21	8,52	18,17	2,13	8,89	18,31	2,06
	4°C	7,62	18,83	2,47	8,35	18,78	2,25	8,65	18,73	2,16	8,97	18,73	2,09	9,29	18,79	2,02	9,62	18,85	1,96	9,94	18,91	1,90
	3°C	8,46	19,55	2,31	9,25	19,49	2,11	9,55	19,43	2,03	9,85	19,39	1,97	10,15	19,39	1,91	10,46	19,40	1,85	10,76	19,40	1,80
	2°C	9,41	20,45	2,17	10,22	20,37	1,99	10,51	20,30	1,93	10,81	20,22	1,87	11,10	20,15	1,82	11,40	20,08	1,76	11,69	20,00	1,71
1°C	9,40	20,25	2,15	10,21	20,18	1,98	10,50	20,08	1,91	10,80	19,99	1,85	11,10	19,90	1,79	11,40	19,88	1,74	11,69	19,78	1,69	
0°C	9,39	20,05	2,13	10,18	19,99	1,96	10,48	19,85	1,89	10,78	19,75	1,83	11,09	19,65	1,77	11,40	19,69	1,73	11,68	19,56	1,67	
-1°C	9,37	19,85	2,12	10,14	19,79	1,95	10,45	19,63	1,88	10,76	19,52	1,81	11,07	19,41	1,75	11,40	19,49	1,71	11,66	19,33	1,66	
-2°C	9,34	19,65	2,10	10,08	19,60	1,94	10,40	19,41	1,87	10,72	19,28	1,80	11,04	19,16	1,74	11,40	19,30	1,69	11,64	19,11	1,64	
-3°C	9,30	19,45	2,09	10,01	19,40	1,94	10,33	19,18	1,86	10,67	19,05	1,79	11,01	18,91	1,72	11,41	19,11	1,68	11,61	18,89	1,63	
-4°C	9,26	19,25	2,08	9,92	19,21	1,94	10,25	18,96	1,85	10,61	18,81	1,77	10,97	18,66	1,70	11,41	18,91	1,66	11,57	18,67	1,61	
-5°C	9,20	19,05	2,07	9,81	19,01	1,94	10,16	18,74	1,84	10,54	18,58	1,76	10,92	18,42	1,69	11,42	18,72	1,64	11,53	18,44	1,60	
-6°C	9,14	18,85	2,06	9,69	18,82	1,94	10,05	18,51	1,84	10,46	18,34	1,75	10,87	18,17	1,67	11,42	18,53	1,62	11,48	18,22	1,59	
-7°C	9,07	18,65	2,06	9,55	18,62	1,95	9,93	18,29	1,84	10,37	18,11	1,75	10,80	17,92	1,66	11,43	18,33	1,60	11,43	18,00	1,57	
-8°C	9,21	18,57	2,02	9,66	18,50	1,91	10,05	18,23	1,81	10,47	18,05	1,72	10,90	17,86	1,64	11,45	18,08	1,58	11,58	17,80	1,54	
-9°C	9,35	18,49	1,98	9,78	18,38	1,88	10,17	18,16	1,79	10,58	17,99	1,70	10,99	17,81	1,62	11,46	17,83	1,56	11,73	17,60	1,50	
-10°C	9,50	18,40	1,94	9,89	18,25	1,84	10,29	18,10	1,76	10,69	17,93	1,68	11,08	17,75	1,60	11,48	17,58	1,53	11,88	17,40	1,47	
-11°C	9,49	17,67	1,86	9,85	17,53	1,78	10,21	17,39	1,70	10,55	17,23	1,63	10,90	17,07	1,57	11,25	16,89	1,50	11,60	16,58	1,43	
-12°C	9,48	16,93	1,79	9,80	16,81	1,72	10,12	16,68	1,65	10,42	16,54	1,59	10,72	16,40	1,53	11,02	16,20	1,47	11,32	15,76	1,39	
-13°C	9,46	16,20	1,71	9,75	16,08	1,65	10,04	15,97	1,59	10,29	15,85	1,54	10,54	15,72	1,49	10,79	15,51	1,44	11,04	14,95	1,35	
-14°C	9,45	15,46	1,64	9,70	15,36	1,58	9,95	15,26	1,53	10,16	15,15	1,49	10,36	15,05	1,45	10,56	14,82	1,40				

60°C			65°C			70°C			75°C				
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP		
5,29	15,98	3,02	6,14	16,32	2,66	7,12	16,67	2,34	0,00	0,00	0,00	35°C	Outdoor temperature
5,29	15,98	3,02	6,13	16,32	2,66	7,11	16,67	2,34	0,00	0,00	0,00	34°C	
5,28	15,98	3,02	6,13	16,32	2,66	7,10	16,67	2,35	0,00	0,00	0,00	33°C	
5,28	15,98	3,03	6,12	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	32°C	
5,27	15,98	3,03	6,11	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	31°C	
5,27	15,98	3,03	6,11	16,32	2,67	7,08	16,67	2,35	0,00	0,00	0,00	30°C	
5,26	15,98	3,04	6,10	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	29°C	
5,26	15,98	3,04	6,09	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	28°C	
5,25	15,98	3,04	6,09	16,32	2,68	7,06	16,67	2,36	0,00	0,00	0,00	27°C	
5,25	15,98	3,04	6,08	16,32	2,68	7,05	16,67	2,36	0,00	0,00	0,00	26°C	
5,24	15,98	3,05	6,08	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	25°C	
5,24	15,98	3,05	6,07	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	24°C	
5,23	15,98	3,05	6,06	16,32	2,69	7,03	16,67	2,37	0,00	0,00	0,00	23°C	
5,23	15,98	3,06	6,06	16,32	2,69	7,02	16,67	2,37	0,00	0,00	0,00	22°C	
5,22	15,98	3,06	6,05	16,32	2,70	7,02	16,67	2,38	0,00	0,00	0,00	21°C	
5,22	15,98	3,06	6,05	16,32	2,70	7,01	16,67	2,38	0,00	0,00	0,00	20°C	
5,21	15,98	3,07	6,04	16,32	2,70	7,00	16,67	2,38	8,12	17,01	2,10	19°C	
5,21	15,98	3,07	6,03	16,32	2,70	7,00	16,67	2,38	8,11	17,01	2,10	18°C	
5,20	15,98	3,07	6,03	16,32	2,71	6,99	16,67	2,38	8,10	17,01	2,10	17°C	
5,19	15,98	3,08	6,02	16,32	2,71	6,98	16,67	2,39	8,09	17,01	2,10	16°C	
5,19	15,98	3,08	6,02	16,32	2,71	6,97	16,67	2,39	8,09	17,01	2,10	15°C	
5,18	15,98	3,08	6,01	16,32	2,72	6,97	16,67	2,39	8,08	17,01	2,11	14°C	
5,18	15,98	3,08	6,00	16,32	2,72	6,96	16,67	2,39	8,07	17,01	2,11	13°C	
5,17	15,98	3,09	6,00	16,32	2,72	6,95	16,67	2,40	8,06	17,01	2,11	12°C	
5,38	16,19	3,01	6,20	16,53	2,67	7,16	16,88	2,36	8,26	17,22	2,08	11°C	
5,55	16,37	2,95	6,38	16,71	2,62	7,33	17,06	2,33	8,44	17,40	2,06	10°C	
5,76	16,58	2,88	6,58	16,92	2,57	7,53	17,27	2,29	8,64	17,61	2,04	9°C	
5,93	16,76	2,82	6,75	17,10	2,53	7,71	17,45	2,26	8,81	17,79	2,02	8°C	
6,23	17,06	2,74	7,05	17,40	2,47	8,00	17,75	2,22	9,10	18,09	1,99	7°C	
7,85	17,83	2,27	8,48	18,07	2,13	9,20	18,30	1,99	10,01	18,53	1,85	6°C	
9,16	18,45	2,01	9,65	18,59	1,93	10,18	18,73	1,84	10,77	18,87	1,75	5°C	
10,23	18,97	1,85	10,61	19,04	1,79	11,01	19,10	1,73	11,44	19,16	1,68	4°C	
11,05	19,40	1,76	11,37	19,40	1,71	11,69	19,41	1,66	12,02	19,41	1,62	3°C	
11,99	19,93	1,66	12,28	19,85	1,62	12,58	19,78	1,57	12,87	19,70	1,53	2°C	
11,97	19,53	1,63	12,26	19,28	1,57	12,54	19,04	1,52	12,83	18,90	1,47	1°C	
11,93	19,14	1,60	12,19	18,72	1,54	12,45	18,30	1,47	12,71	18,10	1,42	0°C	
11,87	18,74	1,58	12,08	18,15	1,50	12,29	17,56	1,43	12,50	17,30	1,38	-1°C	
11,78	18,35	1,56	11,92	17,58	1,48	12,06	16,82	1,39	12,22	16,50	1,35	-2°C	
11,66	17,95	1,54	11,72	17,02	1,45	11,77	16,08	1,37	11,85	15,70	1,32	-3°C	
11,52	17,56	1,52	11,47	16,45	1,43	11,41	15,34	1,34	11,40	14,90	1,31	-4°C	
11,35	17,16	1,51	11,17	15,88	1,42	10,99	14,60	1,33	10,87	14,10	1,30	-5°C	
11,16	16,77	1,50	10,84	15,32	1,41	10,51	13,86	1,32	10,26	13,30	1,30	-6°C	
10,94	16,38	1,50	10,45	14,75	1,41	9,96	13,13	1,32	9,56	12,50	1,31	-7°C	
11,27	16,21	1,44	10,95	14,62	1,33	10,64	13,03	1,22	10,49	12,58	1,20	-8°C	
11,59	16,05	1,38	11,46	14,50	1,26	11,32	12,94	1,14	11,42	12,66	1,11	-9°C	
11,92	15,88	1,33	11,96	14,37	1,20	12,01	12,85	1,07	12,34	12,74	1,03	-10°C	
11,64	15,20	1,31	11,68	13,83	1,18	11,71	12,45	1,06	6,00	6,00	1,00	-11°C	
11,36	14,52	1,28	11,39	13,29	1,17	11,42	12,05	1,05	6,00	6,00	1,00	-12°C	
11,07	13,85	1,25	11,10	12,74	1,15	11,13	11,64	1,05	6,00	6,00	1,00	-13°C	
10,79	13,17	1,22	10,82	12,20	1,13	10,84	11,24	1,04	6,00	6,00	1,00	-14°C	
10,51	12,49	1,19	10,53	11,66	1,11	10,55	10,84	1,03	6,00	6,00	1,00	-15°C	
10,52	12,39	1,18	10,54	11,55	1,10	6,00	6,00	1,00	6,00	6,00	1,00	-16°C	
10,54	12,30	1,17	10,55	11,43	1,08	6,00	6,00	1,00	6,00	6,00	1,00	-17°C	
10,55	12,21	1,16	10,56	11,32	1,07	6,00	6,00	1,00	6,00	6,00	1,00	-18°C	
10,57	12,11	1,15	10,57	11,21	1,06	6,00	6,00	1,00	6,00	6,00	1,00	-19°C	
10,58	12,02	1,14	10,57	11,09	1,05	6,00	6,00	1,00	6,00	6,00	1,00	-20°C	
10,59	11,93	1,13	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-21°C	
10,61	11,83	1,12	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-22°C	
10,62	11,74	1,11	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-23°C	
10,64	11,65	1,09	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-24°C	
10,65	11,55	1,08	6,00	6,00	1,00	6,00	6,00	1,00	6,00	6,00	1,00	-25°C	

▼ AUREA 2 COMPACT 9TRI (backup 9kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1.82	13.38	7.36	2.29	13.38	5.85	2.61	13.20	5.06	3.15	13.17	4.19	3.62	13.22	3.65	4.10	13.32	3.25	4.57	13.44	2.94
34°C	1.81	13.35	7.37	2.28	13.35	5.86	2.60	13.17	5.07	3.14	13.14	4.18	3.62	13.20	3.65	4.09	13.29	3.25	4.57	13.41	2.93
33°C	1.80	13.33	7.39	2.27	13.33	5.87	2.59	13.15	5.08	3.14	13.11	4.18	3.61	13.17	3.64	4.09	13.26	3.24	4.56	13.38	2.93
32°C	1.80	13.30	7.40	2.26	13.30	5.88	2.58	13.12	5.09	3.14	13.09	4.17	3.61	13.14	3.64	4.09	13.24	3.24	4.56	13.36	2.93
31°C	1.79	13.27	7.42	2.25	13.27	5.90	2.57	13.09	5.10	3.13	13.06	4.17	3.61	13.12	3.64	4.08	13.21	3.24	4.56	13.33	2.93
30°C	1.78	13.25	7.43	2.24	13.25	5.91	2.56	13.07	5.11	3.13	13.04	4.16	3.60	13.09	3.63	4.08	13.19	3.23	4.55	13.30	2.92
29°C	1.78	13.22	7.45	2.23	13.22	5.92	2.55	13.04	5.12	3.13	13.01	4.16	3.60	13.07	3.63	4.07	13.16	3.23	4.55	13.28	2.92
28°C	1.77	13.19	7.46	2.22	13.19	5.93	2.54	13.02	5.13	3.12	12.98	4.16	3.60	13.04	3.63	4.07	13.13	3.23	4.54	13.25	2.92
27°C	1.76	13.17	7.48	2.22	13.17	5.94	2.53	12.99	5.14	3.12	12.96	4.15	3.59	13.01	3.62	4.07	13.11	3.22	4.54	13.23	2.92
26°C	1.75	13.14	7.49	2.21	13.14	5.96	2.52	12.96	5.15	3.12	12.93	4.15	3.59	12.99	3.62	4.06	13.08	3.22	4.53	13.20	2.91
25°C	1.75	13.12	7.51	2.20	13.12	5.97	2.51	12.94	5.16	3.11	12.91	4.14	3.59	12.96	3.61	4.06	13.06	3.22	4.53	13.17	2.91
24°C	1.74	13.09	7.52	2.19	13.09	5.98	2.50	12.91	5.17	3.11	12.88	4.14	3.58	12.94	3.61	4.05	13.03	3.22	4.52	13.15	2.91
23°C	1.73	13.06	7.54	2.18	13.06	5.99	2.49	12.89	5.18	3.11	12.86	4.14	3.58	12.91	3.61	4.05	13.01	3.21	4.52	13.12	2.90
22°C	1.73	13.04	7.55	2.17	13.04	6.00	2.48	12.86	5.19	3.11	12.83	4.13	3.57	12.88	3.60	4.04	12.98	3.21	4.51	13.12	2.91
21°C	1.72	13.01	7.57	2.16	13.01	6.02	2.47	12.84	5.20	3.10	12.80	4.13	3.57	12.86	3.60	4.04	12.95	3.21	4.51	13.12	2.91
20°C	1.71	12.99	7.58	2.15	12.99	6.03	2.46	12.81	5.21	3.10	12.78	4.12	3.57	12.83	3.60	4.04	12.93	3.20	4.51	13.12	2.91
19°C	1.71	12.96	7.60	2.15	12.96	6.04	2.45	12.78	5.22	3.10	12.75	4.12	3.56	12.81	3.59	4.03	12.91	3.20	4.50	13.12	2.91
18°C	1.70	12.93	7.61	2.14	12.93	6.05	2.44	12.76	5.23	3.09	12.73	4.12	3.56	12.78	3.59	4.03	12.91	3.20	4.50	13.12	2.92
17°C	1.69	12.91	7.63	2.13	12.91	6.06	2.43	12.73	5.24	3.09	12.70	4.11	3.56	12.76	3.59	4.02	12.91	3.21	4.49	13.12	2.92
16°C	1.69	12.88	7.64	2.12	12.88	6.08	2.42	12.71	5.25	3.09	12.68	4.11	3.55	12.73	3.58	4.02	12.91	3.21	4.49	13.12	2.92
15°C	1.68	12.86	7.66	2.11	12.86	6.09	2.41	12.68	5.26	3.08	12.65	4.10	3.55	12.71	3.58	4.02	12.91	3.21	4.48	13.12	2.93
14°C	1.67	12.83	7.67	2.10	12.83	6.10	2.40	12.66	5.27	3.08	12.63	4.10	3.55	12.70	3.58	4.01	12.91	3.22	4.48	13.12	2.93
13°C	1.67	12.80	7.69	2.10	12.80	6.11	2.39	12.63	5.28	3.08	12.60	4.09	3.54	12.70	3.58	4.01	12.91	3.22	4.47	13.12	2.93
12°C	1.66	12.78	7.70	2.09	12.78	6.12	2.38	12.61	5.29	3.07	12.58	4.09	3.54	12.70	3.59	4.00	12.91	3.22	4.47	13.12	2.94
11°C	2.04	13.02	6.39	2.45	13.02	5.31	2.76	12.89	4.68	3.39	12.86	3.80	3.85	13.01	3.38	4.32	13.22	3.06	4.78	13.44	2.81
10°C	2.37	13.21	5.57	2.77	13.21	4.77	3.09	13.12	4.25	3.65	13.09	3.58	4.12	13.28	3.23	4.58	13.49	2.95	5.05	13.71	2.72
9°C	2.75	13.45	4.89	3.13	13.45	4.30	3.46	13.40	3.87	3.97	13.38	3.38	4.43	13.60	3.07	4.89	13.81	2.82	5.36	14.02	2.62
8°C	3.09	13.65	4.42	3.45	13.65	3.96	3.79	13.64	3.60	4.23	13.65	3.23	4.70	13.87	2.95	5.16	14.08	2.73	5.62	14.29	2.54
7°C	3.60	14.02	3.89	3.95	14.02	3.55	4.27	14.02	3.29	4.68	14.10	3.01	5.14	14.32	2.78	5.60	14.53	2.59	6.07	14.74	2.43
6°C	5.89	15.80	2.68	6.20	15.75	2.54	6.50	15.71	2.41	6.86	15.72	2.29	7.26	15.83	2.18	7.65	15.94	2.08	8.04	16.05	2.00
5°C	7.75	17.25	2.23	8.04	17.17	2.14	8.33	17.08	2.05	8.65	17.04	1.97	8.98	17.06	1.90	9.32	17.08	1.83	9.66	17.11	1.77
4°C	9.27	18.46	1.99	9.54	18.35	1.92	9.82	18.23	1.86	10.11	18.14	1.79	10.41	18.09	1.74	10.71	18.04	1.68	11.01	17.99	1.63
3°C	10.45	19.44	1.86	10.71	19.29	1.80	10.98	19.15	1.74	11.26	19.02	1.69	11.53	18.92	1.64	11.81	18.82	1.59	12.09	18.71	1.55
2°C	11.83	20.65	1.75	12.10	20.47	1.69	12.36	20.30	1.64	12.63	20.12	1.59	12.90	19.95	1.55	13.17	19.78	1.50	13.44	19.60	1.46
1°C	11.84	20.61	1.74	12.10	20.41	1.69	12.37	20.22	1.63	12.64	20.05	1.59	12.90	19.87	1.54	13.17	19.63	1.49	13.44	19.39	1.44
0°C	11.87	20.57	1.73	12.13	20.35	1.68	12.39	20.14	1.63	12.65	19.97	1.58	12.91	19.80	1.53	13.17	19.49	1.48	13.45	19.19	1.43
-1°C	11.93	20.53	1.72	12.17	20.29	1.67	12.43	20.06	1.61	12.68	19.89	1.57	12.92	19.72	1.53	13.17	19.35	1.47	13.48	18.98	1.41
-2°C	12.00	20.49	1.71	12.23	20.22	1.65	12.48	19.98	1.60	12.71	19.81	1.56	12.94	19.64	1.52	13.18	19.21	1.46	13.51	18.78	1.39
-3°C	12.09	20.46	1.69	12.31	20.16	1.64	12.55	19.90	1.59	12.76	19.73	1.55	12.97	19.57	1.51	13.18	19.07	1.45	13.55	18.57	1.37
-4°C	12.21	20.42	1.67	12.40	20.10	1.62	12.64	19.82	1.57	12.82	19.66	1.53	13.00	19.49	1.50	13.19	18.93	1.43	13.60	18.37	1.35
-5°C	12.34	20.38	1.65	12.51	20.04	1.60	12.73	19.74	1.55	12.88	19.58	1.52	13.03	19.42	1.49	13.20	18.79	1.42	13.66	18.16	1.33
-6°C	12.50	20.34	1.63	12.64	19.97	1.58	12.85	19.66	1.53	12.96	19.50	1.50	13.07	19.34	1.48	13.21	18.64	1.41	13.73	17.96	1.31
-7°C	12.67	20.30	1.60	12.78	19.91	1.56	12.98	19.58	1.51	13.05	19.42	1.49	13.12	19.26	1.47	13.22	18.50	1.40	13.81	17.75	1.29
-8°C	12.87	20.15	1.57	12.94	19.73	1.52	13.08	19.35	1.48	13.13	19.10	1.45	13.19	18.84	1.43	13.26	18.19	1.37	13.66	17.53	1.28
-9°C	13.06	19.99	1.53	13.11	19.55	1.49	13.18	19.13	1.45	13.22	18.77	1.42	13.25	18.42	1.39	13.30	17.87	1.34	13.51	17.32	1.28
-10°C	13.25	19.84	1.50	13.27	19.37	1.46	13.29	18.90	1.42	13.30	18.45	1.39	13.32	18.00	1.35	13.34	17.55	1.32	13.35	17.10	1.28
-11°C	13.09	19.42	1.48	13.15	19.02	1.45	13.20	18.63	1.41	13.25	18.25	1.38	13.29	17.87	1.34	13.34	17.47	1.31	13.38	16.94	1.27
-12°C	12.93	18.99	1.47	13.02	18.68	1.43	13.12	18.36	1.40	13.19	18.05	1.37	13.26	17.75	1.34	13.34	17.38	1.30	13.41	16.78	1.25
-13°C	12.77	18.57	1.45	12.90	18.33	1.42	13.03	18.09	1.39	13.13	17.86	1.36	13.23	17.62	1.33	13.33	17.30	1.30	13.43	16.63	1.24
-14°C	12.60	18.15	1.44	12.78	17.98	1.41	12.95	17.82	1.38	13.08	17.66	1.									

60°C			65°C			70°C			75°C			
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,81	13,57	2,82	5,57	13,71	2,46	6,46	13,87	2,15	0,00	0,00	0,00	35°C
4,80	13,54	2,82	5,57	13,69	2,46	6,45	13,84	2,15	0,00	0,00	0,00	34°C
4,80	13,52	2,82	5,56	13,66	2,46	6,45	13,82	2,14	0,00	0,00	0,00	33°C
4,79	13,49	2,82	5,55	13,64	2,45	6,44	13,79	2,14	0,00	0,00	0,00	32°C
4,79	13,46	2,81	5,55	13,61	2,45	6,43	13,76	2,14	0,00	0,00	0,00	31°C
4,78	13,44	2,81	5,54	13,58	2,45	6,43	13,76	2,14	0,00	0,00	0,00	30°C
4,78	13,41	2,81	5,54	13,56	2,45	6,42	13,76	2,14	0,00	0,00	0,00	29°C
4,77	13,39	2,80	5,53	13,54	2,45	6,41	13,76	2,14	0,00	0,00	0,00	28°C
4,77	13,36	2,80	5,53	13,54	2,45	6,41	13,76	2,15	0,00	0,00	0,00	27°C
4,76	13,33	2,80	5,52	13,54	2,45	6,40	13,76	2,15	0,00	0,00	0,00	26°C
4,76	13,33	2,80	5,52	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	25°C
4,75	13,33	2,80	5,51	13,54	2,46	6,39	13,76	2,15	0,00	0,00	0,00	24°C
4,75	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	23°C
4,74	13,33	2,81	5,50	13,54	2,46	6,38	13,76	2,16	0,00	0,00	0,00	22°C
4,74	13,33	2,81	5,49	13,54	2,47	6,37	13,76	2,16	0,00	0,00	0,00	21°C
4,73	13,33	2,82	5,49	13,54	2,47	6,36	13,76	2,16	0,00	0,00	0,00	20°C
4,73	13,33	2,82	5,48	13,54	2,47	6,36	13,76	2,16	7,37	13,97	1,90	19°C
4,72	13,33	2,82	5,48	13,54	2,47	6,35	13,76	2,17	7,36	13,97	1,90	18°C
4,72	13,33	2,82	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	17°C
4,72	13,33	2,83	5,47	13,54	2,48	6,34	13,76	2,17	7,35	13,97	1,90	16°C
4,71	13,33	2,83	5,46	13,54	2,48	6,33	13,76	2,17	7,34	13,97	1,90	15°C
4,71	13,33	2,83	5,46	13,54	2,48	6,32	13,76	2,17	7,33	13,97	1,90	14°C
4,70	13,33	2,84	5,45	13,54	2,48	6,32	13,76	2,18	7,32	13,97	1,91	13°C
4,70	13,33	2,84	5,44	13,54	2,49	6,31	13,76	2,18	7,32	13,97	1,91	12°C
5,01	13,65	2,73	5,75	13,86	2,41	6,62	14,07	2,13	7,62	14,28	1,87	11°C
5,27	13,92	2,64	6,02	14,13	2,35	6,88	14,34	2,08	7,89	14,55	1,84	10°C
5,58	14,23	2,55	6,33	14,44	2,28	7,19	14,66	2,04	8,20	14,87	1,81	9°C
5,85	14,50	2,48	6,59	14,71	2,23	7,46	14,93	2,00	8,46	15,14	1,79	8°C
6,29	14,95	2,38	7,04	15,16	2,15	7,90	15,38	1,95	8,90	15,59	1,75	7°C
8,28	16,16	1,95	8,86	16,27	1,84	9,51	16,38	1,72	10,24	16,49	1,61	6°C
9,91	17,13	1,73	10,35	17,15	1,66	10,83	17,17	1,59	11,37	17,19	1,51	5°C
11,27	17,94	1,59	11,61	17,90	1,54	11,98	17,85	1,49	12,36	17,80	1,44	4°C
12,35	18,61	1,51	12,64	18,50	1,46	12,93	18,40	1,42	13,23	18,30	1,38	3°C
13,70	19,43	1,42	13,97	19,25	1,38	14,24	19,08	1,34	14,51	18,90	1,30	2°C
13,71	19,10	1,39	13,99	18,80	1,34	14,26	18,50	1,30	14,54	18,28	1,26	1°C
13,75	18,77	1,37	14,04	18,34	1,31	14,33	17,92	1,25	14,63	17,66	1,21	0°C
13,80	18,44	1,34	14,13	17,89	1,27	14,45	17,34	1,20	14,79	17,04	1,15	-1°C
13,88	18,11	1,30	14,25	17,44	1,22	14,62	16,76	1,15	15,01	16,42	1,09	-2°C
13,98	17,78	1,27	14,41	16,98	1,18	14,84	16,19	1,09	15,29	15,80	1,03	-3°C
14,10	17,45	1,24	14,60	16,53	1,13	15,10	15,61	1,03	15,63	15,18	0,97	-4°C
14,24	17,12	1,20	14,83	16,07	1,08	15,41	15,03	0,98	16,04	14,55	0,91	-5°C
14,41	16,79	1,17	15,09	15,62	1,04	15,77	14,45	0,92	16,51	13,93	0,84	-6°C
14,60	16,46	1,13	15,38	15,17	0,99	16,17	13,88	0,86	17,04	13,31	0,78	-7°C
14,11	16,24	1,15	14,57	14,96	1,03	15,03	13,67	0,91	15,61	13,20	0,85	-8°C
13,63	16,03	1,18	13,76	14,75	1,07	13,89	13,46	0,97	14,19	13,08	0,92	-9°C
13,15	15,82	1,20	12,95	14,54	1,12	12,75	13,25	1,04	9,00	9,00	1,00	-10°C
13,22	15,75	1,19	13,07	14,56	1,11	12,91	13,37	1,04	9,00	9,00	1,00	-11°C
13,29	15,68	1,18	13,18	14,59	1,11	13,07	13,49	1,03	9,00	9,00	1,00	-12°C
13,37	15,62	1,17	13,30	14,61	1,10	13,23	13,60	1,03	9,00	9,00	1,00	-13°C
13,44	15,55	1,16	13,41	14,64	1,09	13,39	13,72	1,02	9,00	9,00	1,00	-14°C
13,51	15,49	1,15	13,53	14,66	1,08	13,55	13,84	1,02	9,00	9,00	1,00	-15°C
13,52	15,39	1,14	13,54	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-16°C
13,54	15,30	1,13	13,55	14,43	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-17°C
13,55	15,21	1,12	13,56	14,32	1,06	9,00	9,00	1,00	9,00	9,00	1,00	-18°C
13,57	15,11	1,11	13,57	14,21	1,05	9,00	9,00	1,00	9,00	9,00	1,00	-19°C
13,58	15,02	1,11	13,57	14,09	1,04	9,00	9,00	1,00	9,00	9,00	1,00	-20°C
13,59	14,93	1,10	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-21°C
13,61	14,83	1,09	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-22°C
13,62	14,74	1,08	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-23°C
13,64	14,65	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-24°C
13,65	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-25°C

Outdoor temperature

▼ AUREA 2 COMPACT 12TRI (backup 9kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	2,04	15,54	7,63	2,54	15,54	6,11	2,89	15,39	5,32	3,44	15,36	4,46	3,96	15,46	3,90	4,49	15,63	3,48	5,01	15,83	3,16
34°C	2,03	15,50	7,64	2,53	15,50	6,12	2,88	15,36	5,33	3,44	15,33	4,46	3,96	15,43	3,90	4,48	15,59	3,48	5,00	15,80	3,16
33°C	2,02	15,47	7,66	2,52	15,47	6,14	2,87	15,33	5,34	3,44	15,30	4,45	3,96	15,40	3,89	4,48	15,56	3,48	5,00	15,78	3,16
32°C	2,01	15,44	7,67	2,51	15,44	6,15	2,86	15,30	5,35	3,43	15,27	4,45	3,95	15,37	3,89	4,47	15,53	3,47	4,99	15,78	3,16
31°C	2,00	15,41	7,69	2,50	15,41	6,16	2,85	15,27	5,36	3,43	15,24	4,45	3,95	15,34	3,88	4,47	15,50	3,47	4,99	15,78	3,16
30°C	2,00	15,38	7,71	2,49	15,38	6,17	2,84	15,24	5,37	3,43	15,21	4,44	3,94	15,31	3,88	4,46	15,47	3,47	4,98	15,78	3,17
29°C	1,99	15,35	7,72	2,48	15,35	6,18	2,83	15,20	5,38	3,42	15,18	4,44	3,94	15,28	3,88	4,46	15,44	3,46	4,98	15,78	3,17
28°C	1,98	15,32	7,74	2,47	15,32	6,20	2,81	15,17	5,39	3,42	15,15	4,43	3,94	15,25	3,87	4,46	15,41	3,46	4,97	15,78	3,17
27°C	1,97	15,29	7,75	2,46	15,29	6,21	2,80	15,14	5,40	3,42	15,12	4,43	3,93	15,22	3,87	4,45	15,41	3,46	4,97	15,78	3,18
26°C	1,96	15,26	7,77	2,45	15,26	6,22	2,79	15,11	5,41	3,41	15,09	4,42	3,93	15,19	3,87	4,45	15,41	3,47	4,96	15,78	3,18
25°C	1,96	15,23	7,78	2,44	15,23	6,23	2,78	15,08	5,43	3,41	15,06	4,42	3,93	15,16	3,86	4,44	15,41	3,47	4,96	15,78	3,18
24°C	1,95	15,20	7,80	2,43	15,20	6,25	2,77	15,05	5,44	3,40	15,03	4,41	3,92	15,13	3,86	4,44	15,41	3,47	4,95	15,78	3,19
23°C	1,94	15,17	7,81	2,42	15,17	6,26	2,76	15,02	5,45	3,40	15,00	4,41	3,92	15,10	3,85	4,43	15,41	3,48	4,95	15,78	3,19
22°C	1,93	15,14	7,83	2,41	15,14	6,27	2,75	14,99	5,46	3,40	14,97	4,41	3,91	15,07	3,85	4,43	15,41	3,48	4,94	15,78	3,19
21°C	1,93	15,11	7,84	2,40	15,11	6,28	2,74	14,96	5,47	3,39	14,94	4,40	3,91	15,04	3,85	4,42	15,41	3,48	4,94	15,78	3,19
20°C	1,92	15,08	7,86	2,39	15,08	6,30	2,73	14,93	5,48	3,39	14,91	4,40	3,91	15,04	3,85	4,42	15,41	3,49	4,93	15,78	3,20
19°C	1,91	15,05	7,88	2,38	15,05	6,31	2,71	14,90	5,49	3,39	14,88	4,39	3,90	15,04	3,86	4,42	15,41	3,49	4,93	15,78	3,20
18°C	1,90	15,02	7,89	2,38	15,02	6,32	2,70	14,87	5,50	3,38	14,85	4,39	3,90	15,04	3,86	4,41	15,41	3,49	4,92	15,78	3,20
17°C	1,90	14,99	7,91	2,37	14,99	6,33	2,69	14,84	5,51	3,38	14,82	4,38	3,89	15,04	3,86	4,41	15,41	3,50	4,92	15,78	3,21
16°C	1,89	14,96	7,92	2,36	14,96	6,35	2,68	14,81	5,52	3,38	14,79	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
15°C	1,88	14,93	7,94	2,35	14,93	6,36	2,67	14,79	5,53	3,37	14,76	4,38	3,89	15,04	3,87	4,40	15,41	3,50	4,91	15,78	3,21
14°C	1,87	14,90	7,96	2,34	14,90	6,37	2,66	14,76	5,55	3,37	14,73	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
13°C	1,87	14,87	7,97	2,33	14,87	6,38	2,65	14,73	5,56	3,37	14,70	4,37	3,88	15,04	3,88	4,39	15,41	3,51	4,90	15,78	3,22
12°C	1,86	14,84	7,99	2,32	14,84	6,40	2,64	14,70	5,57	3,36	14,68	4,36	3,87	15,04	3,88	4,38	15,41	3,52	4,89	15,78	3,22
11°C	2,27	15,09	6,64	2,70	15,09	5,58	3,02	14,98	4,96	3,68	14,99	4,08	4,19	15,36	3,67	4,70	15,73	3,35	5,20	16,10	3,09
10°C	2,64	15,30	5,78	3,04	15,30	5,03	3,35	15,23	4,54	3,94	15,26	3,87	4,45	15,63	3,51	4,96	16,00	3,22	5,47	16,37	2,99
9°C	3,06	15,55	5,08	3,43	15,55	4,54	3,73	15,51	4,16	4,25	15,58	3,66	4,76	15,94	3,35	5,27	16,31	3,09	5,78	16,68	2,89
8°C	3,43	15,76	4,59	3,76	15,76	4,19	4,07	15,75	3,87	4,52	15,85	3,51	5,03	16,21	3,22	5,54	16,58	2,99	6,05	16,95	2,80
7°C	3,98	16,15	4,05	4,28	16,15	3,77	4,55	16,15	3,55	4,97	16,30	3,28	5,48	16,66	3,04	5,98	17,03	2,85	6,49	17,40	2,68
6°C	6,31	18,09	2,87	6,77	18,08	2,67	7,06	18,07	2,56	7,44	18,16	2,44	7,88	18,42	2,34	8,32	18,68	2,24	8,76	18,93	2,16
5°C	8,20	19,69	2,40	8,79	19,66	2,24	9,09	19,64	2,16	9,45	19,69	2,08	9,84	19,85	2,02	10,22	20,01	1,96	10,61	20,18	1,90
4°C	9,74	21,01	2,16	10,42	20,98	2,01	10,73	20,94	1,95	11,07	20,96	1,89	11,42	21,05	1,84	11,77	21,13	1,79	12,13	21,22	1,75
3°C	10,94	22,07	2,02	11,67	22,03	1,89	11,99	21,99	1,83	12,32	21,98	1,78	12,65	22,01	1,74	12,97	22,03	1,70	13,30	22,06	1,66
2°C	12,33	23,40	1,90	13,08	23,35	1,79	13,40	23,30	1,74	13,72	23,25	1,69	14,04	23,20	1,65	14,36	23,15	1,61	14,69	23,10	1,57
1°C	12,32	23,19	1,88	13,07	23,15	1,77	13,39	23,09	1,72	13,72	23,02	1,68	14,04	22,96	1,64	14,36	22,97	1,60	14,68	22,87	1,56
0°C	12,31	22,99	1,87	13,05	22,96	1,76	13,37	22,88	1,71	13,70	22,80	1,66	14,03	22,72	1,62	14,37	22,79	1,59	14,67	22,63	1,54
-1°C	12,28	22,78	1,86	13,01	22,76	1,75	13,34	22,67	1,70	13,68	22,57	1,65	14,01	22,48	1,60	14,37	22,60	1,57	14,64	22,40	1,53
-2°C	12,24	22,58	1,84	12,95	22,56	1,74	13,30	22,46	1,69	13,64	22,35	1,64	13,99	22,23	1,59	14,38	22,42	1,56	14,61	22,17	1,52
-3°C	12,20	22,37	1,83	12,88	22,37	1,74	13,24	22,24	1,68	13,60	22,12	1,63	13,96	21,99	1,58	14,39	22,24	1,55	14,57	21,93	1,51
-4°C	12,14	22,17	1,83	12,79	22,17	1,73	13,17	22,03	1,67	13,55	21,89	1,62	13,93	21,75	1,56	14,40	22,06	1,53	14,52	21,70	1,49
-5°C	12,08	21,96	1,82	12,69	21,97	1,73	13,08	21,82	1,67	13,48	21,67	1,61	13,89	21,51	1,55	14,41	21,87	1,52	14,46	21,47	1,48
-6°C	12,00	21,76	1,81	12,57	21,77	1,73	12,99	21,61	1,66	13,41	21,44	1,60	13,84	21,27	1,54	14,42	21,69	1,50	14,39	21,23	1,48
-7°C	11,91	21,55	1,81	12,43	21,58	1,74	12,88	21,40	1,66	13,33	21,21	1,59	13,79	21,03	1,53	14,44	21,51	1,49	14,31	21,00	1,47
-8°C	12,08	21,49	1,78	12,56	21,48	1,71	12,99	21,33	1,64	13,43	21,16	1,58	13,87	20,99	1,51	14,44	21,26	1,47	14,49	20,87	1,44
-9°C	12,24	21,43	1,75	12,68	21,38	1,69	13,11	21,27	1,62	13,53	21,10	1,56	13,96	20,94	1,50	14,44	21,00	1,45	14,68	20,73	1,41
-10°C	12,40	21,37	1,72	12,81	21,28	1,66	13,22	21,20	1,60	13,63	21,05	1,54	14,04	20,90	1,49	14,45	20,75	1,44	14,86	20,60	1,39
-11°C	12,41	20,64	1,66	12,78	20,55	1,61	13,15	20,47	1,56	13,51	20,33	1,51	13,87	20,19	1,46	14,23	20,03	1,41	14,58	19,74	1,35
-12°C	12,42	19,91	1,60	12,75	19,82	1,56	13,08	19,74	1,51	13,39	19,61	1,47	13,69	19,49	1,42	14,00	19,30	1,38	14,31	18,88	1,32
-13°C	12,43	19,18	1,54	12,72	19,10	1,50	13,01	19,01	1,46	13,27	18,90	1,42	13,52	18,78	1,39	13,78	18,58	1,35	14,04	18,03	1,28
-14°C	12,43	18,45	1,48	12,69	18,37	1,45	12,94	18,28	1,41	13,14	18,18	1,38	13,35	18,08	1,35	13,56					

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
5,26	16,15	3,07	6,10	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	35°C
5,26	16,15	3,07	6,09	16,52	2,71	7,07	16,88	2,39	0,00	0,00	0,00	34°C
5,25	16,15	3,07	6,09	16,52	2,71	7,06	16,88	2,39	0,00	0,00	0,00	33°C
5,25	16,15	3,08	6,08	16,52	2,72	7,05	16,88	2,39	0,00	0,00	0,00	32°C
5,24	16,15	3,08	6,08	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	31°C
5,24	16,15	3,08	6,07	16,52	2,72	7,04	16,88	2,40	0,00	0,00	0,00	30°C
5,23	16,15	3,09	6,06	16,52	2,72	7,03	16,88	2,40	0,00	0,00	0,00	29°C
5,23	16,15	3,09	6,06	16,52	2,73	7,02	16,88	2,40	0,00	0,00	0,00	28°C
5,22	16,15	3,09	6,05	16,52	2,73	7,02	16,88	2,41	0,00	0,00	0,00	27°C
5,22	16,15	3,10	6,05	16,52	2,73	7,01	16,88	2,41	0,00	0,00	0,00	26°C
5,21	16,15	3,10	6,04	16,52	2,73	7,00	16,88	2,41	0,00	0,00	0,00	25°C
5,21	16,15	3,10	6,03	16,52	2,74	7,00	16,88	2,41	0,00	0,00	0,00	24°C
5,20	16,15	3,11	6,03	16,52	2,74	6,99	16,88	2,42	0,00	0,00	0,00	23°C
5,19	16,15	3,11	6,02	16,52	2,74	6,98	16,88	2,42	0,00	0,00	0,00	22°C
5,19	16,15	3,11	6,02	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	21°C
5,18	16,15	3,11	6,01	16,52	2,75	6,97	16,88	2,42	0,00	0,00	0,00	20°C
5,18	16,15	3,12	6,00	16,52	2,75	6,96	16,88	2,43	8,07	17,25	2,14	19°C
5,17	16,15	3,12	6,00	16,52	2,75	6,95	16,88	2,43	8,06	17,25	2,14	18°C
5,17	16,15	3,12	5,99	16,52	2,76	6,95	16,88	2,43	8,05	17,25	2,14	17°C
5,16	16,15	3,13	5,99	16,52	2,76	6,94	16,88	2,43	8,05	17,25	2,14	16°C
5,16	16,15	3,13	5,98	16,52	2,76	6,93	16,88	2,44	8,04	17,25	2,15	15°C
5,15	16,15	3,13	5,97	16,52	2,76	6,93	16,88	2,44	8,03	17,25	2,15	14°C
5,15	16,15	3,14	5,97	16,52	2,77	6,92	16,88	2,44	8,02	17,25	2,15	13°C
5,14	16,15	3,14	5,96	16,52	2,77	6,91	16,88	2,44	8,01	17,25	2,15	12°C
5,45	16,46	3,02	6,27	16,83	2,68	7,22	17,20	2,38	8,32	17,57	2,11	11°C
5,72	16,73	2,93	6,54	17,10	2,62	7,48	17,47	2,33	8,58	17,84	2,08	10°C
6,03	17,05	2,83	6,84	17,42	2,54	7,79	17,78	2,28	8,89	18,15	2,04	9°C
6,29	17,32	2,75	7,11	17,69	2,49	8,05	18,05	2,24	9,15	18,42	2,01	8°C
6,74	17,77	2,64	7,55	18,14	2,40	8,50	18,50	2,18	9,59	18,87	1,97	7°C
9,04	19,19	2,12	9,68	19,45	2,01	10,40	19,71	1,90	11,21	19,96	1,78	6°C
10,91	20,34	1,86	11,41	20,50	1,80	11,95	20,67	1,73	12,55	20,83	1,66	5°C
12,43	21,31	1,71	12,83	21,39	1,67	13,26	21,48	1,62	13,70	21,56	1,57	4°C
13,62	22,09	1,62	13,96	22,11	1,58	14,31	22,14	1,55	14,66	22,17	1,51	3°C
15,01	23,05	1,54	15,33	23,00	1,50	15,65	22,95	1,47	15,97	22,90	1,43	2°C
14,99	22,61	1,51	15,30	22,36	1,46	15,61	22,11	1,42	15,92	21,97	1,38	1°C
14,94	22,18	1,48	15,21	21,72	1,43	15,48	21,27	1,37	15,76	21,03	1,34	0°C
14,85	21,74	1,46	15,06	21,08	1,40	15,27	20,43	1,34	15,49	20,10	1,30	-1°C
14,73	21,31	1,45	14,85	20,44	1,38	14,97	19,58	1,31	15,11	19,17	1,27	-2°C
14,58	20,87	1,43	14,58	19,81	1,36	14,59	18,74	1,28	14,62	18,23	1,25	-3°C
14,39	20,43	1,42	14,25	19,17	1,34	14,12	17,90	1,27	14,03	17,30	1,23	-4°C
14,16	20,00	1,41	13,87	18,53	1,34	13,57	17,06	1,26	13,33	16,37	1,23	-5°C
13,90	19,56	1,41	13,42	17,89	1,33	12,93	16,22	1,25	12,52	15,43	1,23	-6°C
13,61	19,13	1,41	12,91	17,25	1,34	12,21	15,38	1,26	11,60	14,50	1,25	-7°C
14,05	19,11	1,36	13,60	17,35	1,28	13,15	15,59	1,19	12,86	14,98	1,16	-8°C
14,48	19,09	1,32	14,28	17,45	1,22	14,09	15,81	1,12	14,12	15,45	1,09	-9°C
14,91	19,07	1,28	14,97	17,55	1,17	15,02	16,02	1,07	15,37	15,93	1,04	-10°C
14,63	18,36	1,25	14,68	16,97	1,16	14,73	15,59	1,06	9,00	9,00	1,00	-11°C
14,35	17,64	1,23	14,39	16,39	1,14	14,44	15,15	1,05	9,00	9,00	1,00	-12°C
14,07	16,92	1,20	14,11	15,82	1,12	14,14	14,71	1,04	9,00	9,00	1,00	-13°C
13,79	16,20	1,18	13,82	15,24	1,10	13,85	14,27	1,03	9,00	9,00	1,00	-14°C
13,51	15,49	1,15	13,53	14,66	1,08	13,55	13,84	1,02	9,00	9,00	1,00	-15°C
13,52	15,39	1,14	13,54	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-16°C
13,54	15,30	1,13	13,55	14,43	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-17°C
13,55	15,21	1,12	13,56	14,32	1,06	9,00	9,00	1,00	9,00	9,00	1,00	-18°C
13,57	15,11	1,11	13,57	14,21	1,05	9,00	9,00	1,00	9,00	9,00	1,00	-19°C
13,58	15,02	1,11	13,57	14,09	1,04	9,00	9,00	1,00	9,00	9,00	1,00	-20°C
13,59	14,93	1,10	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-21°C
13,61	14,83	1,09	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-22°C
13,62	14,74	1,08	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-23°C
13,64	14,65	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-24°C
13,65	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 9TRI (backup 9kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	1,91	13,33	6,98	2,37	13,33	5,63	2,69	13,13	4,89	3,22	13,10	4,06	3,68	13,15	3,57	4,14	13,23	3,20	4,60	13,34	2,90
34°C	1,90	13,30	6,99	2,36	13,30	5,64	2,68	13,11	4,90	3,22	13,07	4,06	3,68	13,12	3,57	4,14	13,21	3,19	4,59	13,31	2,90
33°C	1,89	13,27	7,01	2,35	13,27	5,65	2,67	13,08	4,91	3,22	13,05	4,06	3,67	13,10	3,56	4,13	13,18	3,19	4,59	13,29	2,89
32°C	1,89	13,25	7,02	2,34	13,25	5,66	2,65	13,06	4,92	3,21	13,02	4,05	3,67	13,07	3,56	4,13	13,16	3,19	4,59	13,26	2,89
31°C	1,88	13,22	7,04	2,33	13,22	5,67	2,64	13,03	4,93	3,21	13,00	4,05	3,67	13,04	3,56	4,12	13,13	3,18	4,58	13,24	2,89
30°C	1,87	13,19	7,05	2,32	13,19	5,69	2,63	13,00	4,94	3,21	12,97	4,04	3,66	13,02	3,55	4,12	13,10	3,18	4,58	13,21	2,89
29°C	1,86	13,17	7,06	2,31	13,17	5,70	2,62	12,98	4,95	3,20	12,94	4,04	3,66	12,99	3,55	4,12	13,08	3,18	4,57	13,18	2,88
28°C	1,86	13,14	7,08	2,30	13,14	5,71	2,61	12,95	4,96	3,20	12,92	4,04	3,66	12,97	3,55	4,11	13,05	3,17	4,57	13,16	2,88
27°C	1,85	13,11	7,09	2,29	13,11	5,72	2,60	12,93	4,97	3,20	12,89	4,03	3,65	12,94	3,54	4,11	13,03	3,17	4,56	13,13	2,88
26°C	1,84	13,09	7,11	2,28	13,09	5,73	2,59	12,90	4,98	3,19	12,87	4,03	3,65	12,92	3,54	4,10	13,00	3,17	4,56	13,11	2,88
25°C	1,83	13,06	7,12	2,27	13,06	5,74	2,58	12,87	4,99	3,19	12,84	4,02	3,64	12,89	3,54	4,10	12,97	3,17	4,55	13,08	2,87
24°C	1,83	13,04	7,13	2,27	13,04	5,75	2,57	12,85	5,00	3,19	12,81	4,02	3,64	12,86	3,53	4,10	12,95	3,16	4,55	13,05	2,87
23°C	1,82	13,01	7,15	2,26	13,01	5,77	2,56	12,82	5,01	3,18	12,79	4,02	3,64	12,84	3,53	4,09	12,92	3,16	4,54	13,03	2,87
22°C	1,81	12,98	7,16	2,25	12,98	5,78	2,55	12,80	5,02	3,18	12,76	4,01	3,63	12,81	3,53	4,09	12,90	3,16	4,54	13,00	2,86
21°C	1,81	12,96	7,18	2,24	12,96	5,79	2,54	12,77	5,03	3,18	12,74	4,01	3,63	12,79	3,52	4,08	12,87	3,15	4,54	12,98	2,86
20°C	1,80	12,93	7,19	2,23	12,93	5,80	2,53	12,75	5,04	3,17	12,71	4,00	3,63	12,76	3,52	4,08	12,85	3,15	4,53	12,97	2,86
19°C	1,79	12,91	7,21	2,22	12,91	5,81	2,52	12,72	5,05	3,17	12,69	4,00	3,62	12,74	3,52	4,07	12,82	3,15	4,53	12,97	2,87
18°C	1,78	12,88	7,22	2,21	12,88	5,82	2,51	12,70	5,06	3,17	12,66	4,00	3,62	12,71	3,51	4,07	12,80	3,14	4,52	12,97	2,87
17°C	1,78	12,85	7,23	2,20	12,85	5,83	2,50	12,67	5,07	3,17	12,64	3,99	3,62	12,69	3,51	4,07	12,78	3,14	4,52	12,97	2,87
16°C	1,77	12,83	7,25	2,19	12,83	5,85	2,49	12,65	5,08	3,16	12,61	3,99	3,61	12,66	3,50	4,06	12,78	3,15	4,51	12,97	2,87
15°C	1,76	12,80	7,26	2,19	12,80	5,86	2,48	12,62	5,09	3,16	12,59	3,98	3,61	12,64	3,50	4,06	12,78	3,15	4,51	12,97	2,88
14°C	1,76	12,78	7,28	2,18	12,78	5,87	2,47	12,59	5,10	3,16	12,56	3,98	3,61	12,61	3,50	4,05	12,78	3,15	4,50	12,97	2,88
13°C	1,75	12,75	7,29	2,17	12,75	5,88	2,46	12,57	5,11	3,15	12,54	3,98	3,60	12,59	3,50	4,05	12,78	3,16	4,50	12,97	2,88
12°C	1,74	12,73	7,31	2,16	12,73	5,89	2,45	12,54	5,12	3,15	12,51	3,97	3,60	12,59	3,50	4,05	12,78	3,16	4,49	12,97	2,89
11°C	2,10	12,96	6,18	2,51	12,96	5,16	2,82	12,82	4,54	3,46	12,79	3,70	3,91	12,91	3,30	4,36	13,10	3,01	4,81	13,29	2,76
10°C	2,41	13,15	5,45	2,82	13,15	4,67	3,15	13,06	4,14	3,73	13,02	3,49	4,18	13,18	3,16	4,62	13,37	2,89	5,07	13,56	2,67
9°C	2,77	13,39	4,84	3,17	13,39	4,23	3,53	13,34	3,78	4,04	13,30	3,29	4,49	13,49	3,01	4,93	13,68	2,77	5,38	13,87	2,58
8°C	3,08	13,58	4,41	3,47	13,58	3,91	3,85	13,57	3,52	4,31	13,57	3,15	4,75	13,76	2,89	5,20	13,95	2,68	5,65	14,14	2,50
7°C	3,57	13,95	3,90	3,96	13,95	3,52	4,33	13,95	3,22	4,75	14,02	2,95	5,20	14,21	2,73	5,65	14,40	2,55	6,09	14,59	2,39
6°C	5,89	15,77	2,68	6,25	15,71	2,52	6,58	15,65	2,38	6,94	15,65	2,26	7,31	15,73	2,15	7,69	15,81	2,06	8,06	15,89	1,97
5°C	7,77	17,26	2,22	8,11	17,15	2,12	8,40	17,04	2,03	8,71	16,97	1,95	9,03	16,96	1,88	9,35	16,94	1,81	9,67	16,93	1,75
4°C	9,31	18,51	1,99	9,63	18,36	1,91	9,90	18,21	1,84	10,18	18,08	1,78	10,46	17,99	1,72	10,74	17,90	1,67	11,02	17,81	1,62
3°C	10,50	19,51	1,86	10,81	19,32	1,79	11,07	19,14	1,73	11,32	18,97	1,68	11,58	18,82	1,63	11,84	18,67	1,58	12,10	18,52	1,53
2°C	11,89	20,75	1,75	12,20	20,52	1,68	12,45	20,30	1,63	12,69	20,07	1,58	12,94	19,85	1,53	13,19	19,63	1,49	13,44	19,40	1,44
1°C	11,90	20,70	1,74	12,20	20,45	1,68	12,45	20,21	1,62	12,70	19,99	1,57	12,95	19,77	1,53	13,19	19,47	1,48	13,45	19,22	1,43
0°C	11,93	20,65	1,73	12,23	20,38	1,67	12,47	20,12	1,61	12,71	19,91	1,57	12,95	19,70	1,52	13,19	19,32	1,46	13,47	19,03	1,41
-1°C	11,98	20,60	1,72	12,27	20,30	1,66	12,51	20,03	1,60	12,74	19,82	1,56	12,96	19,62	1,51	13,19	19,17	1,45	13,50	18,85	1,40
-2°C	12,06	20,55	1,70	12,32	20,23	1,64	12,56	19,94	1,59	12,77	19,74	1,55	12,98	19,55	1,51	13,19	19,02	1,44	13,54	18,67	1,38
-3°C	12,15	20,50	1,69	12,39	20,15	1,63	12,63	19,84	1,57	12,81	19,66	1,53	13,00	19,47	1,50	13,19	18,87	1,43	13,60	18,48	1,36
-4°C	12,27	20,45	1,67	12,48	20,08	1,61	12,71	19,75	1,55	12,87	19,57	1,52	13,02	19,39	1,49	13,19	18,72	1,42	13,67	18,30	1,34
-5°C	12,41	20,40	1,64	12,58	20,00	1,59	12,80	19,66	1,54	12,93	19,49	1,51	13,05	19,32	1,48	13,19	18,56	1,41	13,75	18,12	1,32
-6°C	12,57	20,35	1,62	12,70	19,93	1,57	12,91	19,57	1,52	13,00	19,41	1,49	13,09	19,24	1,47	13,19	18,41	1,40	13,84	17,93	1,30
-7°C	12,75	20,30	1,59	12,83	19,86	1,55	13,03	19,48	1,49	13,08	19,32	1,48	13,12	19,17	1,46	13,19	18,26	1,38	13,94	17,75	1,27
-8°C	12,95	20,14	1,56	13,01	19,67	1,51	13,14	19,25	1,47	13,17	18,99	1,44	13,20	18,73	1,42	13,25	17,97	1,36	13,75	17,47	1,27
-9°C	13,15	19,98	1,52	13,18	19,49	1,48	13,25	19,03	1,44	13,26	18,66	1,41	13,28	18,29	1,38	13,31	17,67	1,33	13,56	17,18	1,27
-10°C	13,35	19,82	1,48	13,35	19,31	1,45	13,36	18,80	1,41	13,36	18,33	1,37	13,36	17,85	1,34	13,36	17,38	1,30	13,36	16,90	1,26
-11°C	13,17	19,40	1,47	13,21	18,98	1,44	13,26	18,55	1,40	13,29	18,15	1,37	13,32	17,75	1,33	13,36	17,33	1,30	13,39	16,78	1,25
-12°C	12,99	18,98	1,46	13,07	18,64	1,43	13,16	18,30	1,39	13,22	17,98	1,36	13,29	17,66	1,33	13,35	17,28	1,29	13,41	16,66	1,24
-13°C	12,81	18,56	1,45	12,93	18,31	1,42	13,06	18,05	1,38	13,16	17,81	1,35	13,25	17,56	1,33	13,34	17,23	1,29	13,44	16,55	1,23
-14°C	12,62	18,14	1,44	12,79	17,97	1,40	12,96	17,80	1,37	13,09	17,63	1,35	13,21	17,47	1,32						

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
4,83	13,46	2,78	5,60	13,59	2,43	6,49	13,73	2,11	0,00	0,00	0,00	35°C
4,83	13,43	2,78	5,60	13,56	2,42	6,49	13,70	2,11	0,00	0,00	0,00	34°C
4,82	13,41	2,78	5,59	13,54	2,42	6,48	13,67	2,11	0,00	0,00	0,00	33°C
4,82	13,38	2,78	5,59	13,51	2,42	6,48	13,65	2,11	0,00	0,00	0,00	32°C
4,81	13,35	2,77	5,58	13,48	2,42	6,47	13,62	2,11	0,00	0,00	0,00	31°C
4,81	13,33	2,77	5,57	13,46	2,41	6,46	13,60	2,10	0,00	0,00	0,00	30°C
4,80	13,30	2,77	5,57	13,43	2,41	6,46	13,57	2,10	0,00	0,00	0,00	29°C
4,80	13,28	2,77	5,56	13,41	2,41	6,45	13,54	2,10	0,00	0,00	0,00	28°C
4,79	13,25	2,76	5,56	13,38	2,41	6,44	13,54	2,10	0,00	0,00	0,00	27°C
4,79	13,23	2,76	5,55	13,36	2,41	6,44	13,54	2,10	0,00	0,00	0,00	26°C
4,78	13,20	2,76	5,55	13,35	2,41	6,43	13,54	2,11	0,00	0,00	0,00	25°C
4,78	13,17	2,76	5,54	13,35	2,41	6,42	13,54	2,11	0,00	0,00	0,00	24°C
4,78	13,16	2,76	5,54	13,35	2,41	6,42	13,54	2,11	0,00	0,00	0,00	23°C
4,77	13,16	2,76	5,53	13,35	2,41	6,41	13,54	2,11	0,00	0,00	0,00	22°C
4,77	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,11	0,00	0,00	0,00	21°C
4,76	13,16	2,76	5,52	13,35	2,42	6,40	13,54	2,12	0,00	0,00	0,00	20°C
4,76	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,41	13,73	1,85	19°C
4,75	13,16	2,77	5,51	13,35	2,42	6,39	13,54	2,12	7,40	13,73	1,85	18°C
4,75	13,16	2,77	5,50	13,35	2,43	6,38	13,54	2,12	7,40	13,73	1,86	17°C
4,74	13,16	2,78	5,50	13,35	2,43	6,37	13,54	2,12	7,39	13,73	1,86	16°C
4,74	13,16	2,78	5,49	13,35	2,43	6,37	13,54	2,13	7,38	13,73	1,86	15°C
4,73	13,16	2,78	5,49	13,35	2,43	6,36	13,54	2,13	7,37	13,73	1,86	14°C
4,73	13,16	2,78	5,48	13,35	2,44	6,35	13,54	2,13	7,37	13,73	1,86	13°C
4,72	13,16	2,79	5,48	13,35	2,44	6,35	13,54	2,13	7,36	13,73	1,87	12°C
5,03	13,47	2,68	5,78	13,66	2,36	6,66	13,85	2,08	7,67	14,04	1,83	11°C
5,30	13,74	2,59	6,05	13,93	2,30	6,92	14,12	2,04	7,93	14,31	1,81	10°C
5,61	14,06	2,51	6,36	14,25	2,24	7,23	14,44	2,00	8,24	14,63	1,78	9°C
5,87	14,33	2,44	6,62	14,52	2,19	7,49	14,71	1,96	8,50	14,90	1,75	8°C
6,32	14,78	2,34	7,07	14,97	2,12	7,94	15,16	1,91	8,94	15,35	1,72	7°C
8,30	15,97	1,92	8,87	16,05	1,81	9,51	16,13	1,70	10,25	16,21	1,58	6°C
9,92	16,92	1,71	10,35	16,90	1,63	10,82	16,89	1,56	11,34	16,88	1,49	5°C
11,27	17,72	1,57	11,59	17,63	1,52	11,94	17,54	1,47	12,31	17,45	1,42	4°C
12,34	18,37	1,49	12,61	18,22	1,44	12,89	18,08	1,40	13,17	17,93	1,36	3°C
13,69	19,18	1,40	13,94	18,95	1,36	14,19	18,73	1,32	14,44	18,50	1,28	2°C
13,71	18,91	1,38	13,97	18,61	1,33	14,23	18,31	1,29	14,49	18,09	1,25	1°C
13,76	18,65	1,36	14,05	18,28	1,30	14,34	17,90	1,25	14,63	17,68	1,21	0°C
13,84	18,39	1,33	14,18	17,94	1,26	14,52	17,48	1,20	14,87	17,27	1,16	-1°C
13,95	18,13	1,30	14,37	17,60	1,23	14,78	17,07	1,16	15,20	16,86	1,11	-2°C
14,10	17,87	1,27	14,60	17,26	1,18	15,10	16,66	1,10	15,63	16,45	1,05	-3°C
14,28	17,61	1,23	14,89	16,93	1,14	15,50	16,24	1,05	16,15	16,04	0,99	-4°C
14,49	17,35	1,20	15,23	16,59	1,09	15,98	15,83	0,99	16,77	15,63	0,93	-5°C
14,73	17,09	1,16	15,63	16,25	1,04	16,52	15,41	0,93	17,48	15,22	0,87	-6°C
15,01	16,83	1,12	16,08	15,92	0,99	17,14	15,00	0,88	18,29	14,81	0,81	-7°C
14,39	16,43	1,14	15,03	15,40	1,02	15,67	14,36	0,92	16,43	14,14	0,86	-8°C
13,77	16,03	1,16	13,98	14,87	1,06	14,19	13,72	0,97	14,58	13,46	0,92	-9°C
13,15	15,63	1,19	12,93	14,35	1,11	12,72	13,08	1,03	12,72	12,78	1,00	-10°C
13,22	15,60	1,18	13,05	14,41	1,10	12,88	13,23	1,03	9,00	9,00	1,00	-11°C
13,29	15,57	1,17	13,17	14,48	1,10	13,05	13,38	1,03	9,00	9,00	1,00	-12°C
13,37	15,54	1,16	13,29	14,54	1,09	13,22	13,53	1,02	9,00	9,00	1,00	-13°C
13,44	15,51	1,15	13,41	14,60	1,09	13,39	13,69	1,02	9,00	9,00	1,00	-14°C
13,51	15,49	1,15	13,53	14,66	1,08	13,55	13,84	1,02	9,00	9,00	1,00	-15°C
13,52	15,39	1,14	13,54	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-16°C
13,54	15,30	1,13	13,55	14,43	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-17°C
13,55	15,21	1,12	13,56	14,32	1,06	9,00	9,00	1,00	9,00	9,00	1,00	-18°C
13,57	15,11	1,11	13,57	14,21	1,05	9,00	9,00	1,00	9,00	9,00	1,00	-19°C
13,58	15,02	1,11	13,57	14,09	1,04	9,00	9,00	1,00	9,00	9,00	1,00	-20°C
13,59	14,93	1,10	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-21°C
13,61	14,83	1,09	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-22°C
13,62	14,74	1,08	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-23°C
13,64	14,65	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-24°C
13,65	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-25°C

▼ AUREA 2 & AUREA 2 DHW 12TRI (backup 9kW)

	Starting temperature																				
	25°C			30°C			35°C			40°C			45°C			50°C			55°C		
	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP
35°C	2,16	15,48	7,16	2,65	15,48	5,84	3,00	15,32	5,11	3,54	15,30	4,32	4,04	15,39	3,81	4,54	15,54	3,42	5,04	15,73	3,12
34°C	2,15	15,45	7,18	2,64	15,45	5,85	2,98	15,29	5,12	3,54	15,27	4,31	4,04	15,36	3,80	4,54	15,51	3,42	5,03	15,70	3,12
33°C	2,14	15,42	7,19	2,63	15,42	5,86	2,97	15,26	5,13	3,54	15,24	4,31	4,03	15,33	3,80	4,53	15,48	3,42	5,03	15,67	3,12
32°C	2,14	15,39	7,21	2,62	15,39	5,87	2,96	15,23	5,14	3,53	15,21	4,30	4,03	15,30	3,79	4,53	15,45	3,41	5,02	15,64	3,11
31°C	2,13	15,36	7,22	2,61	15,36	5,89	2,95	15,20	5,16	3,53	15,18	4,30	4,03	15,27	3,79	4,52	15,42	3,41	5,02	15,63	3,11
30°C	2,12	15,33	7,23	2,60	15,33	5,90	2,94	15,17	5,17	3,53	15,15	4,29	4,02	15,24	3,79	4,52	15,39	3,41	5,01	15,63	3,12
29°C	2,11	15,30	7,25	2,59	15,30	5,91	2,93	15,14	5,18	3,52	15,12	4,29	4,02	15,20	3,78	4,51	15,36	3,40	5,01	15,63	3,12
28°C	2,10	15,27	7,26	2,58	15,27	5,92	2,91	15,11	5,19	3,52	15,08	4,29	4,01	15,17	3,78	4,51	15,33	3,40	5,00	15,63	3,12
27°C	2,09	15,23	7,28	2,57	15,23	5,93	2,90	15,08	5,20	3,52	15,05	4,28	4,01	15,14	3,78	4,50	15,30	3,40	5,00	15,63	3,13
26°C	2,08	15,20	7,29	2,56	15,20	5,94	2,89	15,05	5,21	3,51	15,02	4,28	4,01	15,11	3,77	4,50	15,28	3,40	4,99	15,63	3,13
25°C	2,08	15,17	7,31	2,55	15,17	5,96	2,88	15,02	5,22	3,51	14,99	4,27	4,00	15,08	3,77	4,50	15,28	3,40	4,99	15,63	3,13
24°C	2,07	15,14	7,32	2,54	15,14	5,97	2,87	14,99	5,23	3,51	14,96	4,27	4,00	15,05	3,77	4,49	15,28	3,40	4,98	15,63	3,14
23°C	2,06	15,11	7,34	2,53	15,11	5,98	2,86	14,96	5,24	3,50	14,94	4,26	3,99	15,02	3,76	4,49	15,28	3,41	4,98	15,63	3,14
22°C	2,05	15,08	7,35	2,52	15,08	5,99	2,84	14,93	5,25	3,50	14,91	4,26	3,99	15,00	3,76	4,48	15,28	3,41	4,97	15,63	3,14
21°C	2,04	15,05	7,37	2,51	15,05	6,00	2,83	14,90	5,26	3,50	14,88	4,26	3,99	14,97	3,75	4,48	15,28	3,41	4,97	15,63	3,15
20°C	2,04	15,02	7,38	2,50	15,02	6,02	2,82	14,87	5,27	3,49	14,85	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
19°C	2,03	14,99	7,40	2,49	14,99	6,03	2,81	14,84	5,28	3,49	14,82	4,25	3,98	14,94	3,75	4,47	15,28	3,42	4,96	15,63	3,15
18°C	2,02	14,96	7,41	2,48	14,96	6,04	2,80	14,81	5,29	3,48	14,79	4,24	3,97	14,94	3,76	4,46	15,28	3,42	4,95	15,63	3,16
17°C	2,01	14,93	7,42	2,47	14,93	6,05	2,79	14,78	5,30	3,48	14,76	4,24	3,97	14,94	3,76	4,46	15,28	3,43	4,95	15,63	3,16
16°C	2,00	14,90	7,44	2,46	14,90	6,06	2,78	14,75	5,31	3,48	14,73	4,23	3,97	14,94	3,77	4,46	15,28	3,43	4,94	15,63	3,16
15°C	2,00	14,87	7,45	2,45	14,87	6,08	2,77	14,72	5,32	3,47	14,70	4,23	3,96	14,94	3,77	4,45	15,28	3,43	4,94	15,63	3,16
14°C	1,99	14,84	7,47	2,44	14,84	6,09	2,76	14,69	5,33	3,47	14,67	4,23	3,96	14,94	3,77	4,45	15,28	3,44	4,93	15,63	3,17
13°C	1,98	14,81	7,48	2,43	14,81	6,10	2,74	14,66	5,34	3,47	14,64	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,93	15,63	3,17
12°C	1,97	14,78	7,50	2,42	14,78	6,11	2,73	14,63	5,35	3,46	14,61	4,22	3,95	14,94	3,78	4,44	15,28	3,44	4,92	15,63	3,17
11°C	2,36	15,03	6,38	2,79	15,03	5,39	3,11	14,92	4,80	3,78	14,91	3,95	4,26	15,25	3,58	4,75	15,60	3,29	5,23	15,95	3,05
10°C	2,70	15,24	5,64	3,11	15,24	4,90	3,44	15,16	4,40	4,04	15,18	3,75	4,53	15,52	3,43	5,01	15,87	3,17	5,50	16,22	2,95
9°C	3,09	15,49	5,02	3,48	15,49	4,45	3,82	15,44	4,04	4,35	15,49	3,56	4,84	15,84	3,27	5,32	16,18	3,04	5,81	16,53	2,85
8°C	3,43	15,69	4,58	3,80	15,69	4,13	4,16	15,68	3,77	4,62	15,76	3,41	5,11	16,11	3,16	5,59	16,45	2,94	6,07	16,80	2,77
7°C	3,95	16,07	4,07	4,30	16,07	3,73	4,64	16,07	3,47	5,07	16,21	3,20	5,55	16,56	2,98	6,04	16,90	2,80	6,52	17,25	2,65
6°C	6,32	18,05	2,86	6,84	18,03	2,64	7,15	18,01	2,52	7,54	18,10	2,40	7,95	18,33	2,30	8,37	18,56	2,22	8,78	18,80	2,14
5°C	8,24	19,67	2,39	8,88	19,64	2,21	9,19	19,60	2,13	9,54	19,63	2,06	9,90	19,77	2,00	10,26	19,91	1,94	10,63	20,05	1,89
4°C	9,81	21,02	2,14	10,54	20,97	1,99	10,84	20,92	1,93	11,16	20,92	1,87	11,48	20,98	1,83	11,81	21,04	1,78	12,13	21,10	1,74
3°C	11,01	22,10	2,01	11,80	22,04	1,87	12,10	21,98	1,82	12,40	21,94	1,77	12,70	21,94	1,73	13,01	21,95	1,69	13,31	21,95	1,65
2°C	12,41	23,45	1,89	13,22	23,37	1,77	13,51	23,30	1,72	13,81	23,22	1,68	14,10	23,15	1,64	14,40	23,08	1,60	14,69	23,00	1,57
1°C	12,40	23,25	1,87	13,21	23,18	1,76	13,50	23,08	1,71	13,80	22,99	1,67	14,10	22,90	1,62	14,40	22,88	1,59	14,69	22,78	1,55
0°C	12,39	23,05	1,86	13,18	22,99	1,74	13,48	22,85	1,70	13,78	22,75	1,65	14,09	22,65	1,61	14,40	22,69	1,58	14,68	22,56	1,54
-1°C	12,37	22,85	1,85	13,14	22,79	1,73	13,45	22,63	1,68	13,76	22,52	1,64	14,07	22,41	1,59	14,40	22,49	1,56	14,66	22,33	1,52
-2°C	12,34	22,65	1,84	13,08	22,60	1,73	13,40	22,41	1,67	13,72	22,28	1,62	14,04	22,16	1,58	14,40	22,30	1,55	14,64	22,11	1,51
-3°C	12,30	22,45	1,82	13,01	22,40	1,72	13,33	22,18	1,66	13,67	22,05	1,61	14,01	21,91	1,56	14,41	22,11	1,53	14,61	21,89	1,50
-4°C	12,26	22,25	1,82	12,92	22,21	1,72	13,25	21,96	1,66	13,61	21,81	1,60	13,97	21,66	1,55	14,41	21,91	1,52	14,57	21,67	1,49
-5°C	12,20	22,05	1,81	12,81	22,01	1,72	13,16	21,74	1,65	13,54	21,58	1,59	13,92	21,42	1,54	14,42	21,72	1,51	14,53	21,44	1,48
-6°C	12,14	21,85	1,80	12,69	21,82	1,72	13,05	21,51	1,65	13,46	21,34	1,59	13,87	21,17	1,53	14,42	21,53	1,49	14,48	21,22	1,47
-7°C	12,07	21,65	1,79	12,55	21,62	1,72	12,93	21,29	1,65	13,37	21,11	1,58	13,80	20,92	1,52	14,43	21,33	1,48	14,43	21,00	1,46
-8°C	12,21	21,57	1,77	12,66	21,50	1,70	13,05	21,23	1,63	13,47	21,05	1,56	13,90	20,86	1,50	14,45	21,08	1,46	14,58	20,80	1,43
-9°C	12,35	21,49	1,74	12,78	21,38	1,67	13,17	21,16	1,61	13,58	20,99	1,55	13,99	20,81	1,49	14,46	20,83	1,44	14,73	20,60	1,40
-10°C	12,50	21,40	1,71	12,89	21,25	1,65	13,29	21,10	1,59	13,69	20,93	1,53	14,08	20,75	1,47	14,48	20,58	1,42	14,88	20,40	1,37
-11°C	12,49	20,67	1,66	12,85	20,53	1,60	13,21	20,39	1,54	13,55	20,23	1,49	13,90	20,07	1,44	14,25	19,89	1,40	14,60	19,58	1,34
-12°C	12,48	19,93	1,60	12,80	19,81	1,55	13,12	19,68	1,50	13,42	19,54	1,46	13,72	19,40	1,41	14,02	19,20	1,37	14,32	18,76	1,31
-13°C	12,46	19,20	1,54	12,75	19,08	1,50	13,04	18,97	1,46	13,29	18,85	1,42	13,54	18,72	1,38	13,79	18,51	1,34	14,04	17,95	1,28
-14°C	12,45	18,46	1,48	12,70	18,36	1,45	12,95	18,26	1,41	13,16	18,15	1,38	13								

60°C			65°C			70°C			75°C			Outdoor temperature
Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	Pabs	Pcal	COP	
5,29	15,98	3,02	6,14	16,32	2,66	7,12	16,67	2,34	0,00	0,00	0,00	35°C
5,29	15,98	3,02	6,13	16,32	2,66	7,11	16,67	2,34	0,00	0,00	0,00	34°C
5,28	15,98	3,02	6,13	16,32	2,66	7,10	16,67	2,35	0,00	0,00	0,00	33°C
5,28	15,98	3,03	6,12	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	32°C
5,27	15,98	3,03	6,11	16,32	2,67	7,09	16,67	2,35	0,00	0,00	0,00	31°C
5,27	15,98	3,03	6,11	16,32	2,67	7,08	16,67	2,35	0,00	0,00	0,00	30°C
5,26	15,98	3,04	6,10	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	29°C
5,26	15,98	3,04	6,09	16,32	2,68	7,07	16,67	2,36	0,00	0,00	0,00	28°C
5,25	15,98	3,04	6,09	16,32	2,68	7,06	16,67	2,36	0,00	0,00	0,00	27°C
5,25	15,98	3,04	6,08	16,32	2,68	7,05	16,67	2,36	0,00	0,00	0,00	26°C
5,24	15,98	3,05	6,08	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	25°C
5,24	15,98	3,05	6,07	16,32	2,69	7,04	16,67	2,37	0,00	0,00	0,00	24°C
5,23	15,98	3,05	6,06	16,32	2,69	7,03	16,67	2,37	0,00	0,00	0,00	23°C
5,23	15,98	3,06	6,06	16,32	2,69	7,02	16,67	2,37	0,00	0,00	0,00	22°C
5,22	15,98	3,06	6,05	16,32	2,70	7,02	16,67	2,38	0,00	0,00	0,00	21°C
5,22	15,98	3,06	6,05	16,32	2,70	7,01	16,67	2,38	0,00	0,00	0,00	20°C
5,21	15,98	3,07	6,04	16,32	2,70	7,00	16,67	2,38	8,12	17,01	2,10	19°C
5,21	15,98	3,07	6,03	16,32	2,70	7,00	16,67	2,38	8,11	17,01	2,10	18°C
5,20	15,98	3,07	6,03	16,32	2,71	6,99	16,67	2,38	8,10	17,01	2,10	17°C
5,19	15,98	3,08	6,02	16,32	2,71	6,98	16,67	2,39	8,09	17,01	2,10	16°C
5,19	15,98	3,08	6,02	16,32	2,71	6,97	16,67	2,39	8,09	17,01	2,10	15°C
5,18	15,98	3,08	6,01	16,32	2,72	6,97	16,67	2,39	8,08	17,01	2,11	14°C
5,18	15,98	3,08	6,00	16,32	2,72	6,96	16,67	2,39	8,07	17,01	2,11	13°C
5,17	15,98	3,09	6,00	16,32	2,72	6,95	16,67	2,40	8,06	17,01	2,11	12°C
5,48	16,29	2,97	6,31	16,64	2,64	7,26	16,98	2,34	8,37	17,33	2,07	11°C
5,75	16,56	2,88	6,57	16,91	2,57	7,52	17,25	2,29	8,63	17,60	2,04	10°C
6,06	16,88	2,79	6,88	17,22	2,50	7,83	17,57	2,24	8,94	17,91	2,00	9°C
6,32	17,15	2,71	7,14	17,49	2,45	8,10	17,84	2,20	9,20	18,18	1,98	8°C
6,77	17,60	2,60	7,59	17,94	2,36	8,54	18,29	2,14	9,64	18,63	1,93	7°C
9,05	19,03	2,10	9,68	19,27	1,99	10,40	19,50	1,88	11,21	19,73	1,76	6°C
10,90	20,19	1,85	11,39	20,33	1,79	11,92	20,47	1,72	12,51	20,61	1,65	5°C
12,42	21,16	1,70	12,80	21,23	1,66	13,20	21,29	1,61	13,63	21,35	1,57	4°C
13,60	21,95	1,61	13,92	21,95	1,58	14,24	21,96	1,54	14,57	21,96	1,51	3°C
14,99	22,93	1,53	15,28	22,85	1,50	15,58	22,78	1,46	15,87	22,70	1,43	2°C
14,97	22,53	1,50	15,26	22,28	1,46	15,54	22,04	1,42	15,83	21,90	1,38	1°C
14,93	22,14	1,48	15,19	21,72	1,43	15,45	21,30	1,38	15,71	21,10	1,34	0°C
14,87	21,74	1,46	15,08	21,15	1,40	15,29	20,56	1,34	15,50	20,30	1,31	-1°C
14,78	21,35	1,44	14,92	20,58	1,38	15,06	19,82	1,32	15,22	19,50	1,28	-2°C
14,66	20,95	1,43	14,72	20,02	1,36	14,77	19,08	1,29	14,85	18,70	1,26	-3°C
14,52	20,56	1,42	14,47	19,45	1,34	14,41	18,34	1,27	14,40	17,90	1,24	-4°C
14,35	20,16	1,40	14,17	18,88	1,33	13,99	17,60	1,26	13,87	17,10	1,23	-5°C
14,16	19,77	1,39	13,84	18,32	1,32	13,51	16,86	1,25	13,26	16,30	1,23	-6°C
13,94	19,38	1,40	13,45	17,75	1,32	12,96	16,13	1,24	12,56	15,50	1,23	-7°C
14,27	19,21	1,35	13,95	17,62	1,26	13,64	16,03	1,18	13,49	15,58	1,16	-8°C
14,59	19,05	1,31	14,46	17,50	1,21	14,32	15,94	1,11	14,42	15,66	1,09	-9°C
14,92	18,88	1,27	14,96	17,37	1,16	15,01	15,85	1,06	15,34	15,74	1,03	-10°C
14,64	18,20	1,24	14,68	16,83	1,15	14,71	15,45	1,05	9,00	9,00	1,00	-11°C
14,36	17,52	1,22	14,39	16,29	1,13	14,42	15,05	1,04	9,00	9,00	1,00	-12°C
14,07	16,85	1,20	14,10	15,74	1,12	14,13	14,64	1,04	9,00	9,00	1,00	-13°C
13,79	16,17	1,17	13,82	15,20	1,10	13,84	14,24	1,03	9,00	9,00	1,00	-14°C
13,51	15,49	1,15	13,53	14,66	1,08	13,55	13,84	1,02	9,00	9,00	1,00	-15°C
13,52	15,39	1,14	13,54	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-16°C
13,54	15,30	1,13	13,55	14,43	1,07	9,00	9,00	1,00	9,00	9,00	1,00	-17°C
13,55	15,21	1,12	13,56	14,32	1,06	9,00	9,00	1,00	9,00	9,00	1,00	-18°C
13,57	15,11	1,11	13,57	14,21	1,05	9,00	9,00	1,00	9,00	9,00	1,00	-19°C
13,58	15,02	1,11	13,57	14,09	1,04	9,00	9,00	1,00	9,00	9,00	1,00	-20°C
13,59	14,93	1,10	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-21°C
13,61	14,83	1,09	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-22°C
13,62	14,74	1,08	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-23°C
13,64	14,65	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-24°C
13,65	14,55	1,07	9,00	9,00	1,00	9,00	9,00	1,00	9,00	9,00	1,00	-25°C

► Performances tables in cooling mode

▼ AUREA 2 COMPACT 3

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	3,50	0,63	5,55	3,64	0,64	5,69	3,77	0,65	5,83	3,86	0,65	5,92	4,00	0,64	6,06	4,18	0,67	6,25
	21°C	3,50	0,64	5,43	3,64	0,65	5,58	3,77	0,66	5,73	3,86	0,66	5,84	4,00	0,67	6,00	4,18	0,67	6,21
	22°C	3,50	0,66	5,30	3,64	0,67	5,47	3,77	0,67	5,64	3,86	0,67	5,75	4,00	0,67	5,93	4,18	0,68	6,17
	23°C	3,50	0,68	5,18	3,64	0,68	5,36	3,77	0,68	5,54	3,86	0,68	5,66	4,00	0,68	5,86	4,18	0,68	6,14
	24°C	3,50	0,69	5,06	3,64	0,69	5,25	3,77	0,69	5,44	3,86	0,69	5,58	4,00	0,69	5,79	4,18	0,69	6,10
	25°C	3,50	0,71	4,93	3,64	0,71	5,13	3,77	0,71	5,35	3,86	0,70	5,49	4,00	0,70	5,73	4,18	0,69	6,06
	26°C	3,50	0,73	4,81	3,64	0,72	5,02	3,77	0,72	5,25	3,86	0,71	5,41	4,00	0,71	5,66	4,18	0,69	6,02
	27°C	3,50	0,75	4,69	3,64	0,74	4,91	3,77	0,73	5,15	3,86	0,73	5,32	4,00	0,72	5,59	4,18	0,70	5,98
	28°C	3,50	0,77	4,56	3,64	0,76	4,80	3,77	0,75	5,05	3,86	0,74	5,23	4,00	0,72	5,52	4,18	0,70	5,95
	29°C	3,50	0,79	4,44	3,64	0,78	4,69	3,77	0,76	4,96	3,86	0,75	5,15	4,00	0,73	5,46	4,18	0,71	5,91
	30°C	3,50	0,81	4,32	3,64	0,79	4,58	3,77	0,78	4,86	3,86	0,76	5,06	4,00	0,74	5,39	4,18	0,71	5,87
	31°C	3,50	0,83	4,19	3,64	0,81	4,47	3,77	0,79	4,76	3,86	0,78	4,98	4,00	0,75	5,32	4,18	0,72	5,83
	32°C	3,50	0,86	4,07	3,64	0,83	4,36	3,77	0,81	4,67	3,86	0,79	4,89	4,00	0,76	5,25	4,18	0,72	5,79
	33°C	3,50	0,89	3,95	3,64	0,86	4,24	3,77	0,83	4,57	3,86	0,80	4,80	4,00	0,77	5,19	4,18	0,73	5,76
	34°C	3,50	0,92	3,82	3,64	0,88	4,13	3,77	0,84	4,47	3,86	0,82	4,72	4,00	0,78	5,12	4,18	0,73	5,72
	35°C	3,50	0,95	3,70	3,64	0,90	4,02	3,77	0,86	4,38	3,86	0,83	4,63	4,00	0,79	5,05	4,18	0,74	5,68
	36°C	3,38	0,95	3,57	3,50	0,90	3,87	3,61	0,86	4,19	3,68	0,83	4,41	3,78	0,79	4,77	3,88	0,74	5,28
	37°C	3,27	0,95	3,45	3,37	0,90	3,72	3,46	0,86	4,01	3,51	0,83	4,21	3,58	0,79	4,52	3,62	0,74	4,92
	38°C	3,16	0,95	3,34	3,25	0,90	3,59	3,32	0,86	3,85	3,36	0,83	4,03	3,40	0,79	4,29	3,40	0,74	4,62
	39°C	3,06	0,95	3,24	3,13	0,90	3,47	3,19	0,86	3,70	3,22	0,83	3,86	3,24	0,79	4,09	3,20	0,74	4,34
	40°C	2,97	0,95	3,14	3,03	0,90	3,35	3,07	0,86	3,57	3,09	0,83	3,71	3,09	0,79	3,90	3,02	0,74	4,10
	41°C	2,88	0,95	3,05	2,93	0,90	3,24	2,96	0,86	3,44	2,97	0,83	3,56	2,96	0,79	3,73	2,86	0,74	3,89
	42°C	2,80	0,95	2,96	2,84	0,90	3,14	2,86	0,86	3,32	2,86	0,83	3,43	2,83	0,79	3,58	2,72	0,74	3,69
	43°C	2,72	0,95	2,88	2,75	0,90	3,05	2,77	0,86	3,21	2,76	0,83	3,31	2,72	0,79	3,43	2,59	0,74	3,52
	44°C	2,65	0,95	2,80	2,67	0,90	2,96	2,68	0,86	3,11	2,66	0,83	3,19	2,62	0,79	3,30	2,47	0,74	3,36
	45°C	2,58	0,95	2,73	2,60	0,90	2,87	2,59	0,86	3,01	2,58	0,83	3,09	2,52	0,79	3,18	2,36	0,74	3,21
	46°C	2,51	0,95	2,66	2,53	0,90	2,79	2,52	0,86	2,92	2,49	0,83	2,99	2,43	0,79	3,07	2,27	0,74	3,08

▼ AUREA 2 COMPACT 4

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	5,00	0,91	5,48	5,27	0,94	5,61	5,55	0,97	5,75	5,73	0,98	5,84	6,00	0,98	5,97	6,36	1,03	6,15
	21°C	5,00	0,93	5,35	5,27	0,96	5,50	5,55	0,98	5,65	5,73	1,00	5,75	6,00	1,02	5,91	6,36	1,04	6,11
	22°C	5,00	0,96	5,23	5,27	0,98	5,39	5,55	1,00	5,56	5,73	1,01	5,67	6,00	1,03	5,84	6,36	1,05	6,08
	23°C	5,00	0,98	5,11	5,27	1,00	5,28	5,55	1,01	5,46	5,73	1,03	5,59	6,00	1,04	5,78	6,36	1,05	6,04
	24°C	5,00	1,00	4,99	5,27	1,02	5,18	5,55	1,03	5,37	5,73	1,04	5,50	6,00	1,05	5,71	6,36	1,06	6,00
	25°C	5,00	1,03	4,87	5,27	1,04	5,07	5,55	1,05	5,28	5,73	1,06	5,42	6,00	1,06	5,65	6,36	1,07	5,96
	26°C	5,00	1,05	4,75	5,27	1,06	4,96	5,55	1,07	5,18	5,73	1,07	5,34	6,00	1,07	5,58	6,36	1,07	5,93
	27°C	5,00	1,08	4,62	5,27	1,09	4,85	5,55	1,09	5,09	5,73	1,09	5,26	6,00	1,09	5,52	6,36	1,08	5,89
	28°C	5,00	1,11	4,50	5,27	1,11	4,74	5,55	1,11	5,00	5,73	1,11	5,17	6,00	1,10	5,45	6,36	1,09	5,85
	29°C	5,00	1,14	4,38	5,27	1,14	4,63	5,55	1,13	4,90	5,73	1,12	5,09	6,00	1,11	5,39	6,36	1,09	5,81
	30°C	5,00	1,17	4,26	5,27	1,17	4,53	5,55	1,15	4,81	5,73	1,14	5,01	6,00	1,13	5,32	6,36	1,10	5,78
	31°C	5,00	1,21	4,14	5,27	1,19	4,42	5,55	1,18	4,72	5,73	1,16	4,93	6,00	1,14	5,26	6,36	1,11	5,74
	32°C	5,00	1,25	4,02	5,27	1,22	4,31	5,55	1,20	4,62	5,73	1,18	4,84	6,00	1,16	5,19	6,36	1,12	5,70
	33°C	5,00	1,28	3,89	5,27	1,26	4,20	5,55	1,22	4,53	5,73	1,20	4,76	6,00	1,17	5,13	6,36	1,12	5,67
	34°C	5,00	1,33	3,77	5,27	1,29	4,09	5,55	1,25	4,44	5,73	1,22	4,68	6,00	1,18	5,06	6,36	1,13	5,63
	35°C	5,00	1,37	3,65	5,27	1,32	3,98	5,55	1,28	4,34	5,73	1,25	4,60	6,00	1,20	5,00	6,36	1,14	5,59
	36°C	4,83	1,37	3,52	5,07	1,32	3,83	5,30	1,28	4,15	5,45	1,25	4,38	5,67	1,20	4,72	5,91	1,14	5,19
	37°C	4,67	1,37	3,41	4,88	1,32	3,69	5,08	1,28	3,98	5,21	1,25	4,18	5,37	1,20	4,47	5,52	1,14	4,85
	38°C	4,52	1,37	3,30	4,71	1,32	3,56	4,88	1,28	3,82	4,98	1,25	4,00	5,10	1,20	4,25	5,17	1,14	4,54
	39°C	4,38	1,37	3,19	4,55	1,32	3,43	4,69	1,28	3,67	4,77	1,25	3,83	4,86	1,20	4,05	4,87	1,14	4,28
	40°C	4,24	1,37	3,10	4,39	1,32	3,32	4,52	1,28	3,54	4,58	1,25	3,68	4,64	1,20	3,86	4,60	1,14	4,04
	41°C	4,12	1,37	3,01	4,25	1,32	3,21	4,36	1,28	3,41	4,41	1,25	3,53	4,43	1,20	3,70	4,35	1,14	3,83
	42°C	4,00	1,37	2,92	4,12	1,32	3,11	4,21	1,28	3,29	4,24	1,25	3,40	4,25	1,20	3,54	4,14	1,14	3,63
	43°C	3,89	1,37	2,84	3,99	1,32	3,02	4,07	1,28	3,18	4,09	1,25	3,28	4,08	1,20	3,40	3,94	1,14	3,46
	44°C	3,78	1,37	2,76	3,88	1,32	2,93	3,94	1,28	3,08	3,95	1,25	3,17	3,92	1,20	3,27	3,76	1,14	3,30
	45°C	3,68	1,37	2,69	3,77	1,32	2,85	3,81	1,28	2,98	3,82	1,25	3,06	3,78	1,20	3,15	3,60	1,14	3,16
	46°C	3,59	1,37	2,62	3,66	1,32	2,77	3,70	1,28	2,89	3,70	1,25	2,96	3,64	1,20	3,04	3,45	1,14	3,03

▼ AUREA 2 COMPACT 5

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	6,80	1,31	5,18	6,99	1,31	5,33	7,18	1,31	5,48	7,31	1,31	5,58	7,50	1,26	5,73	7,75	1,31	5,94
	21°C	6,80	1,34	5,06	6,99	1,34	5,22	7,18	1,33	5,39	7,31	1,33	5,50	7,50	1,32	5,67	7,75	1,31	5,90
	22°C	6,80	1,38	4,95	6,99	1,37	5,12	7,18	1,36	5,29	7,31	1,35	5,42	7,50	1,34	5,60	7,75	1,32	5,87
	23°C	6,80	1,41	4,83	6,99	1,39	5,01	7,18	1,38	5,20	7,31	1,37	5,33	7,50	1,35	5,54	7,75	1,33	5,83
	24°C	6,80	1,44	4,72	6,99	1,42	4,91	7,18	1,41	5,11	7,31	1,39	5,25	7,50	1,37	5,47	7,75	1,34	5,79
	25°C	6,80	1,48	4,60	6,99	1,46	4,80	7,18	1,43	5,02	7,31	1,41	5,17	7,50	1,39	5,41	7,75	1,35	5,76
	26°C	6,80	1,52	4,49	6,99	1,49	4,70	7,18	1,46	4,92	7,31	1,44	5,08	7,50	1,40	5,34	7,75	1,36	5,72
	27°C	6,80	1,56	4,37	6,99	1,52	4,59	7,18	1,49	4,83	7,31	1,46	5,00	7,50	1,42	5,28	7,75	1,36	5,69
	28°C	6,80	1,60	4,26	6,99	1,56	4,49	7,18	1,52	4,74	7,31	1,49	4,92	7,50	1,44	5,21	7,75	1,37	5,65
	29°C	6,80	1,64	4,14	6,99	1,60	4,38	7,18	1,55	4,64	7,31	1,51	4,83	7,50	1,46	5,14	7,75	1,38	5,61
	30°C	6,80	1,69	4,03	6,99	1,63	4,28	7,18	1,58	4,55	7,31	1,54	4,75	7,50	1,48	5,08	7,75	1,39	5,58
	31°C	6,80	1,74	3,91	6,99	1,68	4,17	7,18	1,61	4,46	7,31	1,57	4,67	7,50	1,50	5,01	7,75	1,40	5,54
	32°C	6,80	1,79	3,80	6,99	1,72	4,07	7,18	1,65	4,37	7,31	1,59	4,58	7,50	1,52	4,95	7,75	1,41	5,51
	33°C	6,80	1,85	3,68	6,99	1,77	3,96	7,18	1,68	4,27	7,31	1,62	4,50	7,50	1,54	4,88	7,75	1,42	5,47
	34°C	6,80	1,91	3,57	6,99	1,81	3,86	7,18	1,72	4,18	7,31	1,65	4,42	7,50	1,56	4,82	7,75	1,43	5,43
	35°C	6,80	1,97	3,45	6,99	1,86	3,75	7,18	1,76	4,09	7,31	1,69	4,34	7,50	1,58	4,75	7,75	1,44	5,40
	36°C	6,57	1,97	3,33	6,72	1,86	3,61	6,87	1,76	3,91	6,96	1,69	4,13	7,08	1,58	4,49	7,20	1,44	5,01
	37°C	6,35	1,97	3,22	6,47	1,86	3,47	6,58	1,76	3,75	6,64	1,69	3,94	6,71	1,58	4,25	6,72	1,44	4,68
	38°C	6,14	1,97	3,12	6,24	1,86	3,35	6,32	1,76	3,60	6,36	1,69	3,77	6,38	1,58	4,04	6,30	1,44	4,39
	39°C	5,95	1,97	3,02	6,03	1,86	3,23	6,08	1,76	3,46	6,09	1,69	3,61	6,07	1,58	3,85	5,93	1,44	4,13
	40°C	5,77	1,97	2,93	5,83	1,86	3,13	5,85	1,76	3,33	5,85	1,69	3,47	5,80	1,58	3,67	5,60	1,44	3,90
	41°C	5,60	1,97	2,84	5,64	1,86	3,02	5,64	1,76	3,21	5,62	1,69	3,33	5,54	1,58	3,51	5,31	1,44	3,69
	42°C	5,44	1,97	2,76	5,46	1,86	2,93	5,45	1,76	3,10	5,41	1,69	3,21	5,31	1,58	3,36	5,04	1,44	3,51
	43°C	5,29	1,97	2,68	5,30	1,86	2,84	5,27	1,76	3,00	5,22	1,69	3,10	5,10	1,58	3,23	4,80	1,44	3,34
	44°C	5,15	1,97	2,61	5,14	1,86	2,76	5,10	1,76	2,90	5,04	1,69	2,99	4,90	1,58	3,11	4,58	1,44	3,19
	45°C	5,01	1,97	2,54	4,99	1,86	2,68	4,94	1,76	2,81	4,87	1,69	2,89	4,72	1,58	2,99	4,38	1,44	3,05
	46°C	4,88	1,97	2,48	4,85	1,86	2,60	4,79	1,76	2,72	4,72	1,69	2,80	4,55	1,58	2,88	4,20	1,44	2,92

▼ AUREA 2 COMPACT 7 / 7TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	8,50	1,74	4,88	8,77	1,77	4,95	9,05	1,80	5,03	9,23	1,82	5,08	9,50	1,80	5,16	9,86	1,87	5,26
	21°C	8,50	1,78	4,77	8,77	1,81	4,86	9,05	1,83	4,95	9,23	1,84	5,01	9,50	1,86	5,10	9,86	1,89	5,23
	22°C	8,50	1,82	4,66	8,77	1,84	4,76	9,05	1,86	4,86	9,23	1,87	4,93	9,50	1,88	5,05	9,86	1,90	5,20
	23°C	8,50	1,87	4,55	8,77	1,88	4,66	9,05	1,89	4,78	9,23	1,90	4,86	9,50	1,90	4,99	9,86	1,91	5,17
	24°C	8,50	1,91	4,44	8,77	1,92	4,57	9,05	1,93	4,70	9,23	1,93	4,79	9,50	1,93	4,93	9,86	1,92	5,14
	25°C	8,50	1,96	4,33	8,77	1,96	4,47	9,05	1,96	4,61	9,23	1,96	4,71	9,50	1,95	4,87	9,86	1,93	5,10
	26°C	8,50	2,01	4,23	8,77	2,01	4,37	9,05	2,00	4,53	9,23	1,99	4,64	9,50	1,97	4,82	9,86	1,94	5,07
	27°C	8,50	2,06	4,12	8,77	2,05	4,28	9,05	2,03	4,45	9,23	2,02	4,57	9,50	2,00	4,76	9,86	1,96	5,04
	28°C	8,50	2,12	4,01	8,77	2,10	4,18	9,05	2,07	4,36	9,23	2,05	4,49	9,50	2,02	4,70	9,86	1,97	5,01
	29°C	8,50	2,18	3,90	8,77	2,15	4,08	9,05	2,11	4,28	9,23	2,09	4,42	9,50	2,05	4,64	9,86	1,98	4,98
	30°C	8,50	2,24	3,79	8,77	2,20	3,99	9,05	2,16	4,20	9,23	2,12	4,35	9,50	2,07	4,59	9,86	1,99	4,94
	31°C	8,50	2,31	3,68	8,77	2,26	3,89	9,05	2,20	4,11	9,23	2,16	4,27	9,50	2,10	4,53	9,86	2,01	4,91
	32°C	8,50	2,38	3,58	8,77	2,31	3,79	9,05	2,24	4,03	9,23	2,20	4,20	9,50	2,12	4,47	9,86	2,02	4,88
	33°C	8,50	2,45	3,47	8,77	2,37	3,70	9,05	2,29	3,95	9,23	2,24	4,13	9,50	2,15	4,41	9,86	2,03	4,85
	34°C	8,50	2,53	3,36	8,77	2,44	3,60	9,05	2,34	3,86	9,23	2,28	4,05	9,50	2,18	4,36	9,86	2,05	4,82
	35°C	8,50	2,62	3,25	8,77	2,50	3,50	9,05	2,39	3,78	9,23	2,32	3,98	9,50	2,21	4,30	9,86	2,06	4,79
	36°C	8,21	2,62	3,14	8,44	2,50	3,37	8,65	2,39	3,61	8,79	2,32	3,79	8,97	2,21	4,06	9,16	2,06	4,44
	37°C	7,93	2,62	3,03	8,12	2,50	3,24	8,29	2,39	3,46	8,39	2,32	3,62	8,50	2,21	3,85	8,55	2,06	4,15
	38°C	7,68	2,62	2,94	7,83	2,50	3,13	7,96	2,39	3,33	8,02	2,32	3,46	8,07	2,21	3,66	8,01	2,06	3,89
	39°C	7,44	2,62	2,84	7,56	2,50	3,02	7,65	2,39	3,20	7,69	2,32	3,31	7,69	2,21	3,48	7,54	2,06	3,66
	40°C	7,21	2,62	2,76	7,31	2,50	2,92	7,37	2,39	3,08	7,38	2,32	3,18	7,34	2,21	3,32	7,12	2,06	3,46
	41°C	7,00	2,62	2,68	7,07	2,50	2,83	7,11	2,39	2,97	7,10	2,32	3,06	7,02	2,21	3,18	6,75	2,06	3,27
	42°C	6,80	2,62	2,60	6,85	2,50	2,74	6,86	2,39	2,87	6,84	2,32	2,95	6,73	2,21	3,05	6,41	2,06	3,11
	43°C	6,61	2,62	2,53	6,65	2,50	2,65	6,63	2,39	2,77	6,59	2,32	2,84	6,46	2,21	2,92	6,11	2,06	2,96
	44°C	6,43	2,62	2,46	6,45	2,50	2,58	6,42	2,39	2,68	6,36	2,32	2,74	6,21	2,21	2,81	5,83	2,06	2,83
	45°C	6,26	2,62	2,39	6,27	2,50	2,50	6,22	2,39	2,60	6,15	2,32	2,65	5,98	2,21	2,71	5,58	2,06	2,70
	46°C	6,10	2,62	2,33	6,09	2,50	2,43	6,03	2,39	2,52	5,95	2,32	2,57	5,77	2,21	2,61	5,34	2,06	2,59

▼ AUREA 2 COMPACT 9 / 9TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	12,00	2,50	4,80	12,41	2,53	4,90	12,82	2,56	5,00	13,09	2,59	5,06	13,50	2,55	5,16	14,05	2,65	5,29
	21°C	12,00	2,56	4,69	12,41	2,58	4,80	12,82	2,61	4,91	13,09	2,62	4,99	13,50	2,64	5,11	14,05	2,67	5,26
	22°C	12,00	2,62	4,59	12,41	2,64	4,71	12,82	2,65	4,83	13,09	2,66	4,92	13,50	2,67	5,05	14,05	2,69	5,23
	23°C	12,00	2,68	4,48	12,41	2,69	4,61	12,82	2,70	4,75	13,09	2,70	4,84	13,50	2,71	4,99	14,05	2,70	5,20
	24°C	12,00	2,74	4,37	12,41	2,75	4,52	12,82	2,75	4,67	13,09	2,74	4,77	13,50	2,74	4,93	14,05	2,72	5,17
	25°C	12,00	2,81	4,27	12,41	2,81	4,42	12,82	2,80	4,58	13,09	2,79	4,70	13,50	2,77	4,88	14,05	2,74	5,13
	26°C	12,00	2,88	4,16	12,41	2,87	4,32	12,82	2,85	4,50	13,09	2,83	4,62	13,50	2,80	4,82	14,05	2,75	5,10
	27°C	12,00	2,96	4,05	12,41	2,93	4,23	12,82	2,90	4,42	13,09	2,88	4,55	13,50	2,84	4,76	14,05	2,77	5,07
	28°C	12,00	3,04	3,95	12,41	3,00	4,13	12,82	2,96	4,33	13,09	2,93	4,47	13,50	2,87	4,70	14,05	2,79	5,04
	29°C	12,00	3,13	3,84	12,41	3,07	4,04	12,82	3,02	4,25	13,09	2,97	4,40	13,50	2,91	4,65	14,05	2,81	5,01
	30°C	12,00	3,21	3,73	12,41	3,15	3,94	12,82	3,08	4,17	13,09	3,03	4,33	13,50	2,94	4,59	14,05	2,82	4,97
	31°C	12,00	3,31	3,63	12,41	3,23	3,85	12,82	3,14	4,08	13,09	3,08	4,25	13,50	2,98	4,53	14,05	2,84	4,94
	32°C	12,00	3,41	3,52	12,41	3,31	3,75	12,82	3,20	4,00	13,09	3,13	4,18	13,50	3,02	4,47	14,05	2,86	4,91
	33°C	12,00	3,52	3,41	12,41	3,40	3,65	12,82	3,27	3,92	13,09	3,19	4,11	13,50	3,06	4,42	14,05	2,88	4,88
	34°C	12,00	3,63	3,31	12,41	3,49	3,56	12,82	3,34	3,83	13,09	3,25	4,03	13,50	3,10	4,36	14,05	2,90	4,85
	35°C	12,00	3,75	3,20	12,41	3,58	3,46	12,82	3,42	3,75	13,09	3,31	3,96	13,50	3,14	4,30	14,05	2,92	4,81
	36°C	11,59	3,75	3,09	11,93	3,58	3,33	12,26	3,42	3,59	12,47	3,31	3,77	12,75	3,14	4,06	13,04	2,92	4,47
	37°C	11,20	3,75	2,99	11,49	3,58	3,21	11,75	3,42	3,44	11,90	3,31	3,60	12,08	3,14	3,85	12,17	2,92	4,17
	38°C	10,84	3,75	2,89	11,08	3,58	3,09	11,28	3,42	3,30	11,38	3,31	3,44	11,48	3,14	3,66	11,41	2,92	3,91
	39°C	10,50	3,75	2,80	10,70	3,58	2,99	10,85	3,42	3,17	10,91	3,31	3,30	10,93	3,14	3,48	10,74	2,92	3,68
	40°C	10,18	3,75	2,72	10,34	3,58	2,89	10,44	3,42	3,06	10,47	3,31	3,17	10,43	3,14	3,32	10,14	2,92	3,48
	41°C	9,88	3,75	2,64	10,01	3,58	2,79	10,07	3,42	2,95	10,07	3,31	3,05	9,98	3,14	3,18	9,61	2,92	3,29
	42°C	9,60	3,75	2,56	9,69	3,58	2,71	9,72	3,42	2,85	9,70	3,31	2,93	9,56	3,14	3,05	9,13	2,92	3,13
	43°C	9,33	3,75	2,49	9,40	3,58	2,62	9,40	3,42	2,75	9,35	3,31	2,83	9,18	3,14	2,92	8,69	2,92	2,98
	44°C	9,08	3,75	2,42	9,12	3,58	2,55	9,10	3,42	2,66	9,03	3,31	2,73	8,83	3,14	2,81	8,30	2,92	2,84
	45°C	8,84	3,75	2,36	8,86	3,58	2,47	8,81	3,42	2,58	8,73	3,31	2,64	8,50	3,14	2,71	7,94	2,92	2,72
	46°C	8,62	3,75	2,30	8,62	3,58	2,40	8,55	3,42	2,50	8,45	3,31	2,55	8,20	3,14	2,61	7,61	2,92	2,61

▼ AUREA 2 COMPACT 12 / 12TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	14,00	3,01	4,65	14,41	3,07	4,69	14,82	3,13	4,73	15,09	3,17	4,75	15,50	3,20	4,79	16,05	3,31	4,85
	21°C	14,00	3,08	4,55	14,41	3,13	4,60	14,82	3,19	4,65	15,09	3,22	4,69	15,50	3,27	4,74	16,05	3,33	4,82
	22°C	14,00	3,15	4,44	14,41	3,20	4,51	14,82	3,24	4,57	15,09	3,27	4,62	15,50	3,31	4,69	16,05	3,35	4,79
	23°C	14,00	3,23	4,34	14,41	3,26	4,42	14,82	3,30	4,49	15,09	3,32	4,55	15,50	3,34	4,64	16,05	3,37	4,76
	24°C	14,00	3,30	4,24	14,41	3,33	4,32	14,82	3,36	4,42	15,09	3,37	4,48	15,50	3,38	4,58	16,05	3,39	4,73
	25°C	14,00	3,39	4,13	14,41	3,40	4,23	14,82	3,42	4,34	15,09	3,42	4,41	15,50	3,42	4,53	16,05	3,41	4,70
	26°C	14,00	3,47	4,03	14,41	3,48	4,14	14,82	3,48	4,26	15,09	3,47	4,34	15,50	3,46	4,48	16,05	3,44	4,67
	27°C	14,00	3,57	3,93	14,41	3,56	4,05	14,82	3,54	4,18	15,09	3,53	4,27	15,50	3,50	4,42	16,05	3,46	4,64
	28°C	14,00	3,66	3,82	14,41	3,64	3,96	14,82	3,61	4,10	15,09	3,59	4,21	15,50	3,55	4,37	16,05	3,48	4,61
	29°C	14,00	3,76	3,72	14,41	3,73	3,87	14,82	3,68	4,03	15,09	3,65	4,14	15,50	3,59	4,32	16,05	3,50	4,58
	30°C	14,00	3,87	3,62	14,41	3,82	3,78	14,82	3,75	3,95	15,09	3,71	4,07	15,50	3,63	4,26	16,05	3,52	4,55
	31°C	14,00	3,98	3,51	14,41	3,91	3,68	14,82	3,83	3,87	15,09	3,77	4,00	15,50	3,68	4,21	16,05	3,55	4,52
	32°C	14,00	4,11	3,41	14,41	4,01	3,59	14,82	3,91	3,79	15,09	3,84	3,93	15,50	3,73	4,16	16,05	3,57	4,49
	33°C	14,00	4,23	3,31	14,41	4,11	3,50	14,82	3,99	3,71	15,09	3,91	3,86	15,50	3,78	4,11	16,05	3,59	4,46
	34°C	14,00	4,37	3,20	14,41	4,22	3,41	14,82	4,08	3,63	15,09	3,98	3,79	15,50	3,82	4,05	16,05	3,62	4,44
	35°C	14,00	4,52	3,10	14,41	4,34	3,32	14,82	4,17	3,56	15,09	4,05	3,73	15,50	3,88	4,00	16,05	3,64	4,41
	36°C	13,52	4,52	2,99	13,85	4,34	3,19	14,17	4,17	3,40	14,37	4,05	3,55	14,64	3,88	3,78	14,90	3,64	4,09
	37°C	13,07	4,52	2,89	13,34	4,34	3,07	13,58	4,17	3,26	13,72	4,05	3,39	13,87	3,88	3,58	13,91	3,64	3,82
	38°C	12,64	4,52	2,80	12,87	4,34	2,96	13,04	4,17	3,13	13,12	4,05	3,24	13,18	3,88	3,40	13,04	3,64	3,58
	39°C	12,25	4,52	2,71	12,42	4,34	2,86	12,54	4,17	3,01	12,58	4,05	3,11	12,55	3,88	3,24	12,27	3,64	3,37
	40°C	11,88	4,52	2,63	12,01	4,34	2,77	12,07	4,17	2,90	12,07	4,05	2,98	11,98	3,88	3,09	11,59	3,64	3,18
	41°C	11,53	4,52	2,55	11,62	4,34	2,68	11,64	4,17	2,79	11,61	4,05	2,87	11,46	3,88	2,96	10,98	3,64	3,01
	42°C	11,20	4,52	2,48	11,26	4,34	2,59	11,24	4,17	2,70	11,18	4,05	2,76	10,98	3,88	2,83	10,43	3,64	2,86
	43°C	10,89	4,52	2,41	10,92	4,34	2,51	10,87	4,17	2,61	10,78	4,05	2,66	10,54	3,88	2,72	9,93	3,64	2,73
	44°C	10,59	4,52	2,35	10,59	4,34	2,44	10,52	4,17	2,52	10,41	4,05	2,57	10,13	3,88	2,62	9,48	3,64	2,60
	45°C	10,32	4,52	2,28	10,29	4,34	2,37	10,19	4,17	2,45	10,06	4,05	2,48	9,76	3,88	2,52	9,07	3,64	2,49
	46°C	10,05	4,52	2,23	10,01	4,34	2,30	9,88	4,17	2,37	9,74	4,05	2,40	9,41	3,88	2,43	8,69	3,64	2,39

▼ AUREA 2 & AUREA 2 DHW 3

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	3,43	0,64	5,34	3,57	0,65	5,48	3,71	0,66	5,61	3,80	0,67	5,70	3,94	0,65	5,84	4,12	0,68	6,02
	21°C	3,43	0,66	5,23	3,57	0,66	5,37	3,71	0,67	5,52	3,80	0,68	5,62	3,94	0,68	5,77	4,12	0,69	5,98
	22°C	3,43	0,67	5,11	3,57	0,68	5,26	3,71	0,68	5,43	3,80	0,69	5,54	3,94	0,69	5,71	4,12	0,69	5,94
	23°C	3,43	0,69	4,99	3,57	0,69	5,16	3,71	0,69	5,33	3,80	0,70	5,45	3,94	0,70	5,64	4,12	0,70	5,91
	24°C	3,43	0,70	4,87	3,57	0,71	5,05	3,71	0,71	5,24	3,80	0,71	5,37	3,94	0,71	5,58	4,12	0,70	5,87
	25°C	3,43	0,72	4,75	3,57	0,72	4,94	3,71	0,72	5,15	3,80	0,72	5,29	3,94	0,71	5,51	4,12	0,71	5,83
	26°C	3,43	0,74	4,63	3,57	0,74	4,84	3,71	0,73	5,05	3,80	0,73	5,21	3,94	0,72	5,45	4,12	0,71	5,80
	27°C	3,43	0,76	4,51	3,57	0,75	4,73	3,71	0,75	4,96	3,80	0,74	5,12	3,94	0,73	5,38	4,12	0,71	5,76
	28°C	3,43	0,78	4,39	3,57	0,77	4,62	3,71	0,76	4,87	3,80	0,75	5,04	3,94	0,74	5,32	4,12	0,72	5,72
	29°C	3,43	0,80	4,28	3,57	0,79	4,52	3,71	0,78	4,77	3,80	0,77	4,96	3,94	0,75	5,25	4,12	0,72	5,69
	30°C	3,43	0,83	4,16	3,57	0,81	4,41	3,71	0,79	4,68	3,80	0,78	4,88	3,94	0,76	5,19	4,12	0,73	5,65
	31°C	3,43	0,85	4,04	3,57	0,83	4,30	3,71	0,81	4,59	3,80	0,79	4,79	3,94	0,77	5,12	4,12	0,73	5,61
	32°C	3,43	0,88	3,92	3,57	0,85	4,20	3,71	0,82	4,50	3,80	0,81	4,71	3,94	0,78	5,06	4,12	0,74	5,58
	33°C	3,43	0,90	3,80	3,57	0,87	4,09	3,71	0,84	4,40	3,80	0,82	4,63	3,94	0,79	4,99	4,12	0,74	5,54
	34°C	3,43	0,93	3,68	3,57	0,90	3,98	3,71	0,86	4,31	3,80	0,84	4,55	3,94	0,80	4,93	4,12	0,75	5,51
	35°C	3,43	0,96	3,56	3,57	0,92	3,87	3,71	0,88	4,22	3,80	0,85	4,46	3,94	0,81	4,86	4,12	0,75	5,47
	36°C	3,31	0,96	3,44	3,43	0,92	3,73	3,54	0,88	4,03	3,62	0,85	4,25	3,72	0,81	4,59	3,82	0,75	5,08
	37°C	3,20	0,96	3,33	3,30	0,92	3,59	3,40	0,88	3,86	3,45	0,85	4,06	3,52	0,81	4,35	3,57	0,75	4,74
	38°C	3,10	0,96	3,22	3,19	0,92	3,46	3,26	0,88	3,71	3,30	0,85	3,88	3,34	0,81	4,13	3,35	0,75	4,44
	39°C	3,00	0,96	3,12	3,08	0,92	3,34	3,14	0,88	3,57	3,16	0,85	3,72	3,19	0,81	3,94	3,15	0,75	4,18
	40°C	2,91	0,96	3,02	2,97	0,92	3,23	3,02	0,88	3,44	3,04	0,85	3,57	3,04	0,81	3,76	2,97	0,75	3,95
	41°C	2,82	0,96	2,93	2,88	0,92	3,12	2,91	0,88	3,31	2,92	0,85	3,43	2,91	0,81	3,60	2,82	0,75	3,74
	42°C	2,74	0,96	2,85	2,79	0,92	3,03	2,81	0,88	3,20	2,81	0,85	3,31	2,79	0,81	3,45	2,68	0,75	3,55
	43°C	2,67	0,96	2,77	2,70	0,92	2,94	2,72	0,88	3,09	2,71	0,85	3,19	2,68	0,81	3,31	2,55	0,75	3,39
	44°C	2,60	0,96	2,70	2,62	0,92	2,85	2,63	0,88	2,99	2,62	0,85	3,08	2,57	0,81	3,18	2,43	0,75	3,23
	45°C	2,53	0,96	2,63	2,55	0,92	2,77	2,55	0,88	2,90	2,53	0,85	2,98	2,48	0,81	3,06	2,33	0,75	3,09
	46°C	2,46	0,96	2,56	2,48	0,92	2,69	2,47	0,88	2,81	2,45	0,85	2,88	2,39	0,81	2,95	2,23	0,75	2,96

▼ AUREA 2 & AUREA 2 DHW 4

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	4,94	0,93	5,33	5,21	0,95	5,47	5,49	0,98	5,60	5,68	1,00	5,69	5,96	0,99	5,82	6,33	1,05	6,00
	21°C	4,94	0,95	5,21	5,21	0,97	5,36	5,49	1,00	5,51	5,68	1,01	5,61	5,96	1,03	5,76	6,33	1,06	5,97
	22°C	4,94	0,97	5,10	5,21	0,99	5,26	5,49	1,01	5,42	5,68	1,03	5,53	5,96	1,05	5,70	6,33	1,07	5,93
	23°C	4,94	0,99	4,98	5,21	1,01	5,15	5,49	1,03	5,33	5,68	1,04	5,45	5,96	1,06	5,64	6,33	1,07	5,89
	24°C	4,94	1,02	4,86	5,21	1,03	5,05	5,49	1,05	5,24	5,68	1,06	5,37	5,96	1,07	5,57	6,33	1,08	5,86
	25°C	4,94	1,04	4,74	5,21	1,06	4,94	5,49	1,07	5,15	5,68	1,07	5,29	5,96	1,08	5,51	6,33	1,09	5,82
	26°C	4,94	1,07	4,62	5,21	1,08	4,83	5,49	1,09	5,06	5,68	1,09	5,21	5,96	1,09	5,45	6,33	1,09	5,79
	27°C	4,94	1,10	4,50	5,21	1,10	4,73	5,49	1,11	4,96	5,68	1,11	5,13	5,96	1,11	5,38	6,33	1,10	5,75
	28°C	4,94	1,13	4,39	5,21	1,13	4,62	5,49	1,13	4,87	5,68	1,13	5,05	5,96	1,12	5,32	6,33	1,11	5,71
	29°C	4,94	1,16	4,27	5,21	1,15	4,52	5,49	1,15	4,78	5,68	1,14	4,97	5,96	1,13	5,26	6,33	1,12	5,68
	30°C	4,94	1,19	4,15	5,21	1,18	4,41	5,49	1,17	4,69	5,68	1,16	4,89	5,96	1,15	5,20	6,33	1,12	5,64
	31°C	4,94	1,22	4,03	5,21	1,21	4,31	5,49	1,19	4,60	5,68	1,18	4,81	5,96	1,16	5,13	6,33	1,13	5,60
	32°C	4,94	1,26	3,91	5,21	1,24	4,20	5,49	1,22	4,51	5,68	1,20	4,73	5,96	1,18	5,07	6,33	1,14	5,57
	33°C	4,94	1,30	3,79	5,21	1,27	4,10	5,49	1,24	4,42	5,68	1,22	4,65	5,96	1,19	5,01	6,33	1,15	5,53
	34°C	4,94	1,34	3,67	5,21	1,31	3,99	5,49	1,27	4,33	5,68	1,24	4,57	5,96	1,21	4,94	6,33	1,15	5,49
	35°C	4,94	1,39	3,56	5,21	1,34	3,88	5,49	1,30	4,24	5,68	1,27	4,48	5,96	1,22	4,88	6,33	1,16	5,46
	36°C	4,76	1,39	3,43	5,01	1,34	3,73	5,26	1,30	4,05	5,41	1,27	4,27	5,63	1,22	4,61	5,88	1,16	5,07
	37°C	4,61	1,39	3,32	4,83	1,34	3,60	5,04	1,30	3,88	5,16	1,27	4,08	5,33	1,22	4,37	5,49	1,16	4,73
	38°C	4,46	1,39	3,21	4,66	1,34	3,47	4,83	1,30	3,73	4,94	1,27	3,90	5,07	1,22	4,15	5,15	1,16	4,43
	39°C	4,32	1,39	3,11	4,50	1,34	3,35	4,65	1,30	3,58	4,73	1,27	3,74	4,82	1,22	3,95	4,84	1,16	4,17
	40°C	4,19	1,39	3,02	4,35	1,34	3,24	4,48	1,30	3,45	4,54	1,27	3,59	4,61	1,22	3,77	4,57	1,16	3,94
	41°C	4,06	1,39	2,93	4,21	1,34	3,13	4,32	1,30	3,33	4,37	1,27	3,45	4,41	1,22	3,61	4,33	1,16	3,73
	42°C	3,95	1,39	2,84	4,07	1,34	3,03	4,17	1,30	3,21	4,21	1,27	3,32	4,22	1,22	3,46	4,12	1,16	3,55
	43°C	3,84	1,39	2,77	3,95	1,34	2,94	4,03	1,30	3,11	4,06	1,27	3,20	4,05	1,22	3,32	3,92	1,16	3,38
	44°C	3,73	1,39	2,69	3,83	1,34	2,86	3,90	1,30	3,01	3,92	1,27	3,09	3,90	1,22	3,19	3,74	1,16	3,23
	45°C	3,64	1,39	2,62	3,72	1,34	2,77	3,78	1,30	2,91	3,79	1,27	2,99	3,75	1,22	3,07	3,58	1,16	3,08
	46°C	3,54	1,39	2,55	3,62	1,34	2,70	3,66	1,30	2,82	3,66	1,27	2,89	3,62	1,22	2,96	3,43	1,16	2,96

▼ AUREA 2 & AUREA 2 DHW 5

	Starting temperature																		
	7°C			10°C			13°C			15°C			18°C			22°C			
	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	
Outdoor temperature	20°C	6,73	1,33	5,06	6,93	1,45	4,79	7,13	1,58	4,51	7,27	1,68	4,33	7,47	2,02	4,06	7,74	2,10	3,69
	21°C	6,73	1,36	4,95	6,93	1,48	4,69	7,13	1,61	4,44	7,27	1,70	4,27	7,47	1,86	4,01	7,74	2,11	3,67
	22°C	6,73	1,39	4,84	6,93	1,51	4,60	7,13	1,64	4,36	7,27	1,73	4,20	7,47	1,88	3,96	7,74	2,12	3,65
	23°C	6,73	1,42	4,73	6,93	1,54	4,50	7,13	1,67	4,28	7,27	1,76	4,14	7,47	1,91	3,92	7,74	2,14	3,62
	24°C	6,73	1,46	4,61	6,93	1,57	4,41	7,13	1,70	4,21	7,27	1,78	4,07	7,47	1,93	3,87	7,74	2,15	3,60
	25°C	6,73	1,50	4,50	6,93	1,61	4,32	7,13	1,73	4,13	7,27	1,81	4,01	7,47	1,95	3,82	7,74	2,16	3,58
	26°C	6,73	1,53	4,39	6,93	1,64	4,22	7,13	1,76	4,05	7,27	1,84	3,94	7,47	1,98	3,78	7,74	2,18	3,56
	27°C	6,73	1,57	4,28	6,93	1,68	4,13	7,13	1,79	3,98	7,27	1,87	3,88	7,47	2,00	3,73	7,74	2,19	3,53
	28°C	6,73	1,62	4,16	6,93	1,72	4,03	7,13	1,83	3,90	7,27	1,91	3,81	7,47	2,03	3,68	7,74	2,20	3,51
	29°C	6,73	1,66	4,05	6,93	1,76	3,94	7,13	1,86	3,83	7,27	1,94	3,75	7,47	2,05	3,64	7,74	2,22	3,49
	30°C	6,73	1,71	3,94	6,93	1,80	3,84	7,13	1,90	3,75	7,27	1,97	3,69	7,47	2,08	3,59	7,74	2,23	3,47
	31°C	6,73	1,76	3,83	6,93	1,85	3,75	7,13	1,94	3,67	7,27	2,01	3,62	7,47	2,11	3,55	7,74	2,25	3,44
	32°C	6,73	1,81	3,71	6,93	1,90	3,65	7,13	1,98	3,60	7,27	2,04	3,56	7,47	2,13	3,50	7,74	2,26	3,42
	33°C	6,73	1,87	3,60	6,93	1,95	3,56	7,13	2,03	3,52	7,27	2,08	3,49	7,47	2,16	3,45	7,74	2,28	3,40
	34°C	6,73	1,93	3,49	6,93	2,00	3,47	7,13	2,07	3,44	7,27	2,12	3,43	7,47	2,19	3,41	7,74	2,29	3,38
	35°C	6,73	1,99	3,38	6,93	2,06	3,37	7,13	2,12	3,37	7,27	2,16	3,36	7,47	2,22	3,36	7,74	2,31	3,35
	36°C	6,50	1,99	3,26	6,67	2,06	3,24	6,82	2,12	3,22	6,92	2,16	3,20	7,06	2,22	3,17	7,19	2,31	3,12
	37°C	6,28	1,99	3,15	6,42	2,06	3,12	6,54	2,12	3,09	6,61	2,16	3,06	6,68	2,22	3,01	6,71	2,31	2,91
	38°C	6,08	1,99	3,05	6,19	2,06	3,01	6,28	2,12	2,96	6,32	2,16	2,92	6,35	2,22	2,86	6,29	2,31	2,73
	39°C	5,89	1,99	2,95	5,98	2,06	2,91	6,04	2,12	2,85	6,06	2,16	2,80	6,05	2,22	2,72	5,92	2,31	2,57
40°C	5,71	1,99	2,86	5,78	2,06	2,81	5,81	2,12	2,74	5,81	2,16	2,69	5,77	2,22	2,60	5,59	2,31	2,42	
41°C	5,54	1,99	2,78	5,59	2,06	2,72	5,61	2,12	2,64	5,59	2,16	2,59	5,52	2,22	2,48	5,30	2,31	2,30	
42°C	5,38	1,99	2,70	5,42	2,06	2,63	5,41	2,12	2,55	5,38	2,16	2,49	5,29	2,22	2,38	5,03	2,31	2,18	
43°C	5,23	1,99	2,63	5,25	2,06	2,55	5,23	2,12	2,47	5,19	2,16	2,40	5,08	2,22	2,28	4,79	2,31	2,08	
44°C	5,09	1,99	2,55	5,10	2,06	2,48	5,06	2,12	2,39	5,01	2,16	2,32	4,88	2,22	2,20	4,57	2,31	1,98	
45°C	4,96	1,99	2,49	4,95	2,06	2,41	4,90	2,12	2,31	4,85	2,16	2,24	4,70	2,22	2,12	4,37	2,31	1,90	
46°C	4,83	1,99	2,42	4,81	2,06	2,34	4,76	2,12	2,24	4,69	2,16	2,17	4,54	2,22	2,04	4,19	2,31	1,82	

▼ AUREA 2 & AUREA 2 DHW 7 / 7TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	8,43	1,76	4,78	8,71	1,80	4,85	8,98	1,83	4,92	9,17	1,85	4,97	9,45	1,84	5,04	9,81	1,91	5,14
	21°C	8,43	1,80	4,67	8,71	1,83	4,75	8,98	1,86	4,84	9,17	1,87	4,90	9,45	1,89	4,99	9,81	1,92	5,11
	22°C	8,43	1,85	4,56	8,71	1,87	4,66	8,98	1,89	4,76	9,17	1,90	4,83	9,45	1,92	4,93	9,81	1,93	5,07
	23°C	8,43	1,89	4,46	8,71	1,91	4,57	8,98	1,92	4,68	9,17	1,93	4,75	9,45	1,94	4,87	9,81	1,95	5,04
	24°C	8,43	1,94	4,35	8,71	1,95	4,47	8,98	1,96	4,60	9,17	1,96	4,68	9,45	1,96	4,82	9,81	1,96	5,01
	25°C	8,43	1,99	4,25	8,71	1,99	4,38	8,98	1,99	4,51	9,17	1,99	4,61	9,45	1,98	4,76	9,81	1,97	4,98
	26°C	8,43	2,04	4,14	8,71	2,03	4,28	8,98	2,03	4,43	9,17	2,02	4,54	9,45	2,01	4,71	9,81	1,98	4,95
	27°C	8,43	2,09	4,03	8,71	2,08	4,19	8,98	2,06	4,35	9,17	2,05	4,47	9,45	2,03	4,65	9,81	2,00	4,92
	28°C	8,43	2,15	3,93	8,71	2,13	4,09	8,98	2,10	4,27	9,17	2,09	4,39	9,45	2,06	4,59	9,81	2,01	4,89
	29°C	8,43	2,21	3,82	8,71	2,18	4,00	8,98	2,15	4,19	9,17	2,12	4,32	9,45	2,08	4,54	9,81	2,02	4,86
	30°C	8,43	2,27	3,72	8,71	2,23	3,90	8,98	2,19	4,11	9,17	2,16	4,25	9,45	2,11	4,48	9,81	2,03	4,83
	31°C	8,43	2,34	3,61	8,71	2,29	3,81	8,98	2,23	4,02	9,17	2,19	4,18	9,45	2,13	4,43	9,81	2,05	4,79
	32°C	8,43	2,41	3,50	8,71	2,34	3,71	8,98	2,28	3,94	9,17	2,23	4,11	9,45	2,16	4,37	9,81	2,06	4,76
	33°C	8,43	2,48	3,40	8,71	2,41	3,62	8,98	2,33	3,86	9,17	2,27	4,03	9,45	2,19	4,32	9,81	2,07	4,73
	34°C	8,43	2,56	3,29	8,71	2,47	3,53	8,98	2,38	3,78	9,17	2,31	3,96	9,45	2,22	4,26	9,81	2,09	4,70
	35°C	8,43	2,65	3,18	8,71	2,54	3,43	8,98	2,43	3,70	9,17	2,36	3,89	9,45	2,25	4,20	9,81	2,10	4,67
	36°C	8,14	2,65	3,07	8,37	2,54	3,30	8,59	2,43	3,54	8,73	2,36	3,71	8,92	2,25	3,97	9,11	2,10	4,34
	37°C	7,87	2,65	2,97	8,06	2,54	3,18	8,24	2,43	3,39	8,33	2,36	3,54	8,45	2,25	3,76	8,51	2,10	4,05
	38°C	7,61	2,65	2,88	7,77	2,54	3,06	7,91	2,43	3,25	7,97	2,36	3,38	8,03	2,25	3,57	7,97	2,10	3,79
	39°C	7,38	2,65	2,79	7,51	2,54	2,96	7,60	2,43	3,13	7,64	2,36	3,24	7,65	2,25	3,40	7,50	2,10	3,57
	40°C	7,15	2,65	2,70	7,26	2,54	2,86	7,32	2,43	3,01	7,33	2,36	3,11	7,30	2,25	3,25	7,09	2,10	3,37
	41°C	6,94	2,65	2,62	7,02	2,54	2,77	7,06	2,43	2,91	7,05	2,36	2,99	6,98	2,25	3,11	6,71	2,10	3,20
	42°C	6,74	2,65	2,55	6,80	2,54	2,68	6,82	2,43	2,81	6,79	2,36	2,88	6,69	2,25	2,98	6,38	2,10	3,04
	43°C	6,56	2,65	2,48	6,60	2,54	2,60	6,59	2,43	2,71	6,55	2,36	2,78	6,42	2,25	2,86	6,08	2,10	2,89
	44°C	6,38	2,65	2,41	6,40	2,54	2,52	6,38	2,43	2,62	6,32	2,36	2,68	6,18	2,25	2,75	5,80	2,10	2,76
	45°C	6,21	2,65	2,35	6,22	2,54	2,45	6,18	2,43	2,54	6,11	2,36	2,59	5,95	2,25	2,65	5,55	2,10	2,64
	46°C	6,05	2,65	2,29	6,05	2,54	2,38	5,99	2,43	2,47	5,91	2,36	2,51	5,73	2,25	2,55	5,32	2,10	2,53

▼ AUREA 2 & AUREA 2 DHW 9 / 9TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	11,93	2,54	4,70	12,35	2,73	4,53	12,77	2,93	4,36	13,05	3,07	4,25	13,47	3,49	4,08	14,02	3,64	3,85
	21°C	11,93	2,60	4,59	12,35	2,78	4,44	12,77	2,98	4,29	13,05	3,12	4,19	13,47	3,34	4,03	14,02	3,66	3,83
	22°C	11,93	2,66	4,49	12,35	2,84	4,35	12,77	3,03	4,22	13,05	3,16	4,12	13,47	3,38	3,99	14,02	3,68	3,81
	23°C	11,93	2,72	4,38	12,35	2,90	4,26	12,77	3,08	4,14	13,05	3,21	4,06	13,47	3,41	3,94	14,02	3,71	3,78
	24°C	11,93	2,79	4,28	12,35	2,96	4,18	12,77	3,14	4,07	13,05	3,26	4,00	13,47	3,45	3,90	14,02	3,73	3,76
	25°C	11,93	2,86	4,17	12,35	3,02	4,09	12,77	3,19	4,00	13,05	3,31	3,94	13,47	3,49	3,85	14,02	3,75	3,74
	26°C	11,93	2,93	4,07	12,35	3,09	4,00	12,77	3,25	3,93	13,05	3,36	3,88	13,47	3,53	3,81	14,02	3,78	3,71
	27°C	11,93	3,01	3,96	12,35	3,16	3,91	12,77	3,31	3,86	13,05	3,41	3,82	13,47	3,58	3,76	14,02	3,80	3,69
	28°C	11,93	3,09	3,86	12,35	3,23	3,82	12,77	3,37	3,79	13,05	3,47	3,76	13,47	3,62	3,72	14,02	3,83	3,67
	29°C	11,93	3,18	3,76	12,35	3,31	3,74	12,77	3,44	3,71	13,05	3,53	3,70	13,47	3,66	3,68	14,02	3,85	3,64
	30°C	11,93	3,27	3,65	12,35	3,38	3,65	12,77	3,51	3,64	13,05	3,59	3,64	13,47	3,71	3,63	14,02	3,87	3,62
	31°C	11,93	3,36	3,55	12,35	3,47	3,56	12,77	3,58	3,57	13,05	3,65	3,58	13,47	3,75	3,59	14,02	3,90	3,60
	32°C	11,93	3,46	3,44	12,35	3,56	3,47	12,77	3,65	3,50	13,05	3,71	3,52	13,47	3,80	3,54	14,02	3,93	3,57
	33°C	11,93	3,57	3,34	12,35	3,65	3,38	12,77	3,72	3,43	13,05	3,78	3,46	13,47	3,85	3,50	14,02	3,95	3,55
	34°C	11,93	3,69	3,23	12,35	3,75	3,30	12,77	3,80	3,36	13,05	3,84	3,39	13,47	3,90	3,45	14,02	3,98	3,53
	35°C	11,93	3,81	3,13	12,35	3,85	3,21	12,77	3,89	3,28	13,05	3,91	3,33	13,47	3,95	3,41	14,02	4,00	3,50
	36°C	11,51	3,81	3,02	11,87	3,85	3,08	12,21	3,89	3,14	12,42	3,91	3,17	12,72	3,95	3,22	13,02	4,00	3,25
	37°C	11,13	3,81	2,92	11,43	3,85	2,97	11,70	3,89	3,01	11,86	3,91	3,03	12,05	3,95	3,05	12,15	4,00	3,04
	38°C	10,77	3,81	2,83	11,02	3,85	2,86	11,23	3,89	2,89	11,34	3,91	2,90	11,45	3,95	2,90	11,40	4,00	2,85
	39°C	10,44	3,81	2,74	10,64	3,85	2,77	10,80	3,89	2,78	10,87	3,91	2,78	10,90	3,95	2,76	10,72	4,00	2,68
	40°C	10,12	3,81	2,66	10,29	3,85	2,67	10,40	3,89	2,68	10,44	3,91	2,67	10,40	3,95	2,63	10,13	4,00	2,53
	41°C	9,82	3,81	2,58	9,96	3,85	2,59	10,03	3,89	2,58	10,03	3,91	2,56	9,95	3,95	2,52	9,60	4,00	2,40
	42°C	9,54	3,81	2,50	9,65	3,85	2,51	9,68	3,89	2,49	9,66	3,91	2,47	9,54	3,95	2,41	9,12	4,00	2,28
	43°C	9,28	3,81	2,43	9,35	3,85	2,43	9,36	3,89	2,41	9,32	3,91	2,38	9,16	3,95	2,32	8,68	4,00	2,17
	44°C	9,03	3,81	2,37	9,08	3,85	2,36	9,06	3,89	2,33	9,00	3,91	2,30	8,80	3,95	2,23	8,29	4,00	2,07
	45°C	8,79	3,81	2,31	8,82	3,85	2,29	8,78	3,89	2,26	8,70	3,91	2,22	8,48	3,95	2,15	7,93	4,00	1,98
	46°C	8,56	3,81	2,25	8,57	3,85	2,23	8,51	3,89	2,19	8,42	3,91	2,15	8,18	3,95	2,07	7,60	4,00	1,90


▼ AUREA 2 & AUREA 2 DHW 12 / 12TRI

		Starting temperature																	
		7°C			10°C			13°C			15°C			18°C			22°C		
		Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER	Pfroid	Pabs	EER
Outdoor temperature	20°C	13,92	3,07	4,54	14,34	3,14	4,57	14,76	3,21	4,60	15,04	3,25	4,62	15,47	3,29	4,66	16,03	3,41	4,70
	21°C	13,92	3,14	4,44	14,34	3,20	4,48	14,76	3,26	4,53	15,04	3,30	4,56	15,47	3,36	4,61	16,03	3,43	4,67
	22°C	13,92	3,21	4,34	14,34	3,26	4,39	14,76	3,32	4,45	15,04	3,35	4,49	15,47	3,40	4,55	16,03	3,45	4,64
	23°C	13,92	3,29	4,24	14,34	3,33	4,31	14,76	3,37	4,38	15,04	3,40	4,43	15,47	3,43	4,50	16,03	3,47	4,61
	24°C	13,92	3,37	4,14	14,34	3,40	4,22	14,76	3,43	4,30	15,04	3,45	4,36	15,47	3,47	4,45	16,03	3,50	4,58
	25°C	13,92	3,45	4,04	14,34	3,47	4,13	14,76	3,49	4,22	15,04	3,50	4,29	15,47	3,51	4,40	16,03	3,52	4,56
	26°C	13,92	3,54	3,94	14,34	3,55	4,04	14,76	3,56	4,15	15,04	3,56	4,23	15,47	3,56	4,35	16,03	3,54	4,53
	27°C	13,92	3,63	3,83	14,34	3,63	3,95	14,76	3,63	4,07	15,04	3,62	4,16	15,47	3,60	4,30	16,03	3,56	4,50
	28°C	13,92	3,73	3,73	14,34	3,72	3,86	14,76	3,69	4,00	15,04	3,68	4,09	15,47	3,64	4,25	16,03	3,58	4,47
	29°C	13,92	3,83	3,63	14,34	3,80	3,77	14,76	3,77	3,92	15,04	3,74	4,03	15,47	3,69	4,20	16,03	3,61	4,44
	30°C	13,92	3,94	3,53	14,34	3,89	3,68	14,76	3,84	3,84	15,04	3,80	3,96	15,47	3,73	4,14	16,03	3,63	4,41
	31°C	13,92	4,06	3,43	14,34	3,99	3,59	14,76	3,92	3,77	15,04	3,86	3,89	15,47	3,78	4,09	16,03	3,65	4,38
	32°C	13,92	4,18	3,33	14,34	4,09	3,50	14,76	4,00	3,69	15,04	3,93	3,83	15,47	3,83	4,04	16,03	3,68	4,36
	33°C	13,92	4,31	3,23	14,34	4,20	3,42	14,76	4,08	3,62	15,04	4,00	3,76	15,47	3,88	3,99	16,03	3,70	4,33
	34°C	13,92	4,45	3,13	14,34	4,31	3,33	14,76	4,17	3,54	15,04	4,07	3,69	15,47	3,93	3,94	16,03	3,73	4,30
	35°C	13,92	4,60	3,03	14,34	4,43	3,24	14,76	4,26	3,47	15,04	4,15	3,63	15,47	3,98	3,89	16,03	3,75	4,27
	36°C	13,44	4,60	2,92	13,79	4,43	3,11	14,12	4,26	3,31	14,33	4,15	3,45	14,61	3,98	3,67	14,88	3,75	3,97
	37°C	12,99	4,60	2,83	13,28	4,43	3,00	13,53	4,26	3,18	13,68	4,15	3,30	13,84	3,98	3,48	13,89	3,75	3,70
	38°C	12,58	4,60	2,73	12,81	4,43	2,89	12,99	4,26	3,05	13,08	4,15	3,15	13,15	3,98	3,30	13,02	3,75	3,47
	39°C	12,18	4,60	2,65	12,37	4,43	2,79	12,49	4,26	2,93	12,54	4,15	3,02	12,52	3,98	3,15	12,25	3,75	3,27
	40°C	11,81	4,60	2,57	11,95	4,43	2,70	12,03	4,26	2,82	12,04	4,15	2,90	11,95	3,98	3,00	11,57	3,75	3,08
	41°C	11,47	4,60	2,49	11,57	4,43	2,61	11,60	4,26	2,72	11,57	4,15	2,79	11,43	3,98	2,87	10,96	3,75	2,92
	42°C	11,14	4,60	2,42	11,21	4,43	2,53	11,20	4,26	2,63	11,14	4,15	2,69	10,95	3,98	2,75	10,42	3,75	2,78
	43°C	10,83	4,60	2,35	10,87	4,43	2,45	10,83	4,26	2,54	10,75	4,15	2,59	10,52	3,98	2,64	9,92	3,75	2,64
	44°C	10,54	4,60	2,29	10,55	4,43	2,38	10,48	4,26	2,46	10,38	4,15	2,50	10,11	3,98	2,54	9,47	3,75	2,52
	45°C	10,26	4,60	2,23	10,25	4,43	2,31	10,15	4,26	2,38	10,03	4,15	2,42	9,74	3,98	2,45	9,06	3,75	2,41
	46°C	10,00	4,60	2,17	9,96	4,43	2,25	9,84	4,26	2,31	9,71	4,15	2,34	9,39	3,98	2,36	8,68	3,75	2,31

Sound power - Outdoor unit


AUREA 2-3	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	42	52	54	50	46	47	36	
								58

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1




AUREA 2-4	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	43	53	55	51	47	48	37	
								59

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1




AUREA 2-5	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	48	61	55	55	51	47	39	63

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1




AUREA 2-7	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	58	57	57	56	52	54	46	
								64

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1




AUREA 2-9	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	56	58	61	62	60	49	40	67

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1



AUREA 2-12	Sound power level in octave bands dB(A)							Overall sound power level dB(A) *
	A7W55 standard rating condition according to EN 14511-2							
	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	
	61	60	61	60	56	50	44	67

* The overall sound power level is calculated on octave bands [125 Hz ; 8000 Hz] according to NF EN 12102-1






A series of horizontal dotted lines spanning the width of the page, providing a guide for handwriting practice.


Hydraulic circuit

► Outdoor unit available hydronic pressures and flow rates


■ OU AUREA 2-3 / 2-4 / 2-5




■ OU AUREA 2-7 / 2-9 / 2-12 (TRI)




■ Hydraulic unit AUREA 2



■ Hydraulic unit AUREA 2 DHW



■ Compact - 1 heating circuit




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter

- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger
- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup

- 52 - Decoupling bottle
- 54 - Manometer
- 56 - No-return valve
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 200 - Direct heating circuit kit
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor

- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)

■ Compact - 1 heating circuit + Domestic hot water



- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 51 - Expansion vessel
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valve


- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 149 - DHW kit
- 150 - Disconnector
- 151 - Safety group
- 152 - Thermostatic mixing valve
- 200 - Direct heating circuit kit
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)

- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety

- 90 -



■ Compact - Decoupling bottle 1 heating circuit + Domestic hot water




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valve

- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 149 - DHW kit
- 150 - Disconnector
- 151 - Safety group
- 152 - Thermostatic mixing valve
- 200 - Direct heating circuit kit
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor

- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety

■ Compact - Decoupling bottle 2 heating circuits




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 15 - Heat exchanger (Condensor)
- 16 - Connection

- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 54 - Manometer
- 56 - Non return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver

- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 105 - Room thermostat
- 200 - Direct heating circuit kit
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)

- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 2 heating circuits + Domestic hot water




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 14 - Pressure relief valve (PRV)
- 15 - Heat exchanger (Condensor)
- 16 - Connection

- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 53 - Directional valve
- 54 - Manometer
- 56 - Non return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver

- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 105 - Room thermostat
- 149 - DHW kit
- 150 - Shut-off
- 151 - Safety valve
- 152 - Thermostatic mixer valve
- 200 - Direct heating circuit kit
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor

- (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor
- (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 3 heating circuits




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 15 - Heat exchanger (Condensor)
- 16 - Connection


- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 54 - Manometer
- 56 - Non return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver

- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 105 - Room thermostat
- 200 - Direct heating circuit kit
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 3 heating circuits + Domestic hot water




■ Compact - 1 heating circuit + Boiler connection



- | | | |
|----------------------------------|---|---|
| 1 - Compressor | 77 - Receiver | 511 - Outdoor temp. thermistor |
| 2 - Accumulator | 100 - Radiator | 520 - Return temp. sensor (heating circuit) |
| 3 - 4-way valve | 101 - Heating floor | 521 - Flow temp. sensor (heating circuit) |
| 4 - Heat exchanger (Evaporator) | 102 - Dynamic radiator (fan-convector) | |
| 5 - 3-way valve | 105 - Room thermostat | |
| 6 - Expansion valve | 230 - Boiler relief | |
| 7 - Filter | 231 - Boiler thermostat | |
| 8 - Pressure switch (On/Off) | 501 - Compressor temp. sensor | |
| 10 - Valve | 502 - Discharge temp. thermistor | |
| 11 - Bleeder valve | 503 - Input temp. sensor (Expansion valve) | |
| 12 - Circulating pump | 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger) | |
| 13 - Flowmeter | 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger) | |
| 14 - Pressure relief valve (PRV) | 507 - Flow temp. Thermistor (hydronic heatexchanger) | |
| 15 - Heat exchanger (Condensor) | | |

■ Compact - 1 heating circuit + Boiler connection + Domestic hot water




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 14 - Pressure relief valve (PRV)
- 15 - Heat exchanger (Condensor)

- 16 - Connection
- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 53 - Directional valve
- 54 - Manometer
- 56 - Non return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)

- 77 - Receiver
- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 149 - Room thermostat
- 150 - DHW kit
- 150 - Shut-off
- 151 - Safety valve
- 152 - Thermostatic mixer valve
- 230 - Boiler relief
- 231 - Boiler thermostat
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)

- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety

■ Compact - Decoupling bottle 1 heating circuit + Boiler connection




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Drain valve
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valver

- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 200 - Direct heating circuit kit
- 230 - Boiler relief
- 231 - Boiler thermostat
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)

- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)

■ Compact - Decoupling bottle 1 heating circuit + Domestic hot water + Boiler connection




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valve

- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 149 - DHW kit
- 150 - Disconnector
- 151 - Safety group
- 152 - Thermostatic mixing valve
- 200 - Direct heating circuit kit
- 230 - Boiler relief
- 231 - Boiler thermostat

- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydraulic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety

■ Compact - Decoupling bottle 2 heating circuits + Boiler connection




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valver

- 57 - Decoupling bottle
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 200 - Direct heating circuit kit
- 230 - Boiler relief
- 231 - Boiler thermostat
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor

- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 2 heating circuits + Domestic hot water + Boiler connection




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger
- 16 - Connection

- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)

- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 149 - DHW kit
- 150 - Disconnect
- 151 - Safety group
- 152 - Thermostatic mixing valve
- 200 - Direct heating circuit kit
- 230 - Boiler relief
- 231 - Boiler thermostat
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor

- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 3 heating circuits + Boiler connection




1 - Compressor
2 - Accumulator
3 - 4-way valve
4 - Heat exchanger (Evaporator)
5 - 3-way valve
6 - Expansion valve
7 - Filter
8 - Pressure switch (On/Off)
10 - Valve
11 - Drain valve
12 - System pump
13 - Flowmeter
14 - Safety valve
15 - Refrigerant to Water Heat Exchanger

16 - Connection
17 - Frost protection valve
18 - Sludge pot (decanter)
30 - Outdoor unit
33 - Control Box
35 - Refrigerant unit
40 - Degasser
46 - Pressure sensor (high)
50 - Expansion vessel
51 - Electrical backup
52 - Decoupling bottle
53 - Directional valve
54 - Manometer
56 - No-return valver

57 - Decoupling bottle
72 - Pressure sensor (low)
77 - Receiver
100 - Radiator
101 - Underfloor heating system
102 - Dynamic radiator (fan-convector)
105 - Thermostat or room sensor
200 - Direct heating circuit kit
230 - Boiler relief
231 - Boiler thermostat
251 - Mixed heating circuit kit
252 - Mixing valve
501 - Compressor temp. sensor
502 - Discharge temp. thermistor

503 - Input temp. sensor (Expansion valve)
504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
507 - Flow temp. Thermistor (hydronic heat exchanger)
511 - Outdoor temp. thermistor
520 - Return temp. sensor (heating circuit)
521 - Flow temp. sensor (heating circuit)
540 - Flow temp. sensor (Mixed heating circuit)

■ Compact - Decoupling bottle 3 heating circuits + Domestic hot water + Boiler connection




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Drain valve
- 12 - System pump
- 13 - Flowmeter
- 14 - Safety valve
- 15 - Refrigerant to Water Heat Exchanger
- 16 - Connection

- 17 - Frost protection valve
- 18 - Sludge pot (decanter)
- 30 - Outdoor unit
- 33 - Control Box
- 35 - Refrigerant unit
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 51 - Electrical backup
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - No-return valve
- 57 - Decoupling bottle
- 72 - Pressure sensor (low)

- 77 - Receiver
- 100 - Radiator
- 101 - Underfloor heating system
- 102 - Dynamic radiator (fan-convector)
- 105 - Thermostat or room sensor
- 149 - DHW kit
- 150 - Disconnect
- 151 - Safety group
- 152 - Thermostatic mixing valve
- 200 - Direct heating circuit kit
- 230 - Boiler relief
- 231 - Boiler thermostat
- 251 - Mixed heating circuit kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor


- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Hydraulic unit 1S - 1 heating circuit



- | | | |
|---|--|--|
| 1 - Compressor | 77 - Receiver | 520 - Return temp. sensor (heating circuit) |
| 2 - Accumulator | 100 - Radiator | 521 - Flow temp. sensor (heating circuit) |
| 3 - 4-way valve | 101 - Heating floor | |
| 4 - Heat exchanger (Evaporator) | 102 - Dynamic radiator (fan-convector) | |
| 5 - 3-way valve | 105 - Room thermostat | |
| 6 - Expansion valve | 210 - Buffer tank | |
| 7 - Filter | 501 - Compressor temp. sensor | |
| 8 - Pressure switch (On/Off) | 502 - Discharge temp. thermistor | |
| 10 - Valve | 503 - Input temp. sensor (Expansion valve) | |
| 11 - Bleeder valve | 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger) | |
| 12 - Circulating pump | 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger) | |
| 13 - Flowmeter | 507 - Flow temp. Thermistor (hydronic heat exchanger) | |
| 14 - Pressure relief valve (PRV) | 511 - Outdoor temp. thermistor | |
| 15 - Refrigerant to Water Heat Exchanger | | |
| 16 - Connection | | |
| 17 - Antifreeze valve | | |
| 18 - Sediment trap | | |
| 30 - Outdoor unit | | |
| 31 - Hydronic unit 1 service | | |
| 40 - Degasser | | |
| 46 - Pressure sensor (high) | | |
| 50 - Expansion vessel | | |
| 52 - Decoupling bottle | | |
| 53 - Directional valve | | |
| 54 - Manometer | | |
| 56 - Non return valve | | |
| 60 - HP Electrical backup | | |
| 72 - Pressure sensor (low) | | |

■ Hydraulic unit 1S - 1 heating circuit + Domestic hot water




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 14 - Pressure relief valve (PRV)

- 15 - Refrigerant to Water Heat Exchanger
- 16 - Connection
- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 31 - Hydronic unit 1 service
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - Non return valve

- 60 - HP Electrical backup
- 61 - DHW Electrical backup
- 72 - Pressure sensor (low)
- 77 - Receiver
- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 105 - Room thermostat
- 150 - Shut-off
- 151 - Safety valve
- 152 - Thermostatic mixer valve
- 210 - Buffer tank
- 501 - Compressor temp. sensor

- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 530 - DHW temp. sensor
- 531 - DHW electrical backup thermal safety

■ Hydraulic unit 1S - 2 heating circuits




- 1 - Compressor
- 2 - Accumulator
- 3 - 4-way valve
- 4 - Heat exchanger (Evaporator)
- 5 - 3-way valve
- 6 - Expansion valve
- 7 - Filter
- 8 - Pressure switch (On/Off)
- 10 - Valve
- 11 - Bleeder valve
- 12 - Circulating pump
- 13 - Flowmeter
- 14 - Pressure relief valve (PRV)
- 15 - Refrigerant to Water Heat Exchanger

- 16 - Connection
- 17 - Antifreeze valve
- 18 - Sediment trap
- 30 - Outdoor unit
- 31 - Hydronic unit 1 service
- 40 - Degasser
- 46 - Pressure sensor (high)
- 50 - Expansion vessel
- 52 - Decoupling bottle
- 53 - Directional valve
- 54 - Manometer
- 56 - Non return valve
- 60 - HP Electrical backup
- 72 - Pressure sensor (low)


- 77 - Receiver
- 100 - Radiator
- 101 - Heating floor
- 102 - Dynamic radiator (fan-convector)
- 105 - Room thermostat
- 200 - Direct heating circuit kit
- 210 - Buffer tank
- 250 - 2 circuits kit
- 252 - Mixing valve
- 501 - Compressor temp. sensor
- 502 - Discharge temp. thermistor
- 503 - Input temp. sensor (Expansion valve)
- 504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)
- 505 - Middle heat exchanger temp. thermistor

- (refrigerant heat exchanger)
- 507 - Flow temp. Thermistor (hydronic heat exchanger)
- 511 - Outdoor temp. thermistor
- 520 - Return temp. sensor (heating circuit)
- 521 - Flow temp. sensor (heating circuit)
- 540 - Flow temp. sensor (Mixed heating circuit)

■ Hydraulic unit 1S - 2 heating circuits + Domestic hot water



■ Hydraulic unit DHW - 1 heating circuit




1 - Compressor
2 - Accumulator
3 - 4-way valve
4 - Heat exchanger (Evaporator)
5 - 3-way valve
6 - Expansion valve
7 - Filter
8 - Pressure switch (On/Off)
10 - Valve
11 - Drain valve
12 - System pump
13 - Flowmeter
14 - Safety valve
15 - Refrigerant to Water Heat Exchanger

16 - Connection
17 - Frost protection valve
18 - Sludge pot (decanter)
30 - Outdoor unit
32 - DHW hydronic unit (2 services)
40 - Degasser
46 - Pressure sensor (high)
50 - Expansion vessel
52 - Decoupling bottle
53 - Directional valve
54 - Manometer
56 - No-return valve
60 - HP Electrical backup
61 - DHW Electrical backup

72 - Pressure sensor (low)
77 - Receiver
100 - Radiator
101 - Underfloor heating system
102 - Dynamic radiator (fan-convector)
105 - Thermostat or room sensor
150 - Disconnector
151 - Safety group
152 - Thermostatic mixing valve
210 - Buffer tank
501 - Compressor temp. sensor
502 - Discharge temp. thermistor
503 - Input temp. sensor (Expansion valve)
504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)

505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)
507 - Flow temp. Thermistor (hydronic heat exchanger)
511 - Outdoor temp. thermistor
520 - Return temp. sensor (heating circuit)
521 - Flow temp. sensor (heating circuit)
530 - DHW temp. sensor
531 - DHW electrical backup thermal safety

■ Hydraulic unit DHW - 2 heating circuits



1 - Compressor

2 - Accumulator

3 - 4-way valve

4 - Heat exchanger (Evaporator)

5 - 3-way valve

6 - Expansion valve

7 - Filter

8 - Pressure switch (On/Off)

10 - Valve

11 - Bleeder valve

12 - Circulating pump

13 - Flowmeter

14 - Pressure relief valve (PRV)

15 - Heat exchanger (Condensor)

16 - Connection

17 - Antifreeze valve

18 - Sediment trap

30 - Outdoor unit

32 - DHW hydronic unit (2 services)

40 - Degasser

46 - Pressure sensor (high)

50 - Expansion vessel

52 - Decoupling bottle

53 - Directional valve

54 - Manometer

56 - Non return valve

60 - HP Electrical backup

61 - DHW Electrical backup

72 - Pressure sensor (low)

77 - Receiver

100 - Radiator

101 - Heating floor

102 - Dynamic radiator (fan-convector)

105 - Room thermostat

150 - Shut-off

151 - Safety valve

152 - Thermostatic mixer valve

200 - Direct heating circuit kit

210 - Buffer tank

250 - 2 circuits kit

252 - Mixing valve

501 - Compressor temp. sensor

502 - Discharge temp. thermistor

503 - Input temp. sensor (Expansion valve)

504 - Inlet heat exchanger temp. thermistor (refrigerant heat exchanger)

505 - Middle heat exchanger temp. thermistor (refrigerant heat exchanger)

507 - Flow temp. Thermistor (hydronic heat exchanger)

511 - Outdoor temp. thermistor

520 - Return temp. sensor (heating circuit)

521 - Flow temp. sensor (heating circuit)

530 - DHW temp. sensor

531 - DHW electrical backup thermal safety

540 - Flow temp. sensor (Mixed heating circuit)

Options

Designation	AUREA 2 COMPACT		AUREA 2		AUREA 2 DHW	
	3-4-5-7	9-12	3-4-5-7	9-12	3-4-5-7	9-12
Trace heating cable	809644					
Condensate drain tray - Small	075902	x	075902	x	075902	x
Condensate drain tray- Large	x	075903	x	075903	x	075903
Rubber feet (x 3)	075803					
Antifreeze 1" valves kit	075610					
Thermostat 105	74511					
Thermostat 225	474002					
Thermostat 228	474003					
Extension regulation kit	074872					
Outdoor sensor	074203					
DHW kit	077057		074873		x	
6 kW backup relay kit	x		075327			
Electrical backup kit 2-4-6 kW	077058		x		x	
Electrical backup kit 9 kW (3~)	075498		x		x	
2 circuits kit + Extension regulation kit	x		520260 (74871+74872)		x	
2 circuits kit + Extension regulation kit	x		x		520270 (74874+74872)	
DHW recirculation kit	x		x		074876	
DHW expansion vessel kit	x		x		074877	
Cooling kit	520271					
1 decoupled zone kit	077053		x		x	
2 decoupled zones kit	077054		x		x	
3 decoupled zones kit	077055		x		x	
Boiler connection kit (without pump)	077056					
Pressure switch kit	075609		x		x	



A series of horizontal dotted lines spanning the width of the page, providing a guide for handwriting practice.

THERMOR-Services
17, rue Croix Fauchet, BP 46 - 45141 Saint Jean de la Ruelle cedex
www.thermor.fr

THERMOR-Servicios
Calle Antonio Machado, 65, 08840. Viladecans, Barcelona, España
www.thermor.es



Cet appareil est identifié par ce symbole. Il signifie que tous les produits électriques et électroniques doivent être impérativement séparés des déchets ménagers. Un circuit spécifique de récupération pour ce type de produits est mis en place dans les pays de l'Union Européenne (*), en Norvège, Islande et au Liechtenstein. N'essayez pas de démonter ce produit vous-même. Cela peut avoir des effets nocifs sur votre santé et sur l'environnement. Le retraitement du liquide réfrigérant, de l'huile et des autres pièces doit être réalisé par un installateur qualifié conformément aux législations locales et nationales en vigueur. Pour son recyclage, cet appareil doit être pris en charge par un service spécialisé et ne doit être en aucun cas jeté avec les ordures ménagères, avec les encombrants ou dans une décharge. Veuillez contacter votre installateur ou le représentant local pour plus d'informations. * En fonction des règlements nationaux de chaque état membre.

Thermor